

Subtype AUSTRIA EMAIL LWPM 14 PRO

Certificate Holder	Groupe Atlantic
Address	Rue des Fondateurs BP 64
ZIP	59660
City	Merville
Country	FR
Certification Body	RISE CERT
Subtype title	AUSTRIA EMAIL LWPM 14 PRO
Registration number	012-C700356
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	0.86 kg
Certification Date	02.10.2024
Testing basis	EN 14511:2022, EN 14825:2022, EN 16147:2017+A1:2022, EN 12102:2022

Model AUSTRIA EMAIL LWPM 14 PRO

Model name	AUSTRIA EMAIL LWPM 14 PRO
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.60 kW	6.70 kW
El input	1.61 kW	2.14 kW
COP	4.73	3.13

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	177 %	142 %
Prated	11.90 kW	12.60 kW
SCOP	4.49	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.50 kW	11.00 kW
COP Tj = -7°C	2.43	1.91
Cdh Tj = -7 °C	1.000	0.990
Pdh Tj = +2°C	6.40 kW	6.70 kW
COP Tj = +2°C	5.00	3.91
Cdh Tj = +2 °C	0.990	0.980
Pdh Tj = +7°C	7.40 kW	4.30 kW

COP Tj = +7°C	5.62	4.66
Cdh Tj = +7 °C	0.990	0.960
Pdh Tj = 12°C	8.40 kW	8.10 kW
COP Tj = 12°C	6.73	5.50
Cdh Tj = +12 °C	0.990	0.980
Pdh Tj = Tbiv	10.50 kW	11.00 kW
COP Tj = Tbiv	2.43	1.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.76
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	0.990
WTOL	70 °C	70 °C
Poff	15 W	15 W
PTO	35 W	35 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.20 kW	1.90 kW
Annual energy consumption Qhe	5471 kWh	7177 kWh

Model AUSTRIA EMAIL LWPM 14 PRO CONTROLBOX

Model name	AUSTRIA EMAIL LWPM 14 PRO CONTROLBOX
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.60 kW	6.70 kW
El input	1.61 kW	2.14 kW
COP	4.73	3.13

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	177 %	142 %
Prated	11.90 kW	12.60 kW
SCOP	4.49	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.50 kW	11.00 kW
COP Tj = -7°C	2.43	1.91
Cdh Tj = -7 °C	1.000	0.990
Pdh Tj = +2°C	6.40 kW	6.70 kW
COP Tj = +2°C	5.00	3.91
Cdh Tj = +2 °C	0.990	0.980
Pdh Tj = +7°C	7.40 kW	4.30 kW

COP Tj = +7°C	5.62	4.66
Cdh Tj = +7 °C	0.990	0.960
Pdh Tj = 12°C	8.40 kW	8.10 kW
COP Tj = 12°C	6.73	5.50
Cdh Tj = +12 °C	0.990	0.980
Pdh Tj = Tbiv	10.50 kW	11.00 kW
COP Tj = Tbiv	2.43	1.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.76
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	0.990
WTOL	70 °C	70 °C
Poff	15 W	15 W
PTO	35 W	35 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.20 kW	1.90 kW
Annual energy consumption Qhe	5471 kWh	7177 kWh

Model AUSTRIA EMAIL LWPKM 14 PRO

Model name	AUSTRIA EMAIL LWPKM 14 PRO
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	120 %
COP	3.00
Heating up time	0:55 h:min
Standby power input	30.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	245 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.60 kW	6.70 kW
El input	1.61 kW	2.14 kW
COP	4.73	3.13

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	177 %	142 %
Prated	11.90 kW	12.60 kW

SCOP	4.49	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.50 kW	11.00 kW
COP Tj = -7°C	2.43	1.91
Cdh Tj = -7 °C	1.000	0.990
Pdh Tj = +2°C	6.40 kW	6.70 kW
COP Tj = +2°C	5.00	3.91
Cdh Tj = +2 °C	0.990	0.980
Pdh Tj = +7°C	7.40 kW	4.30 kW
COP Tj = +7°C	5.62	4.66
Cdh Tj = +7 °C	0.990	0.960
Pdh Tj = 12°C	8.40 kW	8.10 kW
COP Tj = 12°C	6.73	5.50
Cdh Tj = +12 °C	0.990	0.980
Pdh Tj = Tbiv	10.50 kW	11.00 kW
COP Tj = Tbiv	2.43	1.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.70 kW	10.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.44	1.76
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	0.990
WTOL	70 °C	70 °C
Poff	15 W	15 W
PTO	35 W	35 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.20 kW	1.90 kW
Annual energy consumption Qhe	5471 kWh	7177 kWh