

Subtype AQUA F 100

Certificate Holder	Clivet s.p.a.
Address	Via camp lonc 25 c.ap.
ZIP	I-32032
City	z.i. Villapaiera - Feltre (BL)
Country	IT
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	AQUA F 100
Registration number	011-1W0989
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R290
Mass of Refrigerant	0.15 kg
Certification Date	13.02.2025
Testing basis	HP KEYMARK certification scheme rules V14

Model DSDH-P AQ 1 S 100

Model name	DSDH-P AQ 1 S 100
Application	n/a
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Heat Pump for Domestic Hot Water (DHW)

EN 16147 | Operating test

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

EN 12102-2 | Average Climate

Sound power level indoor	54 dB(A)
--------------------------	----------

EN 16147 | Average Climate

Declared load profile	M
Efficiency η_{DHW}	111 %
COP	2.61
Heating up time	6:04 h:min
Standby power input	19.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	110 l

EN 12102-2 | Colder Climate

Sound power level indoor	54 dB(A)
--------------------------	----------

EN 16147 | Colder Climate

Declared load profile	M
Efficiency η_{DHW}	92 %
COP	2.22
Heating up time	7:10 h:min
Standby power input	20.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	108 l

EN 12102-2 | Warmer Climate

Sound power level indoor 54 dB(A)

EN 16147 | Warmer Climate

Declared load profile	M
Efficiency η_{DHW}	114 %
COP	2.74
Heating up time	5:14 h:min
Standby power input	16.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	108 l