

## Subtype MONOBLOC ACTIVE AOWD 17

Certificate Holder	Eurofred S.A.
Address	Marqués de Sentmenat, 97
ZIP	08029
City	Barcelona
Country	ES
Certification Body	BRE Global Limited
Subtype title	MONOBLOC ACTIVE AOWD 17
Registration number	041-K010-19
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.3 kg
Certification Date	04.07.2024
Testing basis	HP KEYMARK certification scheme rules rev. no.14
Testing laboratory	TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN

## Model AOWD-MB-AT17

Model name	AOWD-MB-AT17
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.99 kW	17.36 kW
El input	3.61 kW	5.44 kW
COP	4.71	3.19

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	183 %	145 %
Prated	12.57 kW	11.81 kW
SCOP	4.65	3.71
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.12 kW	10.45 kW
COP Tj = -7°C	3.31	2.31
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	6.82 kW	6.39 kW
COP Tj = +2°C	4.51	3.64
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	7.60 kW	7.44 kW

COP Tj = +7°C	5.60	4.68
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	7.71 kW	7.56 kW
COP Tj = 12°C	6.89	6.18
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	11.12 kW	10.45 kW
COP Tj = Tbiv	3.31	2.31
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.54 kW	12.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.85	1.96
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	75 °C	75 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	58 W	58 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.03 kW	0.00 kW
Annual energy consumption Qhe	5587 kWh	6587 kWh

## Model AOWD-MB-AT17T

Model name	AOWD-MB-AT17T
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	15.73 kW	17.03 kW
El input	3.94 kW	4.79 kW
COP	3.99	3.56

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	61 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	193 %	145 %
Prated	12.55 kW	12.34 kW
SCOP	4.91	3.70
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.11 kW	10.92 kW
COP Tj = -7°C	3.23	2.34
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	6.89 kW	6.80 kW
COP Tj = +2°C	4.83	3.58
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	7.30 kW	7.36 kW

COP Tj = +7°C	6.04	4.74
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	7.78 kW	7.39 kW
COP Tj = 12°C	7.46	6.12
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	11.11 kW	10.92 kW
COP Tj = Tbiv	3.23	2.34
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.61 kW	12.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.89	2.06
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	63 °C	63 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	17 W	17 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.01 kW
Annual energy consumption Qhe	5281 kWh	6895 kWh