

Subtype DC Inverter Air to Water Heat Pump Unit-R32-6HYD

| | |
|---------------------|--|
| Certificate Holder | DUKO Energie s.r.o. |
| Address | Šafaříkova 1737 |
| ZIP | 53901 |
| City | Hlinsko |
| Country | CZ |
| Certification Body | BRE Global Limited |
| Subtype title | DC Inverter Air to Water Heat Pump Unit-R32-6HYD |
| Registration number | 041-K115-01 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R32 |
| Mass of Refrigerant | 0.9 kg |
| Certification Date | 27.08.2025 |
| Testing basis | HP KEYMARK certification scheme rules rev. no.15 |
| Testing laboratory | TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN |

Model Indoor unit: M6kWR32HYD; Outdoor unit: M6kWR32HYD

| | |
|-------------------------------------|---|
| Model name | Indoor unit: M6kWR32HYD; Outdoor unit: M6kWR32HYD |
| Application | Heating (medium temp) |
| Units | Indoor, Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water
EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

| | |
|-------------------------------|--------|
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 3.30 kW | 5.31 kW |
| El input | 0.69 kW | 1.89 kW |
| COP | 4.82 | 2.81 |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 44 dB(A) | 45 dB(A) |
| Sound power level outdoor | 52 dB(A) | 54 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 180 % | 133 % |
| Prated | 4.13 kW | 4.56 kW |
| SCOP | 4.58 | 3.40 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 3.66 kW | 4.04 kW |
| COP Tj = -7°C | 3.15 | 2.03 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 2.30 kW | 2.49 kW |
| COP Tj = +2°C | 4.45 | 3.39 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |

| | | |
|---|-------------|-------------|
| Pdh Tj = +7°C | 2.66 kW | 2.49 kW |
| COP Tj = +7°C | 6.43 | 4.88 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 3.15 kW | 3.02 kW |
| COP Tj = 12°C | 8.64 | 6.83 |
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 3.66 kW | 4.04 kW |
| COP Tj = Tbiv | 3.15 | 2.03 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 4.15 kW | 3.48 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.80 | 1.71 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 58 °C | 58 °C |
| Poff | 13 W | 10 W |
| PTO | 31 W | 31 W |
| PSB | 13 W | 10 W |
| PCK | 44 W | 44 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.00 kW | 1.08 kW |
| Annual energy consumption Qhe | 1865 kWh | 2770 kWh |