

## Subtype ACP 06/08

Certificate Holder	Climer
Address	Carr. Córdoba - Málaga, Km. 77
ZIP	14900
City	Córdoba
Country	ES
Certification Body	ICIM S.p.A.
Subtype title	ACP 06/08
Registration number	ICIM-PDC-000201
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	0.97 kg
Certification Date	30.08.2023

## Model ACP06

Model name	ACP06
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.13 kW	5.95 kW
El input	1.25 kW	2.04 kW
COP	4.90	2.92

### EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.64 kW	
Cooling capacity	5.19	
EER	3.16	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	175 %	126 %
Prated	7.00 kW	7.00 kW
SCOP	4.46	3.22
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C

Pdh Tj = -7°C	6.10 kW	6.00 kW
COP Tj = -7°C	2.96	2.17
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	3.80 kW	3.60 kW
COP Tj = +2°C	4.49	3.22
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	5.37	3.82
Cdh Tj = +7 °C	0.963	0.972
Pdh Tj = 12°C	3.50 kW	3.30 kW
COP Tj = 12°C	7.29	5.05
Cdh Tj = +12 °C	0.954	0.966
Pdh Tj = Tbiv	6.10 kW	6.00 kW
COP Tj = Tbiv	2.96	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.10 kW	6.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.73	2.04
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.90 kW	1.00 kW
Annual energy consumption Qhe	3211 kWh	4321 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	5.19 kW	
SEER	4.42	
Pdc Tj = 35°C	5.19 kW	
EER Tj = 35°C	3.16	
Pdc Tj = 30°C	3.80 kW	
EER Tj = 30°C	4.04	
Cdc Tj = 30 °C	0.977	
Pdc Tj = 25°C	2.45 kW	
EER Tj = 25°C	4.80	
Cdc Tj = 25 °C	0.957	
Pdc Tj = 20°C	2.86 kW	
EER Tj = 20°C	6.51	
Cdc Tj = 20 °C	0.950	
Poff	22 W	
PTO	0 W	

PSB	28 W
PCK	0 W
Annual energy consumption Qce	705 kWh

## Model ACP08

Model name	ACP08
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.81 kW	7.63 kW
El input	1.71 kW	2.62 kW
COP	4.57	2.91

### EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	1.97 kW	
Cooling capacity	6.14	
EER	3.12	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	175 %	128 %
Prated	8.00 kW	7.00 kW
SCOP	4.46	3.27
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C

Pdh Tj = -7°C	6.80 kW	6.60 kW
COP Tj = -7°C	2.98	2.21
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.20 kW	3.90 kW
COP Tj = +2°C	4.58	3.26
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	5.16	3.90
Cdh Tj = +7 °C	0.965	0.972
Pdh Tj = 12°C	3.60 kW	3.40 kW
COP Tj = 12°C	6.85	5.23
Cdh Tj = +12 °C	0.958	0.966
Pdh Tj = Tbiv	6.80 kW	6.60 kW
COP Tj = Tbiv	2.98	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	6.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.20 kW	0.60 kW
Annual energy consumption Qhe	3560 kWh	4721 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	6.14 kW	
SEER	4.51	
Pdc Tj = 35°C	6.14 kW	
EER Tj = 35°C	3.12	
Pdc Tj = 30°C	4.51 kW	
EER Tj = 30°C	4.08	
Cdc Tj = 30 °C	0.980	
Pdc Tj = 25°C	2.90 kW	
EER Tj = 25°C	4.85	
Cdc Tj = 25 °C	0.963	
Pdc Tj = 20°C	2.90 kW	
EER Tj = 20°C	6.27	
Cdc Tj = 20 °C	0.952	
Poff	22 W	
PTO	0 W	

PSB	28 W
PCK	0 W
Annual energy consumption $Q_{ce}$	825 kWh

Model ACP08-LN		
Model name	ACP08-LN	
Application	Heating (medium temp)	
Units	Outdoor	
Climate zone (for heating)	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C	
Any additional heat sources	n/a	
General data		
Power supply	1x230V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4   Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2   Heating		
	Low temperature	Medium temperature
Heat output	4.78 kW	4.68 kW
El input	0.95 kW	1.46 kW
COP	5.03	3.21
EN 14511-2   Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	1.97 kW	
Cooling capacity	6.14	
EER	3.12	
EN 12102-1   Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)
EN 14825   Average Climate		
	Low temperature	Medium temperature
ηs	180 %	131 %
Prated	8.00 kW	7.00 kW
SCOP	4.57	3.34
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C



Pdh Tj = -7°C	6.70 kW	6.50 kW
COP Tj = -7°C	3.00	2.23
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.10 kW	3.80 kW
COP Tj = +2°C	4.67	3.32
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	5.49	4.08
Cdh Tj = +7 °C	0.963	0.970
Pdh Tj = 12°C	3.50 kW	3.40 kW
COP Tj = 12°C	7.02	5.36
Cdh Tj = +12 °C	0.956	0.965
Pdh Tj = Tbiv	6.70 kW	6.50 kW
COP Tj = Tbiv	3.00	2.23
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.50 kW	6.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.61	1.92
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.50 kW	0.90 kW
Annual energy consumption Qhe	3424 kWh	4557 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	6.14 kW	
SEER	4.51	
Pdc Tj = 35°C	6.14 kW	
EER Tj = 35°C	3.12	
Pdc Tj = 30°C	4.51 kW	
EER Tj = 30°C	4.08	
Cdc Tj = 30 °C	0.980	
Pdc Tj = 25°C	2.90 kW	
EER Tj = 25°C	4.85	
Cdc Tj = 25 °C	0.963	
Pdc Tj = 20°C	2.90 kW	
EER Tj = 20°C	6.27	
Cdc Tj = 20 °C	0.952	
Poff	22 W	
PTO	0 W	

PSB	28 W
PCK	0 W
Annual energy consumption Qce	825 kWh