

Subtype DAIKIN ALTHERMA 3 R 7 ECH2O 04KW (500L)

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA 3 R 7 ECH2O 04KW (500L)
Registration number	011-1W0368
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	09.04.2020
Testing basis	HP KEYMARK certification scheme rules rev. 14
Testing laboratory	Universität Stuttgart, Prüfstelle HLK am Institut für Gebäudeenergetik, Thermotechnik und Energiespeicherung (IGTE), DE

Model ERGA04EV7 / EHSX(B)04P50E

Model name	ERGA04EV7 / EHSX(B)04P50E
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	125 %
COP	3.06
Heating up time	2:41 h:min
Standby power input	25.3 W
Reference hot water temperature	44.6 °C
Mixed water at 40°C	227.9 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.36 kW	4.90 kW
El input	0.83 kW	1.85 kW
COP	5.23	2.65

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	129 %

Prated	6.0 kW	6.0 kW
SCOP	4.96	3.29
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.2 kW	5.3 kW
COP Tj = -7°C	3.23	1.97
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	3.7 kW	3.3 kW
COP Tj = +2°C	4.94	3.23
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	3.2 kW	3.0 kW
COP Tj = +7°C	6.19	4.40
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	3.3 kW	3.3 kW
COP Tj = 12°C	7.78	6.10
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	6.2 kW	5.3 kW
COP Tj = Tbiv	3.23	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.2 kW	4.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.37
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.8 kW	2.0 kW
Annual energy consumption Qhe	2501 kWh	3769 kWh