

## Subtype DAIKIN ALTHERMA 3 R F 14KW (230L)

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DAIKIN ALTHERMA 3 R F 14KW (230L)
Registration number	011-1W0496
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	3.8 kg
Certification Date	10.11.2021
Testing basis	HP KEYMARK certification scheme rules rev. 8

## Model ERLA14DV3 / EBVH16S23D(6V/9W)

Model name	ERLA14DV3 / EBVH16S23D(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

### EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	126 %
Prated	11 kW	11 kW
SCOP	4.60	3.22
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4935 kWh	7047 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	239 %	166 %
Prated	11 kW	12.1 kW
SCOP	6.04	4.23
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.52	2.21
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2431 kWh	3818 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	

EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DW1 / EBVH16S23D(6V/9W)

Model name	ERLA14DW1 / EBVH16S23D(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	126 %
Prated	11 kW	11 kW
SCOP	4.60	3.22
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4935 kWh	7047 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	239 %	166 %
Prated	11 kW	12.1 kW
SCOP	6.04	4.23
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.53	2.22
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2431 kWh	3818 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	



EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DV3 / EBVH16SU23D6V

Model name	ERLA14DV3 / EBVH16SU23D6V
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

### General data

Power supply	1x230V 50Hz
Off-peak product	n/a

### Outdoor Air/Water

#### EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

#### EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

### EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	126 %
Prated	11 kW	11 kW
SCOP	4.60	3.22
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4935 kWh	7047 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	239 %	166 %
Prated	11 kW	12.1 kW
SCOP	6.04	4.23
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.54	2.23
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2431 kWh	3818 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	

EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DW1 / EBVH16SU23D6V

Model name	ERLA14DW1 / EBVH16SU23D6V
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	126 %
Prated	11 kW	11 kW
SCOP	4.60	3.22
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4935 kWh	7047 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	239 %	166 %
Prated	11 kW	12.1 kW
SCOP	6.04	4.23
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.55	2.24
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2431 kWh	3818 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	



EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DV3 / EBVX16S23D(6V/9W)

Model name	ERLA14DV3 / EBVX16S23D(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	184 %	128 %
Prated	11 kW	11 kW
SCOP	4.68	3.26
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4851 kWh	6962 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	249 %	171 %
Prated	11 kW	12.1 kW
SCOP	6.31	4.35
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.56	2.25
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2330 kWh	3717 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	

EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DW1 / EBVX16S23D(6V/9W)

Model name	ERLA14DW1 / EBVX16S23D(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	184 %	128 %
Prated	11 kW	11 kW
SCOP	4.68	3.26
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4851 kWh	6962 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	249 %	171 %
Prated	11 kW	12.1 kW
SCOP	6.31	4.35
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.57	2.26
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2330 kWh	3717 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	



EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DV3 / EBVZ16S23D(6V/9W)

Model name	ERLA14DV3 / EBVZ16S23D(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

### General data

Power supply	1x230V 50Hz
Off-peak product	n/a

### Outdoor Air/Water

#### EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

#### EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

### EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	126 %
Prated	11 kW	11 kW
SCOP	4.60	3.22
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4935 kWh	7047 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	239 %	166 %
Prated	11 kW	12.1 kW
SCOP	6.04	4.23
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.58	2.27
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2431 kWh	3818 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	

EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DW1 / EBVZ16S23D(6V/9W)

Model name	ERLA14DW1 / EBVZ16S23D(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

### General data

Power supply	3x400V 50Hz
Off-peak product	n/a

### Outdoor Air/Water

#### EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

#### EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

### EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	126 %
Prated	11 kW	11 kW
SCOP	4.60	3.22
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4935 kWh	7047 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	239 %	166 %
Prated	11 kW	12.1 kW
SCOP	6.04	4.23
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.59	2.28
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2431 kWh	3818 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	



EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DV3 / EBVH16S23D(6V/9W) + cooling kit

Model name	ERLA14DV3 / EBVH16S23D(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	184 %	128 %
Prated	11 kW	11 kW
SCOP	4.68	3.26
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4851 kWh	6962 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	249 %	171 %
Prated	11 kW	12.1 kW
SCOP	6.31	4.35
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.60	2.29
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2330 kWh	3717 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	

EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DW1 / EBVH16S23D(6V/9W) + cooling kit

Model name	ERLA14DW1 / EBVH16S23D(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

#### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	184 %	128 %
Prated	11 kW	11 kW
SCOP	4.68	3.26
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4851 kWh	6962 kWh

#### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	249 %	171 %
Prated	11 kW	12.1 kW
SCOP	6.31	4.35
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.61	2.30
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2330 kWh	3717 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	



EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DV3 / EBVZ16S23D(6V/9W) + cooling kit

Model name	ERLA14DV3 / EBVZ16S23D(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	184 %	128 %
Prated	11 kW	11 kW
SCOP	4.68	3.26
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4851 kWh	6962 kWh

### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	249 %	171 %
Prated	11 kW	12.1 kW
SCOP	6.31	4.35
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.62	2.31
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2330 kWh	3717 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	

EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh

## Model ERLA14DW1 / EBVZ16S23D(6V/9W) + cooling kit

Model name	ERLA14DW1 / EBVZ16S23D(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer, Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	109 %
COP	2.63
Heating up time	1:11 h:min
Standby power input	43.2 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	124 %
COP	3.00
Heating up time	1:10 h:min
Standby power input	37.6 W
Reference hot water temperature	51.5 °C
Mixed water at 40°C	295.0 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.87 kW
El input	2.46 kW	4.11 kW
COP	4.87	2.89

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	4.34 kW	
Cooling capacity	12.92	
EER	2.98	

#### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	62.0 dB(A)	62.0 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	184 %	128 %
Prated	11 kW	11 kW
SCOP	4.68	3.26
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.8 kW	8.5 kW
COP Tj = -7°C	2.99	1.80
Cdh Tj = -7 °C	1.0	
Pdh Tj = +2°C	6.1 kW	6.2 kW
COP Tj = +2°C	4.35	3.28
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.6 kW	4.4 kW
COP Tj = +7°C	6.70	4.88
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.4 kW	5.3 kW
COP Tj = 12°C	8.65	6.58
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	9.8 kW	8.9 kW
COP Tj = Tbiv	2.99	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.1 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	1.76
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.9 kW	4.0 kW
Annual energy consumption Qhe	4851 kWh	6962 kWh

#### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	249 %	171 %
Prated	11 kW	12.1 kW
SCOP	6.31	4.35
Tbiv	2 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.0 kW	10.1 kW
COP Tj = +2°C	3.51	2.20
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	7.4 kW	7.6 kW
COP Tj = +7°C	5.77	3.83
Cdh Tj = +7 °C	1.0	1.0
Pdh Tj = 12°C	5.2 kW	5.0 kW
COP Tj = 12°C	7.73	5.69
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	11.0 kW	11.1 kW
COP Tj = Tbiv	3.51	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.95 kW	10.06 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.63	2.32
WTOL	35 °C	55 °C
Poff	23 W	23 W
PTO	23 W	23 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	2.04 kW
Annual energy consumption Qhe	2330 kWh	3717 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	12.90 kW	
SEER	5.86	
Pdc Tj = 35°C	12.90 kW	
EER Tj = 35°C	2.96	
Pdc Tj = 30°C	8.80 kW	
EER Tj = 30°C	4.77	
Cdc Tj = 30 °C	0.990	
Pdc Tj = 25°C	6.20 kW	



EER Tj = 25°C	7.00
Cdc Tj = 25 °C	0.970
Pdc Tj = 20°C	5.90 kW
EER Tj = 20°C	8.88
Cdc Tj = 20 °C	0.960
Poff	23 W
PTO	23 W
PSB	23 W
PCK	0 W
Annual energy consumption Qce	1314 kWh