

Subtype EVI DC Inverter Air Source Heat Pump- R32- 25B

Certificate Holder	Guangzhou Sprsun New Energy Technology Dev. Co., Ltd,
Address	No.15 Tangxi Road, Yinsha Industrial Park
ZIP	511338
City	Guangzhou
Country	CN
Certification Body	BRE Global Limited
Subtype title	EVI DC Inverter Air Source Heat Pump- R32- 25B
Registration number	041-K036-07
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	27.09.2024
Testing basis	HP KEYMARK certification scheme rules rev. no.14

Model CGK-025V3L-B

Model name	CGK-025V3L-B
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.92 kW	8.17 kW
El input	1.69 kW	2.73 kW
COP	4.67	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	62 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	7.20 kW	7.47 kW
SCOP	4.46	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.37 kW	6.61 kW
COP Tj = -7°C	3.39	2.33
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.19 kW	4.04 kW
COP Tj = +2°C	4.46	3.34
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.39 kW	4.25 kW

COP Tj = +7°C	5.66	4.24
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.99 kW	4.88 kW
COP Tj = 12°C	7.59	5.76
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.37 kW	6.61 kW
COP Tj = Tbiv	3.39	2.33
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.84 kW	6.28 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.11
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	40 W	40 W
PSB	8 W	8 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.37 kW	1.19 kW
Annual energy consumption Qhe	3335 kWh	4642 kWh