

## Subtype WPL 07 ACS classic

Certificate Holder	STIEBEL ELTRON GmbH & Co KG
Address	Dr. Stiebel Straße 33
ZIP	37603
City	Holzminden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	WPL 07 ACS classic
Registration number	011-1W0060
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	1.1 kg
Certification Date	19.01.2017

## Model WPL 07 ACS classic + HSBB 200 classic, HSBB 200 S classic

Model name	WPL 07 ACS classic + HSBB 200 classic, HSBB 200 S classic
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	No

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	113 %
COP	2.70
Heating up time	1:50 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	245 l

## EN 16147 | Colder Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	104 %
COP	1.00
Heating up time	2:52 h:min
Standby power input	42.1 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	104 %
COP	1.00
Heating up time	2:52 h:min
Standby power input	42.1 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

#### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.27 kW	1.92 kW
El input	0.50 kW	0.74 kW
COP	4.54	2.59

#### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	166 %	116 %
Prated	3.62 kW	3.83 kW
SCOP	4.22	2.96
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-7 °C
Pdh Tj = -7°C	3.20 kW	2.79 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	1.95 kW	2.01 kW
COP Tj = +2°C	4.11	2.94
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.59 kW	1.25 kW
COP Tj = +7°C	5.81	4.13
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.66 kW	1.54 kW
COP Tj = 12°C	6.34	5.13
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.20 kW	3.09 kW
COP Tj = Tbiv	2.88	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.04 kW	2.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.01
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	30 W	30 W

PSB	17 W	17 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	3.83 kW
Annual energy consumption Q <sub>he</sub>	1771 kWh	2672 kWh

## Model WPL 07 ACS classic

Model name	WPL 07 ACS classic
Application	Heating (low temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	No

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.27 kW	
El input	0.50 kW	
COP	4.54	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	
Sound power level outdoor	52 dB(A)	

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	166 %	
Prated	3.62 kW	
SCOP	4.22	
Tbiv	-7 °C	
TOL	-10 °C	
Pdh Tj = -7°C	3.20 kW	
COP Tj = -7°C	2.88	
Cdh Tj = -7 °C	0.900	
Pdh Tj = +2°C	1.95 kW	
COP Tj = +2°C	4.11	
Cdh Tj = +2 °C	0.900	

Pdh Tj = +7°C	1.59 kW
COP Tj = +7°C	5.81
Cdh Tj = +7 °C	0.900
Pdh Tj = 12°C	1.66 kW
COP Tj = 12°C	6.34
Cdh Tj = +12 °C	0.900
Pdh Tj = Tbiv	3.20 kW
COP Tj = Tbiv	2.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.07
Rated airflow rate	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	60 °C
Poff	17 W
PTO	30 W
PSB	17 W
PCK	5 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.58 kW
Annual energy consumption Qhe	1771 kWh

#### EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	
Sound power level outdoor	52 dB(A)	

#### EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	148 %	
Prated	3.38 kW	
SCOP	3.77	
Tbiv	-15 °C	
TOL	-20 °C	
Pdh Tj = -7°C	2.05 kW	
COP Tj = -7°C	3.20	
Cdh Tj = -7 °C	0.900	
Pdh Tj = +2°C	1.25 kW	
COP Tj = +2°C	4.55	
Cdh Tj = +2 °C	0.900	
Pdh Tj = +7°C	1.39 kW	
COP Tj = +7°C	6.03	
Cdh Tj = +7 °C	0.900	
Pdh Tj = 12°C	1.64 kW	

COP Tj = 12°C	6.22
Cdh Tj = +12 °C	0.900
Pdh Tj = Tbiv	2.76 kW
COP Tj = Tbiv	2.56
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.13
Rated airflow rate	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	60 °C
Poff	17 W
PTO	30 W
PSB	17 W
PCK	5 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	3.38 kW
Annual energy consumption Qhe	2208 kWh
Pdh Tj = -15°C (if TOL	
COP Tj = -15°C (if TOL	
Cdh Tj = -15 °C	

#### EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	
Sound power level outdoor	52 dB(A)	

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	200 %	
Prated	3.00 kW	
SCOP	5.07	
Tbiv	2 °C	
TOL	2 °C	
Pdh Tj = -7°C	0.00 kW	
COP Tj = -7°C	0.00	
Pdh Tj = +2°C	3.04 kW	
COP Tj = +2°C	3.39	
Cdh Tj = +2 °C	0.900	
Pdh Tj = +7°C	1.95 kW	
COP Tj = +7°C	5.18	
Cdh Tj = +7 °C	0.900	
Pdh Tj = 12°C	1.63 kW	
COP Tj = 12°C	6.14	
Cdh Tj = +12 °C	0.900	

Pdh Tj = Tbiv	3.04 kW
COP Tj = Tbiv	3.39
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.04 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.39
Rated airflow rate	0 m <sup>3</sup> /h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900
WTOL	60 °C
Poff	17 W
PTO	30 W
PSB	17 W
PCK	5 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	791 kWh



## Model WPL 07 ACS classic + HSBC 200 classic, HSBC 200 S classic

Model name	WPL 07 ACS classic + HSBC 200 classic, HSBC 200 S classic
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	No

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	113 %
COP	2.70
Heating up time	1:50 h:min
Standby power input	35.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	245 l

## EN 16147 | Colder Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	104 %
COP	1.00
Heating up time	2:52 h:min
Standby power input	42.1 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	104 %
COP	1.00
Heating up time	2:52 h:min
Standby power input	42.1 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

#### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.27 kW	1.92 kW
El input	0.50 kW	0.74 kW
COP	4.54	2.59

#### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	166 %	116 %
Prated	3.62 kW	3.83 kW
SCOP	4.22	2.96
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-7 °C
Pdh Tj = -7°C	3.20 kW	2.79 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	1.95 kW	2.01 kW
COP Tj = +2°C	4.11	2.94
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.59 kW	1.25 kW
COP Tj = +7°C	5.81	4.13
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.66 kW	1.54 kW
COP Tj = 12°C	6.34	5.13
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.20 kW	3.09 kW
COP Tj = Tbiv	2.88	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.04 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.20
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	30 W	30 W

PSB	17 W	17 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	3.83 kW
Annual energy consumption Q <sub>he</sub>	1771 kWh	2672 kWh

## Model WPL 07 ACS classic + HSBB/HSBC 180 (S) Plus (GB) "Profile M"

Model name	WPL 07 ACS classic + HSBB/HSBC 180 (S) Plus (GB) "Profile M"
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

### General data

Power supply	1x230V 50Hz
Off-peak product	n/a

### Outdoor Air/Water

#### EN 16147 | Average Climate

Declared load profile	M
Efficiency $\eta_{DHW}$	91 %
COP	2.08
Heating up time	1:58 h:min
Standby power input	39.8 W
Reference hot water temperature	48.9 °C
Mixed water at 40°C	226 l

#### EN 16147 | Colder Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	104 %
COP	1.00
Heating up time	2:52 h:min
Standby power input	42.1 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

#### EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	104 %
COP	1.00
Heating up time	2:52 h:min
Standby power input	42.1 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

#### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.27 kW	1.92 kW
El input	0.50 kW	0.74 kW
COP	4.54	2.59

#### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	166 %	116 %
Prated	3.62 kW	3.83 kW
SCOP	4.22	2.96
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-7 °C
Pdh Tj = -7°C	3.20 kW	2.79 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	1.95 kW	2.01 kW
COP Tj = +2°C	4.11	2.94
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.59 kW	1.25 kW
COP Tj = +7°C	5.81	4.13
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.66 kW	1.54 kW
COP Tj = 12°C	6.34	5.13
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.20 kW	3.09 kW
COP Tj = Tbiv	2.88	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.04 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.20
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	30 W	30 W

PSB	17 W	17 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	3.83 kW
Annual energy consumption Q <sub>he</sub>	1771 kWh	2672 kWh

## Model WPL 07 ACS classic + HSBB/HSBC 180 (S) Plus (GB) "Profile L"

Model name	WPL 07 ACS classic + HSBB/HSBC 180 (S) Plus (GB) "Profile L"
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	116 %
COP	2.76
Heating up time	1:50 h:min
Standby power input	39.8 W
Reference hot water temperature	49.1 °C
Mixed water at 40°C	219 l

## EN 16147 | Colder Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	104 %
COP	1.00
Heating up time	2:52 h:min
Standby power input	42.1 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

## EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	104 %
COP	1.00
Heating up time	2:52 h:min
Standby power input	42.1 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	245 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

#### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	2.27 kW	1.92 kW
El input	0.50 kW	0.74 kW
COP	4.54	2.59

#### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	33 dB(A)	33 dB(A)
Sound power level outdoor	52 dB(A)	52 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	166 %	116 %
Prated	3.62 kW	3.83 kW
SCOP	4.22	2.96
Tbiv	-7 °C	-5 °C
TOL	-10 °C	-7 °C
Pdh Tj = -7°C	3.20 kW	2.79 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	1.95 kW	2.01 kW
COP Tj = +2°C	4.11	2.94
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	1.59 kW	1.25 kW
COP Tj = +7°C	5.81	4.13
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.66 kW	1.54 kW
COP Tj = 12°C	6.34	5.13
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.20 kW	3.09 kW
COP Tj = Tbiv	2.88	2.20
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.04 kW	3.09 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.51	2.20
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	17 W	17 W
PTO	30 W	30 W



PSB	17 W	17 W
PCK	5 W	5 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.58 kW	3.83 kW
Annual energy consumption Q <sub>he</sub>	1771 kWh	2672 kWh