

Subtype Jäspi Inverter Nordic 16

Certificate Holder	Kaukora
Address	Tuotekatu 11
ZIP	FI-21200
City	Raisio
Country	FI
Certification Body	RISE CERT
Subtype title	Jäspi Inverter Nordic 16
Registration number	012-SC0655-18
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	3 kg
Certification Date	05.05.2020
Testing laboratory	Danish Technological Institute (DTI), DK

Model Jäspi Inverter Nordic 16

Model name	Jäspi Inverter Nordic 16
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Colder Climate
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	No

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.94 kW	7.25 kW
El input	1.43 kW	2.35 kW
COP	4.85	3.08

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	55 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	199 %	153 %
Prated	11.00 kW	12.30 kW
SCOP	5.05	3.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	10.90 kW
COP Tj = -7°C	3.41	2.48
Pdh Tj = +2°C	6.50 kW	6.70 kW
COP Tj = +2°C	5.08	3.96
Pdh Tj = +7°C	6.90 kW	5.90 kW
COP Tj = +7°C	5.95	4.69
Pdh Tj = 12°C	6.80 kW	6.50 kW
COP Tj = 12°C	7.36	5.81
Pdh Tj = Tbiv	9.70 kW	10.90 kW

COP Tj = Tbiv	3.41	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	11.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.11	2.40
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	7 W	7 W
PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.70 kW
Annual energy consumption Qhe	4508 kWh	6530 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	165 %	134 %
Prated	13.00 kW	14.00 kW
SCOP	4.19	3.41
Tbiv	-12 °C	-12 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.90 kW	8.50 kW
COP Tj = -7°C	3.50	2.85
Pdh Tj = +2°C	6.20 kW	6.10 kW
COP Tj = +2°C	5.25	4.15
Pdh Tj = +7°C	5.90 kW	6.00 kW
COP Tj = +7°C	5.60	4.80
Pdh Tj = 12°C	6.70 kW	6.40 kW
COP Tj = 12°C	7.00	5.80
Pdh Tj = Tbiv	9.60 kW	10.30 kW
COP Tj = Tbiv	3.15	2.55
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.30 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.94
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	7 W	7 W

PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.70 kW	5.30 kW
Annual energy consumption Q _{he}	7639 kWh	10108 kWh