

Subtype Ecodan Power Inverter 12

Certificate Holder	Mitsubishi Electric Air Conditioning Systems Europe LTD
Address	Nettlehill Road, Houston Industrial Estate
ZIP	EH54 5EQ
City	Livingston
Country	GB
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
Subtype title	Ecodan Power Inverter 12
Registration number	037-0051-20
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	4.6 kg
Certification Date	29.02.2024
Testing basis	HP Keymark scheme rules rev. no. 7
Testing laboratory	SZU Brno, CZ

Model PUHZ-SW120VHA(-BS) + EHST20C-M*D

Model name	PUHZ-SW120VHA(-BS) + EHST20C-M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	138 %
COP	3.25
Heating up time	01:29 h:min
Standby power input	35.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	278 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	125 %
Prated	12.9 kW	12.1 kW

SCOP	4.13	3.21
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.17	3.11
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.55	4.47
Cdh Tj = +7 °C	1	0.99
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.5
Cdh Tj = +12 °C	1	0.99
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6448 kWh	7790 kWh

Model PUAZ-SW120VHA(-BS) + EHST20C-*M*D

Model name	PUAZ-SW120VHA(-BS) + EHST20C-*M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	138 %
COP	3.25
Heating up time	01:29 h:min
Standby power input	35.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	278 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	125 %
Prated	12.9 kW	12.1 kW

SCOP	4.13	3.21
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.17	3.11
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.55	4.47
Cdh Tj = +7 °C	1	0.99
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.5
Cdh Tj = +12 °C	1	0.99
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6448 kWh	7790 kWh

Model PUHZ-SW120VHA(-BS) + EHSC-M*D

Model name	PUHZ-SW120VHA(-BS) + EHSC-M*D
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	125 %
Prated	12.9 kW	12.1 kW
SCOP	4.13	3.21
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.17	3.11
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW

COP Tj = +7°C	5.55	4.47
Cdh Tj = +7 °C	1	0.99
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.5
Cdh Tj = +12 °C	1	0.99
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6448 kWh	7790 kWh

Model PUAZ-SW120VHA(-BS) + EHSC-*M*D

Model name	PUAZ-SW120VHA(-BS) + EHSC-*M*D
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	125 %
Prated	12.9 kW	12.1 kW
SCOP	4.13	3.21
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.17	3.11
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW

COP Tj = +7°C	5.55	4.47
Cdh Tj = +7 °C	1	0.99
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.5
Cdh Tj = +12 °C	1	0.99
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6448 kWh	7790 kWh

Model PUHZ-SW120VHA(-BS) + ERST20C-*M*D

Model name	PUHZ-SW120VHA(-BS) + ERST20C-*M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	138 %
COP	3.25
Heating up time	01:29 h:min
Standby power input	35.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	278 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	127 %

Prated	12.9 kW	12.1 kW
SCOP	4.18	3.24
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.19	3.13
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.55	4.47
Cdh Tj = +7 °C	1	0.99
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.5
Cdh Tj = +12 °C	1	0.99
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6377 kWh	7710 kWh

Model PUAZ-SW120VHA(-BS) + ERSC-M*D

Model name	PUAZ-SW120VHA(-BS) + ERSC-M*D
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	127 %
Prated	12.9 kW	12.1 kW
SCOP	4.18	3.24
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.19	3.13
Cdh Tj = +2 °C	1	0.99

Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.55	4.47
Cdh Tj = +7 °C	1	0.99
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.5
Cdh Tj = +12 °C	1	0.99
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6377 kWh	7710 kWh

Model PUAZ-SW120VHA(-BS) + ERSC-*M*D

Model name	PUAZ-SW120VHA(-BS) + ERSC-*M*D
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	127 %
Prated	12.9 kW	12.1 kW
SCOP	4.18	3.24
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.19	3.13
Cdh Tj = +2 °C	1	0.99

Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.55	4.47
Cdh Tj = +7 °C	1	0.99
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.5
Cdh Tj = +12 °C	1	0.99
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6377 kWh	7710 kWh

Model PUAZ-SW120YHA(-BS) + EHST20C-M*D

Model name	PUAZ-SW120YHA(-BS) + EHST20C-M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	138 %
COP	3.25
Heating up time	01:29 h:min
Standby power input	35.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	278 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	125 %
Prated	12.9 kW	12.1 kW

SCOP	4.13	3.21
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.18	3.13
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.63	4.5
Cdh Tj = +7 °C	1	0.98
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.55
Cdh Tj = +12 °C	1	0.98
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6458 kWh	7788 kWh

Model PUHZ-SW120YHA(-BS) + EHST20C-*M*D

Model name	PUHZ-SW120YHA(-BS) + EHST20C-*M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	138 %
COP	3.25
Heating up time	01:29 h:min
Standby power input	35.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	278 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	125 %
Prated	12.9 kW	12.1 kW

SCOP	4.13	3.21
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.18	3.13
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.63	4.5
Cdh Tj = +7 °C	1	0.98
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.55
Cdh Tj = +12 °C	1	0.98
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6458 kWh	7788 kWh

Model PUAZ-SW120YHA(-BS) + EHSC-M*D

Model name	PUAZ-SW120YHA(-BS) + EHSC-M*D
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	125 %
Prated	12.9 kW	12.1 kW
SCOP	4.13	3.21
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.18	3.13
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW

COP Tj = +7°C	5.63	4.5
Cdh Tj = +7 °C	1	0.98
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.55
Cdh Tj = +12 °C	1	0.98
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6458 kWh	7788 kWh

Model PUAZ-SW120YHA(-BS) + EHSC-*M*D

Model name	PUAZ-SW120YHA(-BS) + EHSC-*M*D
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	162 %	125 %
Prated	12.9 kW	12.1 kW
SCOP	4.13	3.21
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.18	3.13
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW

COP Tj = +7°C	5.63	4.5
Cdh Tj = +7 °C	1	0.98
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.55
Cdh Tj = +12 °C	1	0.98
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6458 kWh	7788 kWh

Model PUAZ-SW120YHA(-BS) + ERST20C-*M*D

Model name	PUAZ-SW120YHA(-BS) + ERST20C-*M*D
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	138 %
COP	3.25
Heating up time	01:29 h:min
Standby power input	35.0 W
Reference hot water temperature	52.3 °C
Mixed water at 40°C	278 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	127 %

Prated	12.9 kW	12.1 kW
SCOP	4.18	3.24
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.18	3.13
Cdh Tj = +2 °C	1	0.99
Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.63	4.5
Cdh Tj = +7 °C	1	0.98
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.55
Cdh Tj = +12 °C	1	0.98
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6377 kWh	7708 kWh

Model PUHZ-SW120YHA(-BS) + ERSC-M*D

Model name	PUHZ-SW120YHA(-BS) + ERSC-M*D
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	127 %
Prated	12.9 kW	12.1 kW
SCOP	4.18	3.24
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.18	3.13
Cdh Tj = +2 °C	1	0.99

Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.63	4.5
Cdh Tj = +7 °C	1	0.98
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.55
Cdh Tj = +12 °C	1	0.98
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6377 kWh	7708 kWh

Model PUAZ-SW120YHA(-BS) + ERSC-*M*D

Model name	PUAZ-SW120YHA(-BS) + ERSC-*M*D
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16 kW	15.2 kW
El input	3.9 kW	6.03 kW
COP	4.1	2.52

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	72 dB(A)	72 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	127 %
Prated	12.9 kW	12.1 kW
SCOP	4.18	3.24
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	11.4 kW	10.7 kW
COP Tj = -7°C	2.37	1.83
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	6.9 kW	6.5 kW
COP Tj = +2°C	4.18	3.13
Cdh Tj = +2 °C	1	0.99

Pdh Tj = +7°C	6.5 kW	6 kW
COP Tj = +7°C	5.63	4.5
Cdh Tj = +7 °C	1	0.98
Pdh Tj = 12°C	7.7 kW	7.4 kW
COP Tj = 12°C	7.32	6.55
Cdh Tj = +12 °C	1	0.98
Pdh Tj = Tbiv	11.4 kW	10.7 kW
COP Tj = Tbiv	2.37	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.5 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.14	1.74
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.4 kW	2.1 kW
Annual energy consumption Qhe	6377 kWh	7708 kWh