Subtype Air Source Heat Pump R290-15	
Certificate Holder	Jiangsu Micoe Solar Energy Co., Ltd
Address	No.199, Yingzhou Road,
ZIP	222000
City	LianyungangCity, Jiangsu Province
Country	CN
Certification Body	BRE Global Limited
Subtype title	Air Source Heat Pump R290-15
Registration number	041-K061-07
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.05 kg
Certification Date	08.08.2023
Testing basis	Heat Pump KEYMARK certification Scheme rules v12
Testing laboratory	TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN

Model MMHP15D1	
Model name	MMHP15D1
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data	
Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating		
	Low temperature	Medium temperature
Heat output	12.38 kW	12.40 kW
El input	2.66 kW	4.18 kW
COP	4.66	2.97

EN 12102-1 | Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	67 dB(A)	68 dB(A)

EN 14825 | Average Climate		
	Low temperature	Medium temperature
ηs	188 %	148 %
Prated	9.90 kW	10.22 kW
SCOP	4.77	3.77
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.76 kW	9.04 kW
COP Tj = -7°C	3.15	2.28
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.50 kW	5.51 kW
COP Tj = +2°C	4.57	3.64
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.75 kW	3.57 kW

COP Tj = +7°C	6.20	5.11
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.27 kW	4.09 kW
COP Tj = 12°C	9.06	7.09
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.76 kW	9.04 kW
COP Tj = Tbiv	3.15	2.28
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.94 kW	9.99 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.74	2.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	64 °C	64 °C
Poff	13 W	13 W
PTO	38 W	38 W
PSB	13 W	13 W
PCK	83 W	83 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.23 kW
Annual energy consumption Qhe	4286 kWh	5608 kWh

Model MMHP15D3		
Model name	MMHP15D3	
Application	Heating (medium temp)	
Units	Outdoor	
Climate zone (for heating)	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	3x400V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 | Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 | Heating		
	Low temperature	Medium temperature
Heat output	12.09 kW	12.49 kW
El input	2.67 kW	4.26 kW
COP	4.53	2.93
EN 12102-1 | Average Climate		
	Low temperature	Medium temperature
Sound power level outdoor	67 dB(A)	68 dB(A)
EN 14825 | Average Climate		
	Low temperature	Medium temperature
ηs	187 %	145 %
Prated	9.88 kW	9.93 kW
SCOP	4.74	3.70
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.74 kW	8.79 kW
COP Tj = -7°C	3.18	2.35
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.54 kW	5.38 kW
COP Tj = +2°C	4.60	3.61
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.50 kW	3.45 kW

COP Tj = +7°C	6.10	4.83
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.10 kW	3.94 kW
COP Tj = 12°C	8.18	6.57
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.74 kW	8.79 kW
COP Tj = Tbiv	3.18	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.83 kW	9.92 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	2.03
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	13 W	13 W
PTO	38 W	38 W
PSB	13 W	13 W
PCK	83 W	83 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	0.01 kW
Annual energy consumption Qhe	4300 kWh	5547 kWh