Subtype VWL 75/8.2 AS 230V with Hydraulic station and 250l cylinder

Certificate Holder	Vaillant GmbH
Address	Berghauser Str. 40
ZIP	42859
City	Remscheid
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	VWL 75/8.2 AS 230V with Hydraulic station and 250l cylinder
Registration number	011-1W0970
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	11.02.2025
Testing basis	HP KEYMARK certification scheme rules rev. 14

Model VWL 75/8.2 AS 230V + VWL 77/8.2 IS + VIH RW 250/2 B	
Model name	VWL 75/8.2 AS 230V + VWL 77/8.2 IS + VIH RW 250/2 B
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a
General data	
Power supply	1x230V 50Hz
Off-peak product	n/a
Outdoor Air/Water	
EN 16147 | Average Climate	
Declared load profile	XL
Efficiency ηDHW	137 %
COP	3.32
Heating up time	01:20 h:min
Standby power input	34.4 W
Reference hot water temperature	53.7 °C
Mixed water at 40°C	341 l
EN 16147 | Colder Climate	
Declared load profile	L
Efficiency ηDHW	128 %
COP	3.19
Heating up time	01:11 h:min
Standby power input	53.4 W
Reference hot water temperature	53 °C
Mixed water at 40°C	248 l
EN 16147 | Warmer Climate	
Declared load profile	XL
Efficiency ηDHW	167 %
COP	4.18
Heating up time	01:27 h:min
Standby power input	31.5 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	362 l
EN 14511-4 | Heating	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Defrost test	passed	
Starting and operating test	passed	

EN 14511-2 | Heating		
	Low temperature	Medium temperature
Heat output	5.07 kW	6.45 kW
El input	1.01 kW	2.16 kW
COP	5.00	2.98

EN 14511-2 | Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	1.40 kW	1.87 kW
Cooling capacity	4.26	7.29
EER	3.04	3.90

EN 12102-1 | Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Average Climate		
	Low temperature	Medium temperature
ηs	203 %	142 %
Prated	6.61 kW	5.67 kW
SCOP	5.15	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.85 kW	5.01 kW
COP Tj = -7°C	3.20	2.27
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.34 kW	2.91 kW
COP Tj = +2°C	5.22	3.52
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.14 kW	2.97 kW
COP Tj = +7°C	6.31	4.68
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.71 kW	3.57 kW
COP Tj = 12°C	8.36	6.42
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.85 kW	5.01 kW
COP Tj = Tbiv	3.20	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.78 kW	4.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.90

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.83 kW	0.94 kW
Annual energy consumption Qhe	2649 kWh	3230 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	175 %	122 %
Prated	6.88 kW	5.69 kW
SCOP	4.44	3.12
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	4.51 kW	3.69 kW
COP Tj = -7°C	3.76	2.66
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.82 kW	2.58 kW
COP Tj = +2°C	5.57	3.97
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	3.24 kW	3.06 kW
COP Tj = +7°C	6.78	5.32
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.69 kW	3.60 kW
COP Tj = 12°C	8.06	6.73
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.61 kW	4.64 kW
COP Tj = Tbiv	2.61	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.12 kW	4.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W

PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.88 kW	5.69 kW
Annual energy consumption Qhe	3816 kWh	4499 kWh
Pdh Tj = -15°C (if TOL	5.61	4.64
COP Tj = -15°C (if TOL	2.61	2.02
Cdh Tj = -15 °C	1.00	1.00

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	257 %	176 %
Prated	6.80 kW	6.79 kW
SCOP	6.51	4.47
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.80 kW	6.79 kW
COP Tj = +2°C	3.42	2.37
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.68 kW	4.82 kW
COP Tj = +7°C	5.94	3.84
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	3.66 kW	3.49 kW
COP Tj = 12°C	7.87	5.72
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	6.80 kW	6.79 kW
COP Tj = Tbiv	3.42	2.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	6.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.42	2.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1397 kWh	2028 kWh
EN 14825 | Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	6.09 kW	6.63 kW
SEER	5.05	7.02
Pdc Tj = 35°C	6.09 kW	6.63 kW
EER Tj = 35°C	2.96	4.05
Cdc Tj = 35 °C	1.000	1.000
Pdc Tj = 30°C	4.52 kW	4.93 kW
EER Tj = 30°C	4.17	6.00
Cdc Tj = 30 °C	1.000	1.000
Pdc Tj = 25°C	2.98 kW	3.95 kW
EER Tj = 25°C	5.72	8.20
Cdc Tj = 25 °C	0.991	0.990
Pdc Tj = 20°C	3.27 kW	4.03 kW
EER Tj = 20°C	7.26	9.64
Cdc Tj = 20 °C	0.990	0.989
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Annual energy consumption Qce	723 kWh	567 kWh

Model VWL 75/8.2 AS 230V + VWL 77/8.2 IS S1 + VIH RW 250/2 B

Model name	VWL 75/8.2 AS 230V + VWL 77/8.2 IS S1 + VIH RW 250/2 B
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency ηDHW	137 %
COP	3.32
Heating up time	01:20 h:min
Standby power input	34.4 W
Reference hot water temperature	53.7 °C
Mixed water at 40°C	341 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency ηDHW	128 %
COP	3.19
Heating up time	01:11 h:min
Standby power input	53.4 W
Reference hot water temperature	53 °C
Mixed water at 40°C	248 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency ηDHW	167 %
COP	4.18
Heating up time	01:27 h:min
Standby power input	31.5 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	362 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating		
	Low temperature	Medium temperature
Heat output	5.07 kW	6.45 kW
El input	1.01 kW	2.16 kW
COP	5.00	2.98

EN 14511-2 | Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	1.40 kW	1.87 kW
Cooling capacity	4.26	7.29
EER	3.04	3.90

EN 12102-1 | Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Average Climate		
	Low temperature	Medium temperature
ηs	203 %	142 %
Prated	6.61 kW	5.67 kW
SCOP	5.15	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.85 kW	5.01 kW
COP Tj = -7°C	3.20	2.27
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.34 kW	2.91 kW
COP Tj = +2°C	5.22	3.52
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.14 kW	2.97 kW
COP Tj = +7°C	6.31	4.68
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.71 kW	3.57 kW
COP Tj = 12°C	8.36	6.42
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.85 kW	5.01 kW
COP Tj = Tbiv	3.20	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.78 kW	4.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.90

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.83 kW	0.94 kW
Annual energy consumption Qhe	2649 kWh	3230 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	175 %	122 %
Prated	6.88 kW	5.69 kW
SCOP	4.44	3.12
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	4.51 kW	3.69 kW
COP Tj = -7°C	3.76	2.66
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.82 kW	2.58 kW
COP Tj = +2°C	5.57	3.97
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	3.24 kW	3.06 kW
COP Tj = +7°C	6.78	5.32
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.69 kW	3.60 kW
COP Tj = 12°C	8.06	6.73
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.61 kW	4.64 kW
COP Tj = Tbiv	2.61	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.12 kW	4.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W

PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.88 kW	5.69 kW
Annual energy consumption Qhe	3816 kWh	4499 kWh
Pdh Tj = -15°C (if TOL	5.61	4.64
COP Tj = -15°C (if TOL	2.61	2.02
Cdh Tj = -15 °C	1.00	1.00

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	257 %	176 %
Prated	6.80 kW	6.79 kW
SCOP	6.51	4.47
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.80 kW	6.79 kW
COP Tj = +2°C	3.42	2.37
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.68 kW	4.82 kW
COP Tj = +7°C	5.94	3.84
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	3.66 kW	3.49 kW
COP Tj = 12°C	7.87	5.72
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	6.80 kW	6.79 kW
COP Tj = Tbiv	3.42	2.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	6.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.42	2.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1397 kWh	2028 kWh
EN 14825 | Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	6.09 kW	6.63 kW
SEER	5.05	7.02
Pdc Tj = 35°C	6.09 kW	6.63 kW
EER Tj = 35°C	2.96	4.05
Cdc Tj = 35 °C	1.000	1.000
Pdc Tj = 30°C	4.52 kW	4.93 kW
EER Tj = 30°C	4.17	6.00
Cdc Tj = 30 °C	1.000	1.000
Pdc Tj = 25°C	2.98 kW	3.95 kW
EER Tj = 25°C	5.72	8.20
Cdc Tj = 25 °C	0.991	0.990
Pdc Tj = 20°C	3.27 kW	4.03 kW
EER Tj = 20°C	7.26	9.64
Cdc Tj = 20 °C	0.990	0.989
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Annual energy consumption Qce	723 kWh	567 kWh

Model VWL 75/8.2 AS 230V S2 + VWL 77/8.2 IS + VIH RW 250/2 B	
Model name	VWL 75/8.2 AS 230V S2 + VWL 77/8.2 IS + VIH RW 250/2 B
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data	
Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water EN 16147 | Average Climate	
Declared load profile	XL
Efficiency ηDHW	137 %
COP	3.32
Heating up time	01:20 h:min
Standby power input	34.4 W
Reference hot water temperature	53.7 °C
Mixed water at 40°C	341 l

EN 16147 | Colder Climate	
Declared load profile	L
Efficiency ηDHW	128 %
COP	3.19
Heating up time	01:11 h:min
Standby power input	53.4 W
Reference hot water temperature	53 °C
Mixed water at 40°C	248 l

EN 16147 | Warmer Climate	
Declared load profile	XL
Efficiency ηDHW	167 %
COP	4.18
Heating up time	01:27 h:min
Standby power input	31.5 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	362 l

EN 14511-4 | Heating	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.07 kW	6.45 kW
El input	1.01 kW	2.16 kW
COP	5.00	2.98

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
ηs	199 %	140 %
Prated	6.61 kW	5.67 kW
SCOP	5.06	3.57
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.85 kW	5.01 kW
COP Tj = -7°C	3.20	2.27
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.34 kW	2.91 kW
COP Tj = +2°C	5.22	3.52
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.14 kW	2.97 kW
COP Tj = +7°C	6.31	4.68
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.71 kW	3.57 kW
COP Tj = 12°C	8.36	6.42
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.85 kW	5.01 kW
COP Tj = Tbiv	3.20	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.78 kW	4.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.83 kW	0.94 kW
Annual energy consumption Qhe	2698 kWh	3279 kWh

EN 12102-1 | Colder Climate		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Colder Climate		
	Low temperature	Medium temperature
ηs	173 %	121 %
Prated	6.88 kW	5.69 kW
SCOP	4.41	3.10
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	4.51 kW	3.69 kW
COP Tj = -7°C	3.76	2.66
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.82 kW	2.58 kW
COP Tj = +2°C	5.57	3.97
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	3.24 kW	3.06 kW
COP Tj = +7°C	6.78	5.32
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.69 kW	3.60 kW
COP Tj = 12°C	8.06	6.73
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.61 kW	4.64 kW
COP Tj = Tbiv	2.61	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.12 kW	4.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.88 kW	5.69 kW
Annual energy consumption Qhe	3845 kWh	4529 kWh
Pdh Tj = -15°C (if TOL	5.61	4.64

COP Tj = -15°C (if TOL	2.61	2.02
Cdh Tj = -15 °C	1.00	1.00

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	247 %	171 %
Prated	6.80 kW	6.79 kW
SCOP	6.24	4.35
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.80 kW	6.79 kW
COP Tj = +2°C	3.42	2.37
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.68 kW	4.82 kW
COP Tj = +7°C	5.94	3.84
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	3.66 kW	3.49 kW
COP Tj = 12°C	7.87	5.72
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	6.80 kW	6.79 kW
COP Tj = Tbiv	3.42	2.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	6.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.42	2.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1456 kWh	2086 kWh

Model VWL 75/8.2 AS 230V S2 + VWL 77/8.2 IS S1 + VIH RW 250/2 B	
Model name	VWL 75/8.2 AS 230V S2 + VWL 77/8.2 IS S1 + VIH RW 250/2 B
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data	
Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water EN 16147 | Average Climate	
Declared load profile	XL
Efficiency ηDHW	137 %
COP	3.32
Heating up time	01:20 h:min
Standby power input	34.4 W
Reference hot water temperature	53.7 °C
Mixed water at 40°C	341 l

EN 16147 | Colder Climate	
Declared load profile	L
Efficiency ηDHW	128 %
COP	3.19
Heating up time	01:11 h:min
Standby power input	53.4 W
Reference hot water temperature	53 °C
Mixed water at 40°C	248 l

EN 16147 | Warmer Climate	
Declared load profile	XL
Efficiency ηDHW	167 %
COP	4.18
Heating up time	01:27 h:min
Standby power input	31.5 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	362 l

EN 14511-4 | Heating	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.07 kW	6.45 kW
El input	1.01 kW	2.16 kW
COP	5.00	2.98

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
ηs	199 %	140 %
Prated	6.61 kW	5.67 kW
SCOP	5.06	3.57
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.85 kW	5.01 kW
COP Tj = -7°C	3.20	2.27
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.34 kW	2.91 kW
COP Tj = +2°C	5.22	3.52
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.14 kW	2.97 kW
COP Tj = +7°C	6.31	4.68
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.71 kW	3.57 kW
COP Tj = 12°C	8.36	6.42
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.85 kW	5.01 kW
COP Tj = Tbiv	3.20	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.78 kW	4.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.83 kW	0.94 kW
Annual energy consumption Qhe	2698 kWh	3279 kWh

EN 12102-1 | Colder Climate		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Colder Climate		
	Low temperature	Medium temperature
ηs	173 %	121 %
Prated	6.88 kW	5.69 kW
SCOP	4.41	3.10
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	4.51 kW	3.69 kW
COP Tj = -7°C	3.76	2.66
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.82 kW	2.58 kW
COP Tj = +2°C	5.57	3.97
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	3.24 kW	3.06 kW
COP Tj = +7°C	6.78	5.32
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.69 kW	3.60 kW
COP Tj = 12°C	8.06	6.73
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.61 kW	4.64 kW
COP Tj = Tbiv	2.61	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.12 kW	4.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.88 kW	5.69 kW
Annual energy consumption Qhe	3845 kWh	4529 kWh
Pdh Tj = -15°C (if TOL	5.61	4.64

COP Tj = -15°C (if TOL	2.61	2.02
Cdh Tj = -15 °C	1.00	1.00

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	247 %	171 %
Prated	6.80 kW	6.79 kW
SCOP	6.24	4.35
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.80 kW	6.79 kW
COP Tj = +2°C	3.42	2.37
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.68 kW	4.82 kW
COP Tj = +7°C	5.94	3.84
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	3.66 kW	3.49 kW
COP Tj = 12°C	7.87	5.72
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	6.80 kW	6.79 kW
COP Tj = Tbiv	3.42	2.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	6.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.42	2.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1456 kWh	2086 kWh

Model VWL 85/8.2 AS 230V S3 + VWL 87/8.2 IS + VIH RW 250/2 B

Model name	VWL 85/8.2 AS 230V S3 + VWL 87/8.2 IS + VIH RW 250/2 B
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency ηDHW	137 %
COP	3.32
Heating up time	01:20 h:min
Standby power input	34.4 W
Reference hot water temperature	53.7 °C
Mixed water at 40°C	341 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency ηDHW	128 %
COP	3.19
Heating up time	01:11 h:min
Standby power input	53.4 W
Reference hot water temperature	53 °C
Mixed water at 40°C	248 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency ηDHW	167 %
COP	4.18
Heating up time	01:27 h:min
Standby power input	31.5 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	362 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating		
	Low temperature	Medium temperature
Heat output	5.07 kW	6.45 kW
El input	1.01 kW	2.16 kW
COP	5.00	2.98

EN 14511-2 | Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	1.40 kW	1.87 kW
Cooling capacity	4.26	7.29
EER	3.04	3.90

EN 12102-1 | Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Average Climate		
	Low temperature	Medium temperature
ηs	203 %	142 %
Prated	6.61 kW	5.67 kW
SCOP	5.15	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.85 kW	5.01 kW
COP Tj = -7°C	3.20	2.27
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.34 kW	2.91 kW
COP Tj = +2°C	5.22	3.52
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.14 kW	2.97 kW
COP Tj = +7°C	6.31	4.68
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.71 kW	3.57 kW
COP Tj = 12°C	8.36	6.42
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.85 kW	5.01 kW
COP Tj = Tbiv	3.20	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.78 kW	4.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.90

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.83 kW	0.94 kW
Annual energy consumption Qhe	2649 kWh	3230 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	175 %	122 %
Prated	6.88 kW	5.69 kW
SCOP	4.44	3.12
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	4.51 kW	3.69 kW
COP Tj = -7°C	3.76	2.66
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.82 kW	2.58 kW
COP Tj = +2°C	5.57	3.97
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	3.24 kW	3.06 kW
COP Tj = +7°C	6.78	5.32
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.69 kW	3.60 kW
COP Tj = 12°C	8.06	6.73
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.61 kW	4.64 kW
COP Tj = Tbiv	2.61	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.12 kW	4.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W

PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.88 kW	5.69 kW
Annual energy consumption Qhe	3816 kWh	4499 kWh
Pdh Tj = -15°C (if TOL	5.61	4.64
COP Tj = -15°C (if TOL	2.61	2.02
Cdh Tj = -15 °C	1.00	1.00

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	257 %	176 %
Prated	6.80 kW	6.79 kW
SCOP	6.51	4.47
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.80 kW	6.79 kW
COP Tj = +2°C	3.42	2.37
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.68 kW	4.82 kW
COP Tj = +7°C	5.94	3.84
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	3.66 kW	3.49 kW
COP Tj = 12°C	7.87	5.72
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	6.80 kW	6.79 kW
COP Tj = Tbiv	3.42	2.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	6.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.42	2.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1397 kWh	2028 kWh
EN 14825 | Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	6.09 kW	6.63 kW
SEER	5.05	7.02
Pdc Tj = 35°C	6.09 kW	6.63 kW
EER Tj = 35°C	2.96	4.05
Cdc Tj = 35 °C	1.000	1.000
Pdc Tj = 30°C	4.52 kW	4.93 kW
EER Tj = 30°C	4.17	6.00
Cdc Tj = 30 °C	1.000	1.000
Pdc Tj = 25°C	2.98 kW	3.95 kW
EER Tj = 25°C	5.72	8.20
Cdc Tj = 25 °C	0.991	0.990
Pdc Tj = 20°C	3.27 kW	4.03 kW
EER Tj = 20°C	7.26	9.64
Cdc Tj = 20 °C	0.990	0.989
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Annual energy consumption Qce	723 kWh	567 kWh

Model VWL 85/8.2 AS 230V S3 + VWL 87/8.2 IS S1 + VIH RW 250/2 B	
Model name	VWL 85/8.2 AS 230V S3 + VWL 87/8.2 IS S1 + VIH RW 250/2 B
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data	
Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water EN 16147 | Average Climate	
Declared load profile	XL
Efficiency ηDHW	137 %
COP	3.32
Heating up time	01:20 h:min
Standby power input	34.4 W
Reference hot water temperature	53.7 °C
Mixed water at 40°C	341 l

EN 16147 | Colder Climate	
Declared load profile	L
Efficiency ηDHW	128 %
COP	3.19
Heating up time	01:11 h:min
Standby power input	53.4 W
Reference hot water temperature	53 °C
Mixed water at 40°C	248 l

EN 16147 | Warmer Climate	
Declared load profile	XL
Efficiency ηDHW	167 %
COP	4.18
Heating up time	01:27 h:min
Standby power input	31.5 W
Reference hot water temperature	52.0 °C
Mixed water at 40°C	362 l

EN 14511-4 | Heating	
Shutting off the heat transfer medium flow	passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating		
	Low temperature	Medium temperature
Heat output	5.07 kW	6.45 kW
El input	1.01 kW	2.16 kW
COP	5.00	2.98

EN 14511-2 | Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	1.40 kW	1.87 kW
Cooling capacity	4.26	7.29
EER	3.04	3.90

EN 12102-1 | Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Average Climate		
	Low temperature	Medium temperature
ηs	203 %	142 %
Prated	6.61 kW	5.67 kW
SCOP	5.15	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.85 kW	5.01 kW
COP Tj = -7°C	3.20	2.27
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	3.34 kW	2.91 kW
COP Tj = +2°C	5.22	3.52
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	3.14 kW	2.97 kW
COP Tj = +7°C	6.31	4.68
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.71 kW	3.57 kW
COP Tj = 12°C	8.36	6.42
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.85 kW	5.01 kW
COP Tj = Tbiv	3.20	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.78 kW	4.72 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.90

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.83 kW	0.94 kW
Annual energy consumption Qhe	2649 kWh	3230 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	175 %	122 %
Prated	6.88 kW	5.69 kW
SCOP	4.44	3.12
Tbiv	-15 °C	-15 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	4.51 kW	3.69 kW
COP Tj = -7°C	3.76	2.66
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	2.82 kW	2.58 kW
COP Tj = +2°C	5.57	3.97
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	3.24 kW	3.06 kW
COP Tj = +7°C	6.78	5.32
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	3.69 kW	3.60 kW
COP Tj = 12°C	8.06	6.73
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	5.61 kW	4.64 kW
COP Tj = Tbiv	2.61	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.12 kW	4.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	2.02
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W

PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.88 kW	5.69 kW
Annual energy consumption Qhe	3816 kWh	4499 kWh
Pdh Tj = -15°C (if TOL	5.61	4.64
COP Tj = -15°C (if TOL	2.61	2.02
Cdh Tj = -15 °C	1.00	1.00

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	48 dB(A)	48 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	257 %	176 %
Prated	6.80 kW	6.79 kW
SCOP	6.51	4.47
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.80 kW	6.79 kW
COP Tj = +2°C	3.42	2.37
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.68 kW	4.82 kW
COP Tj = +7°C	5.94	3.84
Cdh Tj = +7 °C	0.99	1.00
Pdh Tj = 12°C	3.66 kW	3.49 kW
COP Tj = 12°C	7.87	5.72
Cdh Tj = +12 °C	0.99	0.99
Pdh Tj = Tbiv	6.80 kW	6.79 kW
COP Tj = Tbiv	3.42	2.37
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.80 kW	6.79 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.42	2.37
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.00	1.00
WTOL	60 °C	60 °C
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	1397 kWh	2028 kWh
EN 14825 | Cooling		
	+7°C/+12°C	+18°C/+23°C
Pdesignc	6.09 kW	6.63 kW
SEER	5.05	7.02
Pdc Tj = 35°C	6.09 kW	6.63 kW
EER Tj = 35°C	2.96	4.05
Cdc Tj = 35 °C	1.000	1.000
Pdc Tj = 30°C	4.52 kW	4.93 kW
EER Tj = 30°C	4.17	6.00
Cdc Tj = 30 °C	1.000	1.000
Pdc Tj = 25°C	2.98 kW	3.95 kW
EER Tj = 25°C	5.72	8.20
Cdc Tj = 25 °C	0.991	0.990
Pdc Tj = 20°C	3.27 kW	4.03 kW
EER Tj = 20°C	7.26	9.64
Cdc Tj = 20 °C	0.990	0.989
Poff	13 W	13 W
PTO	5 W	5 W
PSB	13 W	13 W
PCK	0 W	0 W
Annual energy consumption Qce	723 kWh	567 kWh