

## Subtype AQUA PLUS SWAN-2 190S

Certificate Holder	Clivet s.p.a.
Address	Via camp lonc 25 c.ap.
ZIP	I-32032
City	z.i. Villapaiera - Feltre (BL)
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	AQUA PLUS SWAN-2 190S
Registration number	ICIM-PDC-000030
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R134a
Mass of Refrigerant	1.1 kg
Certification Date	02.05.2019
Testing basis	HP KEYMARK certification scheme rules rev. no. 4

## Model SWAN-2 190S

Model name	SWAN-2 190S
Application	Heating + DHW
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	No

## Heat Pump for Domestic Hot Water (DHW)

### EN 16147 | Operating test

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

### EN 12102-2 | Average Climate

Sound power level indoor	51 dB(A)
--------------------------	----------

### EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	115 %
COP	2.76
Heating up time	7:01 h:min
Standby power input	26.3 W
Reference hot water temperature	53.8 °C
Mixed water at 40°C	234 l