

Subtype THERMOR PERFECO S 16

| | |
|---------------------|---|
| Certificate Holder | Groupe Atlantic |
| Address | Rue des Fondeurs BP 64 |
| ZIP | 59660 |
| City | Merville |
| Country | FR |
| Certification Body | RISE CERT |
| Subtype title | THERMOR PERFECO S 16 |
| Registration number | 012-C700260 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R410A |
| Mass of Refrigerant | 2.5 kg |
| Certification Date | 08.03.2024 |
| Testing basis | EN 14511:2022, EN 14825:2022, EN 12102:2022 |
| Testing laboratory | ACTA INDUSTRIE - Laboratoire Acoustique et Climatique |

Model THERMOR PERFECO S 16

| | |
|-------------------------------------|-----------------------|
| Model name | THERMOR PERFECO S 16 |
| Application | Heating (medium temp) |
| Units | Indoor, Outdoor |
| Climate zone (for heating) | n/a |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow passed

| | |
|-------------------------------|--------|
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 13.80 kW | 10.40 kW |
| EI input | 3.12 kW | 3.70 kW |
| COP | 4.42 | 2.81 |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 40 dB(A) | 40 dB(A) |
| Sound power level outdoor | 67 dB(A) | 67 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 166 % | 130 % |
| Prated | 13.30 kW | 13.30 kW |
| SCOP | 4.21 | 3.32 |
| Tbiv | -7 °C | -5 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 11.50 kW | 9.50 kW |
| COP Tj = -7°C | 2.73 | 1.98 |
| Cdh Tj = -7 °C | 1.000 | 1.000 |
| Pdh Tj = +2°C | 6.90 kW | 7.20 kW |
| COP Tj = +2°C | 3.96 | 3.26 |
| Cdh Tj = +2 °C | 0.990 | 0.990 |
| Pdh Tj = +7°C | 6.30 kW | 6.40 kW |

| | | |
|---|-------------|-------------|
| COP Tj = +7°C | 5.86 | 4.78 |
| Cdh Tj = +7 °C | 0.990 | 0.990 |
| Pdh Tj = 12°C | 7.20 kW | 7.50 kW |
| COP Tj = 12°C | 7.40 | 6.02 |
| Cdh Tj = +12 °C | 0.980 | 0.990 |
| Pdh Tj = Tbiv | 11.50 kW | 10.50 kW |
| COP Tj = Tbiv | 2.73 | 2.21 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 11.30 kW | 8.40 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.63 | 1.76 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000 | 1.000 |
| WTOL | 60 °C | 60 °C |
| Poff | 10 W | 10 W |
| PTO | 15 W | 15 W |
| PSB | 10 W | 10 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 2.00 kW | 4.90 kW |
| Annual energy consumption Qhe | 6522 kWh | 8266 kWh |