

Subtype HPR29012

| | |
|---------------------|-------------------|
| Certificate Holder | Rinnai UK Ltd |
| Address | 9 Christleton Ct |
| ZIP | WA7 1ST |
| City | Runcorn |
| Country | GB |
| Certification Body | ICIM S.p.A. |
| Subtype title | HPR29012 |
| Registration number | ICIM-PDC-000303 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R290 |
| Mass of Refrigerant | 1 kg |
| Certification Date | 23.10.2024 |
| Testing basis | V12 |

Model HPR29012

| | |
|-------------------------------------|-----------------------|
| Model name | HPR29012 |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | +7°C/12°C |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water
EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

| | |
|-------------------------------|--------|
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 12.60 kW | 11.61 kW |
| El input | 2.61 kW | 3.60 kW |
| COP | 4.83 | 3.22 |

EN 14511-2 | Cooling

| | | |
|------------------|------------|-------------|
| | +7°C/+12°C | +18°C/+23°C |
| El input | 3.74 kW | |
| Cooling capacity | 10.67 | |
| EER | 2.85 | |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 59 dB(A) | 59 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|--------|-----------------|--------------------|
| ηs | 192 % | 140 % |
| Prated | 9.60 kW | 9.40 kW |
| SCOP | 4.88 | 3.59 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |

| | | |
|---|-------------|-------------|
| Pdh Tj = -7°C | 8.50 kW | 8.30 kW |
| COP Tj = -7°C | 2.93 | 2.17 |
| Cdh Tj = -7 °C | 1.000 | 1.000 |
| Pdh Tj = +2°C | 5.50 kW | 5.10 kW |
| COP Tj = +2°C | 4.61 | 3.42 |
| Cdh Tj = +2 °C | 1.000 | 1.000 |
| Pdh Tj = +7°C | 3.70 kW | 3.40 kW |
| COP Tj = +7°C | 7.01 | 5.10 |
| Cdh Tj = +7 °C | 0.958 | 0.967 |
| Pdh Tj = 12°C | 4.40 kW | 4.30 kW |
| COP Tj = 12°C | 9.33 | 5.93 |
| Cdh Tj = +12 °C | 0.953 | 0.970 |
| Pdh Tj = Tbiv | 8.50 kW | 8.30 kW |
| COP Tj = Tbiv | 2.93 | 2.17 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 8.10 kW | 7.80 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.59 | 1.90 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000 | 1.000 |
| WTOL | 68 °C | 68 °C |
| Poff | 22 W | 22 W |
| PTO | 22 W | 22 W |
| PSB | 22 W | 22 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.50 kW | 1.60 kW |
| Annual energy consumption Qhe | 4069 kWh | 5410 kWh |

EN 14825 | Cooling

| | +7°C/+12°C | +18°C/+23°C |
|----------------|------------|-------------|
| Pdesignc | 10.67 kW | |
| SEER | 4.72 | |
| Pdc Tj = 35°C | 10.67 kW | |
| EER Tj = 35°C | 2.85 | |
| Cdc Tj = 35 °C | 1.000 | |
| Pdc Tj = 30°C | 8.17 kW | |
| EER Tj = 30°C | 4.04 | |
| Cdc Tj = 30 °C | 1.000 | |
| Pdc Tj = 25°C | 5.10 kW | |
| EER Tj = 25°C | 5.26 | |
| Cdc Tj = 25 °C | 1.000 | |
| Pdc Tj = 20°C | 4.31 kW | |
| EER Tj = 20°C | 6.63 | |
| Cdc Tj = 20 °C | 0.966 | |
| Poff | 22 W | |

| | |
|-------------------------------|----------|
| PTO | 0 W |
| PSB | 28 W |
| PCK | 0 W |
| Annual energy consumption Qce | 1356 kWh |