

Subtype TTL 7.1 ACS comfort

Certificate Holder	tecalor GmbH
Address	Lüchtringer Weg 3
ZIP	37603
City	Holzminden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	TTL 7.1 ACS comfort
Registration number	011-1W0983
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.4 kg
Certification Date	04.02.2025
Testing basis	HP KEYMARK certification scheme rules rev. 14

Model TTL 7.1 ACS comfort

Model name	TTL 7.1 ACS comfort
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.05 kW	2.65 kW
El input	0.56 kW	0.83 kW
COP	5.50	3.19

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	43 dB(A)	43 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	200 %	158 %
Prated	8.15 kW	8.05 kW
SCOP	5.09	4.02
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.21 kW	7.12 kW
COP Tj = -7°C	3.29	2.68
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.40 kW	4.29 kW
COP Tj = +2°C	4.79	3.79
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.89 kW	2.78 kW

COP Tj = +7°C	7.16	5.42
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.29 kW	3.24 kW
COP Tj = 12°C	8.61	6.58
Cdh Tj = +12 °C	0.930	0.960
Pdh Tj = Tbiv	7.21 kW	7.12 kW
COP Tj = Tbiv	3.29	2.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.84 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.10	2.52
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	75 °C	75 °C
Poff	9 W	9 W
PTO	26 W	18 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.31 kW	1.05 kW
Annual energy consumption Qhe	3310 kWh	4133 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	43 dB(A)	43 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	182 %	144 %
Prated	7.78 kW	7.64 kW
SCOP	4.62	3.68
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.73 kW	4.61 kW
COP Tj = -7°C	3.99	3.15
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	2.90 kW	2.79 kW
COP Tj = +2°C	5.41	4.23
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.90 kW	2.80 kW
COP Tj = +7°C	7.23	5.62
Cdh Tj = +7 °C	0.910	0.960
Pdh Tj = 12°C	3.28 kW	3.26 kW
COP Tj = 12°C	8.38	6.76
Cdh Tj = +12 °C	0.930	0.960
Pdh Tj = Tbiv	6.35 kW	6.23 kW

COP Tj = Tbiv	3.03	2.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.16 kW	4.85 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	75 °C	75 °C
Poff	9 W	9 W
PTO	26 W	18 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.62 kW	2.79 kW
Annual energy consumption Qhe	4154 kWh	5120 kWh
Pdh Tj = -15°C (if TOL	6.35	6.23
COP Tj = -15°C (if TOL	3.03	2.50
Cdh Tj = -15 °C	0.900	0.900

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	43 dB(A)	43 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	253 %	180 %
Prated	4.30 kW	4.43 kW
SCOP	6.39	4.58
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.30 kW	4.43 kW
COP Tj = +2°C	4.26	2.84
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.82 kW	2.87 kW
COP Tj = +7°C	6.20	4.07
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.27 kW	3.17 kW
COP Tj = 12°C	7.99	5.82
Cdh Tj = +12 °C	0.940	0.970
Pdh Tj = Tbiv	4.30 kW	4.43 kW
COP Tj = Tbiv	4.26	2.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.30 kW	4.43 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.26	2.84

$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$

WTOL	75 °C	75 °C
P _{off}	9 W	9 W
PTO	26 W	18 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	899 kWh	1292 kWh