

Subtype Samsung EHS R32 Mono 12kW & 16kW (space heating/ 200L)

Certificate Holder	Samsung Electronics Air Conditioner Europe B.V.
Address	Evert van de Beekstraat 310
ZIP	1118 CX
City	Schiphol
Country	NL
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Samsung EHS R32 Mono 12kW & 16kW (space heating/ 200L)
Registration number	011-1W0446
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	2.2 kg
Certification Date	26.01.2021
Testing basis	HP KEYMARK certification scheme rules V7

Model AE120RXYDEG/EU & AE200RNWMEG/EU

Model name	AE120RXYDEG/EU & AE200RNWMEG/EU
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	110 %
COP	2.72
Heating up time	1:30 h:min
Standby power input	62.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	206 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.30 kW
El input	2.65 kW	3.73 kW
COP	4.53	3.03

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	185 %	138 %

Prated	13.00 kW	12.00 kW
SCOP	4.69	3.51
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.50 kW	10.60 kW
COP Tj = -7°C	2.71	2.16
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	7.00 kW	6.50 kW
COP Tj = +2°C	4.48	3.45
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.60 kW	4.20 kW
COP Tj = +7°C	6.86	4.57
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.40 kW
COP Tj = 12°C	8.95	6.12
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.50 kW	10.60 kW
COP Tj = Tbiv	2.71	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.00 kW	12.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.37	1.96
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5725 kWh	7051 kWh

Model AE120RXYDEG/EU & MIM-E03CN

Model name	AE120RXYDEG/EU & MIM-E03CN
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.30 kW
El input	2.65 kW	3.73 kW
COP	4.53	3.03

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	185 %	138 %
Prated	13.00 kW	12.00 kW
SCOP	4.69	3.51
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.50 kW	10.62 kW
COP Tj = -7°C	2.71	2.16
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	7.00 kW	6.46 kW
COP Tj = +2°C	4.48	3.45
Cdh Tj = +2 °C	0.900	0.900

Pdh Tj = +7°C	5.60 kW	4.15 kW
COP Tj = +7°C	6.86	4.57
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.40 kW
COP Tj = 12°C	8.95	6.12
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.50 kW	10.62 kW
COP Tj = Tbiv	2.71	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.00 kW	12.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.37	1.96
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5725 kWh	7051 kWh

Model AE160RXYDEG/EU & AE200RNWMEG/EU

Model name	AE160RXYDEG/EU & AE200RNWMEG/EU
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	110 %
COP	2.72
Heating up time	1:30 h:min
Standby power input	62.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	206 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.00 kW	15.00 kW
El input	3.62 kW	5.18 kW
COP	4.42	2.90

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	138 %

Prated	16.00 kW	16.00 kW
SCOP	4.48	3.53
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.15 kW	14.15 kW
COP Tj = -7°C	2.65	2.06
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	8.62 kW	8.62 kW
COP Tj = +2°C	4.11	3.31
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.54 kW	5.54 kW
COP Tj = +7°C	6.86	5.23
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.20 kW	4.49 kW
COP Tj = 12°C	8.81	6.35
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	14.15 kW	14.15 kW
COP Tj = Tbiv	2.65	2.06
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.80 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.37	1.82
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.20 kW	2.00 kW
Annual energy consumption Qhe	7385 kWh	9379 kWh

Model AE160RXYDEG/EU & MIM-E03CN

Model name	AE160RXYDEG/EU & MIM-E03CN
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.00 kW	15.00 kW
El input	3.62 kW	5.18 kW
COP	4.42	2.90

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	138 %
Prated	16.00 kW	16.00 kW
SCOP	4.48	3.53
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.15 kW	14.15 kW
COP Tj = -7°C	2.65	2.06
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	8.62 kW	8.62 kW
COP Tj = +2°C	4.11	3.31
Cdh Tj = +2 °C	0.900	0.900

Pdh Tj = +7°C	5.54 kW	5.54 kW
COP Tj = +7°C	6.86	5.23
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.20 kW	4.49 kW
COP Tj = 12°C	8.81	6.35
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	14.15 kW	14.15 kW
COP Tj = Tbiv	2.65	2.06
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.80 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.37	1.82
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.20 kW	2.00 kW
Annual energy consumption Qhe	7385 kWh	9379 kWh

Model AE120RXYDEG/EU + AE200CNWMEG/EU

Model name	AE120RXYDEG/EU + AE200CNWMEG/EU
Application	Heating + DHW + low temp
Units	n/a
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	110 %
COP	2.72
Heating up time	1:30 h:min
Standby power input	62.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	206 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	11.30 kW
El input	2.65 kW	3.73 kW
COP	4.53	3.03

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	185 %	138 %
Prated	13.00 kW	12.00 kW
SCOP	4.69	3.51
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.50 kW	10.60 kW
COP Tj = -7°C	2.71	2.16

Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	7.00 kW	6.50 kW
COP Tj = +2°C	4.48	3.45
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.60 kW	4.20 kW
COP Tj = +7°C	6.86	4.57
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.80 kW	4.40 kW
COP Tj = 12°C	8.95	6.12
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.50 kW	10.60 kW
COP Tj = Tbiv	2.71	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.00 kW	12.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.37	1.96
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5725 kWh	7051 kWh

Model AE160RXYDEG/EU + AE200CNWMEG/EU

Model name	AE160RXYDEG/EU + AE200CNWMEG/EU
Application	Heating + DHW + low temp
Units	n/a
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	110 %
COP	2.72
Heating up time	1:30 h:min
Standby power input	62.0 W
Reference hot water temperature	52.1 °C
Mixed water at 40°C	206 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	16.00 kW	15.00 kW
El input	3.62 kW	5.18 kW
COP	4.42	2.90

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	138 %
Prated	16.00 kW	16.00 kW
SCOP	4.48	3.53
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.15 kW	14.15 kW
COP Tj = -7°C	2.65	2.06

Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	8.62 kW	8.62 kW
COP Tj = +2°C	4.11	3.31
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.54 kW	5.54 kW
COP Tj = +7°C	6.86	5.23
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.20 kW	4.49 kW
COP Tj = 12°C	8.81	6.35
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	14.15 kW	14.15 kW
COP Tj = Tbiv	2.65	2.06
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.80 kW	14.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.37	1.82
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.20 kW	2.00 kW
Annual energy consumption Qhe	7385 kWh	9379 kWh