

Subtype Sylber VEGA M 12 14 16 kW

Certificate Holder	Riello S.p.A.
Address	Via Ing. Pilade Riello 7
ZIP	37045
City	Legnago (VR)
Country	IT
Certification Body	BRE Global Limited
Subtype title	Sylber VEGA M 12 14 16 kW
Registration number	041-K019-11
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.84 kg
Certification Date	05.11.2021
Testing basis	Heat Pump Keymark Scheme Rules Rev 08
Testing laboratory	TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN

Model VEGA M 012

Model name	VEGA M 012
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.10 kW	11.90 kW
El input	2.44 kW	3.90 kW
COP	4.95	3.05

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	135 %
Prated	12.00 kW	11.58 kW
SCOP	4.81	3.45
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.61 kW	10.25 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.69 kW	6.52 kW
COP Tj = +2°C	4.65	3.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.44 kW	4.36 kW

COP Tj = +7°C	6.62	4.59
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.74 kW	3.30 kW
COP Tj = 12°C	8.47	6.05
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.61 kW	10.25 kW
COP Tj = Tbiv	2.88	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.75 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.79
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.26 kW	2.50 kW
Annual energy consumption Qhe	5152 kWh	6927 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	160 %	118 %
Prated	11.38 kW	10.32 kW
SCOP	4.08	3.02
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.05 kW	6.63 kW
COP Tj = -7°C	3.48	2.63
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.68 kW	4.07 kW
COP Tj = +2°C	4.96	3.60
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.14 kW	2.78 kW
COP Tj = +7°C	6.10	4.54
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.57 kW	3.33 kW
COP Tj = 12°C	7.87	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.28 kW	8.42 kW
COP Tj = Tbiv	2.59	1.84

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.01 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.98	1.13
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.37 kW	6.12 kW
Annual energy consumption Qhe	6870 kWh	8419 kWh
Pdh Tj = -15°C (if TOL	9.28	8.42
COP Tj = -15°C (if TOL	2.59	1.84
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	256 %	174 %
Prated	11.11 kW	12.51 kW
SCOP	6.53	4.43
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.11 kW	12.08 kW
COP Tj = +2°C	3.59	2.31
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.14 kW	8.04 kW
COP Tj = +7°C	5.87	3.86
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.56 kW	3.75 kW
COP Tj = 12°C	7.94	5.70
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.14 kW	8.04 kW
COP Tj = Tbiv	5.87	3.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.11 kW	12.08 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.59	2.31
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	14 W	14 W

PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.44 kW
Annual energy consumption Q _{he}	2292 kWh	3776 kWh

Model VEGA M 014

Model name	VEGA M 014
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.50 kW	13.80 kW
El input	3.15 kW	4.68 kW
COP	4.60	2.95

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	13.73 kW	12.08 kW
SCOP	4.72	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.14 kW	10.69 kW
COP Tj = -7°C	2.79	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.95 kW	6.86 kW
COP Tj = +2°C	4.52	3.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.20 kW	4.64 kW

COP Tj = +7°C	6.68	4.66
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.76 kW	3.32 kW
COP Tj = 12°C	8.52	6.13
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.14 kW	10.69 kW
COP Tj = Tbiv	2.79	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.48 kW	9.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.76
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.23 kW	2.91 kW
Annual energy consumption Qhe	6012 kWh	7202 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	160 %	119 %
Prated	12.64 kW	10.97 kW
SCOP	4.07	3.05
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.97 kW	6.89 kW
COP Tj = -7°C	3.44	2.66
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.05 kW	4.32 kW
COP Tj = +2°C	4.92	3.66
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.16 kW	3.06 kW
COP Tj = +7°C	6.11	4.72
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.58 kW	3.33 kW
COP Tj = 12°C	7.82	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.31 kW	8.95 kW
COP Tj = Tbiv	2.53	1.79

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.13
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.07 kW	6.77 kW
Annual energy consumption Qhe	7667 kWh	8866 kWh
Pdh Tj = -15°C (if TOL	10.31	8.95
COP Tj = -15°C (if TOL	2.53	1.79
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	260 %	175 %
Prated	12.11 kW	14.17 kW
SCOP	6.63	4.45
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.04 kW	13.05 kW
COP Tj = +2°C	3.44	2.20
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.78 kW	9.11 kW
COP Tj = +7°C	5.84	3.89
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.75 kW	4.09 kW
COP Tj = 12°C	8.25	5.90
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.78 kW	9.11 kW
COP Tj = Tbiv	5.84	3.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.04 kW	13.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.44	2.20
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	14 W	14 W

PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.07 kW	1.13 kW
Annual energy consumption Q _{he}	2457 kWh	4258 kWh

Model VEGA M 016

Model name	VEGA M 016
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	15.90 kW	16.00 kW
El input	3.53 kW	5.61 kW
COP	4.50	2.85

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	133 %
Prated	15.21 kW	13.02 kW
SCOP	4.62	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.45 kW	11.52 kW
COP Tj = -7°C	2.72	1.99
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.57 kW	7.18 kW
COP Tj = +2°C	4.41	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.70 kW	4.68 kW

COP Tj = +7°C	6.56	4.61
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.78 kW	3.32 kW
COP Tj = 12°C	8.51	6.07
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	13.45 kW	11.52 kW
COP Tj = Tbiv	2.72	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.52 kW	10.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.80
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.68 kW	2.67 kW
Annual energy consumption Qhe	6804 kWh	7895 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	158 %	122 %
Prated	13.76 kW	11.79 kW
SCOP	4.02	3.12
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.31 kW	7.64 kW
COP Tj = -7°C	3.37	2.65
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.27 kW	4.43 kW
COP Tj = +2°C	4.86	3.79
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.62 kW	2.98 kW
COP Tj = +7°C	6.49	4.81
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.43 kW
COP Tj = 12°C	7.40	6.29
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.22 kW	9.62 kW
COP Tj = Tbiv	2.43	1.86

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.89 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.23
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.87 kW	6.57 kW
Annual energy consumption Qhe	8431 kWh	9309 kWh
Pdh Tj = -15°C (if TOL	11.22	9.62
COP Tj = -15°C (if TOL	2.43	1.86
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	249 %	176 %
Prated	13.09 kW	14.17 kW
SCOP	6.33	4.48
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	13.09 kW	13.38 kW
COP Tj = +2°C	3.35	2.29
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.42 kW	9.11 kW
COP Tj = +7°C	5.36	3.89
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.88 kW	4.06 kW
COP Tj = 12°C	8.11	5.86
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.42 kW	9.11 kW
COP Tj = Tbiv	5.36	3.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.09 kW	13.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.35	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	14 W	14 W

PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.79 kW
Annual energy consumption Q _{he}	2781 kWh	4231 kWh

Model VEGA M 012T

Model name	VEGA M 012T
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.10 kW	11.90 kW
El input	2.44 kW	3.90 kW
COP	4.95	3.05

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	189 %	135 %
Prated	12.00 kW	11.58 kW
SCOP	4.81	3.45
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.61 kW	10.25 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.69 kW	6.52 kW
COP Tj = +2°C	4.65	3.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.44 kW	4.36 kW

COP Tj = +7°C	6.62	4.59
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.74 kW	3.30 kW
COP Tj = 12°C	8.47	6.05
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.61 kW	10.25 kW
COP Tj = Tbiv	2.88	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.75 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.79
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.26 kW	2.50 kW
Annual energy consumption Qhe	5153 kWh	6928 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	160 %	118 %
Prated	11.38 kW	10.32 kW
SCOP	4.08	3.02
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.05 kW	6.63 kW
COP Tj = -7°C	3.48	2.63
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.68 kW	4.07 kW
COP Tj = +2°C	4.96	3.60
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.14 kW	2.78 kW
COP Tj = +7°C	6.10	4.54
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.57 kW	3.33 kW
COP Tj = 12°C	7.87	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.28 kW	8.42 kW
COP Tj = Tbiv	2.59	1.84

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.01 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.98	1.13
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.37 kW	6.12 kW
Annual energy consumption Qhe	6871 kWh	8420 kWh
Pdh Tj = -15°C (if TOL	9.28	8.42
COP Tj = -15°C (if TOL	2.59	1.84
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	256 %	174 %
Prated	11.11 kW	12.51 kW
SCOP	6.53	4.42
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.11 kW	12.08 kW
COP Tj = +2°C	3.59	2.31
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.14 kW	8.04 kW
COP Tj = +7°C	5.87	3.86
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.56 kW	3.75 kW
COP Tj = 12°C	7.94	5.70
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.14 kW	8.04 kW
COP Tj = Tbiv	5.87	3.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.11 kW	12.08 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.59	2.31
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	20 W	20 W

PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.44 kW
Annual energy consumption Q _{he}	2296 kWh	3780 kWh

Model VEGA M 014T

Model name	VEGA M 014T
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.50 kW	13.80 kW
El input	3.15 kW	4.68 kW
COP	4.60	2.95

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	13.73 kW	12.08 kW
SCOP	4.72	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.14 kW	10.69 kW
COP Tj = -7°C	2.79	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.95 kW	6.86 kW
COP Tj = +2°C	4.52	3.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.20 kW	4.64 kW

COP Tj = +7°C	6.68	4.66
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.76 kW	3.32 kW
COP Tj = 12°C	8.52	6.13
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.14 kW	10.69 kW
COP Tj = Tbiv	2.79	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.48 kW	9.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.76
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.23 kW	2.91 kW
Annual energy consumption Qhe	6013 kWh	7203 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	160 %	119 %
Prated	12.64 kW	10.97 kW
SCOP	4.06	3.05
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.97 kW	6.89 kW
COP Tj = -7°C	3.44	2.66
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.05 kW	4.32 kW
COP Tj = +2°C	4.92	3.66
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.16 kW	3.06 kW
COP Tj = +7°C	6.11	4.72
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.58 kW	3.33 kW
COP Tj = 12°C	7.82	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.31 kW	8.95 kW
COP Tj = Tbiv	2.53	1.79

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.13
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.07 kW	6.77 kW
Annual energy consumption Qhe	7667 kWh	8867 kWh
Pdh Tj = -15°C (if TOL	10.31	8.95
COP Tj = -15°C (if TOL	2.53	1.79
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	260 %	175 %
Prated	12.11 kW	14.17 kW
SCOP	6.63	4.44
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.04 kW	13.05 kW
COP Tj = +2°C	3.44	2.20
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.78 kW	9.11 kW
COP Tj = +7°C	5.84	3.89
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.75 kW	4.09 kW
COP Tj = 12°C	8.25	5.90
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.78 kW	9.11 kW
COP Tj = Tbiv	5.84	3.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.04 kW	13.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.44	2.20
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	20 W	20 W

PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.07 kW	1.13 kW
Annual energy consumption Q _{he}	2462 kWh	4262 kWh

Model VEGA M 016T

Model name	VEGA M 016T
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	15.90 kW	16.00 kW
El input	3.53 kW	5.61 kW
COP	4.50	2.85

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	133 %
Prated	15.21 kW	13.02 kW
SCOP	4.62	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.45 kW	11.52 kW
COP Tj = -7°C	2.72	1.99
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.57 kW	7.18 kW
COP Tj = +2°C	4.41	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.70 kW	4.68 kW

COP Tj = +7°C	6.56	4.61
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.78 kW	3.32 kW
COP Tj = 12°C	8.51	6.07
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	13.45 kW	11.52 kW
COP Tj = Tbiv	2.72	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.52 kW	10.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.80
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.68 kW	2.67 kW
Annual energy consumption Qhe	6805 kWh	7896 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	158 %	122 %
Prated	13.76 kW	11.79 kW
SCOP	4.02	3.12
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.31 kW	7.64 kW
COP Tj = -7°C	3.37	2.65
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.27 kW	4.43 kW
COP Tj = +2°C	4.86	3.79
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.62 kW	2.98 kW
COP Tj = +7°C	6.49	4.81
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.43 kW
COP Tj = 12°C	7.40	6.29
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.22 kW	9.62 kW
COP Tj = Tbiv	2.43	1.86

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.89 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.23
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.87 kW	6.57 kW
Annual energy consumption Qhe	8431 kWh	9310 kWh
Pdh Tj = -15°C (if TOL	11.22	9.62
COP Tj = -15°C (if TOL	2.43	1.86
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	248 %	176 %
Prated	13.09 kW	14.17 kW
SCOP	6.33	4.47
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	13.09 kW	13.38 kW
COP Tj = +2°C	3.35	2.29
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.42 kW	9.11 kW
COP Tj = +7°C	5.36	3.89
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.88 kW	4.06 kW
COP Tj = 12°C	8.11	5.86
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.42 kW	9.11 kW
COP Tj = Tbiv	5.36	3.89
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.09 kW	13.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.35	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	20 W	20 W

PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.79 kW
Annual energy consumption Q _{he}	2786 kWh	4236 kWh