

Subtype Monobloc Heat pump 18KW R290

| | |
|---------------------|--|
| Certificate Holder | Foshan Goodheat Technology Ltd |
| Address | No.5-6, Wusha Xinyue Road |
| ZIP | 528300 |
| City | Shunde, Foshan, Guangdong |
| Country | CN |
| Certification Body | DIN CERTCO Gesellschaft für Konformitätsbewertung mbH |
| Subtype title | Monobloc Heat pump 18KW R290 |
| Registration number | 011-1W1091 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R290 |
| Mass of Refrigerant | 1.4 kg |
| Certification Date | 18.09.2025 |
| Testing basis | HP KEYMARK certification scheme rules rev. 14 |
| Testing laboratory | Intertek Testing Services Shenzhen LTD. Guangzhou Branch, CN |

Model GSHVTH-18AA1

| | |
|-------------------------------------|-----------------------|
| Model name | GSHVTH-18AA1 |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 3x400V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

| | |
|-------------------------------|--------|
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 18.00 kW | 15.60 kW |
| El input | 3.80 kW | 5.20 kW |
| COP | 4.74 | 3.00 |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 68 dB(A) | 68 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 193 % | 155 % |
| Prated | 16.00 kW | 17.10 kW |
| SCOP | 4.90 | 3.95 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 14.18 kW | 15.13 kW |
| COP Tj = -7°C | 3.18 | 2.51 |
| Cdh Tj = -7 °C | 1.000 | 1.000 |
| Pdh Tj = +2°C | 9.26 kW | 9.35 kW |
| COP Tj = +2°C | 4.77 | 3.84 |
| Cdh Tj = +2 °C | 0.990 | 0.990 |
| Pdh Tj = +7°C | 6.43 kW | 6.80 kW |

| | | |
|---|-------------|-------------|
| COP Tj = +7°C | 6.16 | 5.07 |
| Cdh Tj = +7 °C | 0.990 | 0.990 |
| Pdh Tj = 12°C | 7.47 kW | 7.33 kW |
| COP Tj = 12°C | 7.99 | 7.38 |
| Cdh Tj = +12 °C | 0.990 | 0.990 |
| Pdh Tj = Tbiv | 14.18 kW | 15.13 kW |
| COP Tj = Tbiv | 3.18 | 2.51 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 14.84 kW | 13.64 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.80 | 2.13 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000 | 1.000 |
| WTOL | 75 °C | 75 °C |
| Poff | 13 W | 13 W |
| PTO | 13 W | 13 W |
| PSB | 14 W | 14 W |
| PCK | 55 W | 55 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.19 kW | 3.46 kW |
| Annual energy consumption Qhe | 6780 kWh | 8921 kWh |