

## Subtype Combo RSJ-15/190RDN3-F

Certificate Holder	GD Midea Heating & Ventilating Equipment Co., Ltd.
Address	Penglai Industry Road
ZIP	528311
City	Beijiao, Shunde, Foshan
Country	CN
Certification Body	BRE Global Limited
Subtype title	Combo RSJ-15/190RDN3-F
Registration number	041-K007-01
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R134a
Mass of Refrigerant	1 kg
Certification Date	04.05.2020
Testing basis	Scheme Rules Rev 07

**Model RSJ-15/190RDN3-F**

Model name	RSJ-15/190RDN3-F
Application	n/a
Units	Indoor
Climate zone (for heating)	n/a
Heat Source	Outdoor Air
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

**General data**

Power supply	1x230V 50Hz
Off-peak product	No

**Heat Pump for Domestic Hot Water (DHW)****EN 16147 | Operating test**

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

**EN 12102-2 | Average Climate**

Sound power level indoor	58 dB(A)
--------------------------	----------

**EN 16147 | Average Climate**

Declared load profile	L
Efficiency $\eta_{DHW}$	104 %
COP	2.55
Heating up time	7:05 h:min
Standby power input	20.8 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	234 l