

## Subtype Daikin Altherma 3 R MT F+W 12 kW (180L)

Certificate Holder	DAIKIN Europe N.V.
Address	Zandvoordestraat 300
ZIP	B-8400
City	Oostende
Country	BE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Daikin Altherma 3 R MT F+W 12 kW (180L)
Registration number	011-1W0655
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	3.25 kg
Certification Date	01.08.2023
Testing basis	HP KEYMARK certification scheme rules V12

## Model ERRA12EV3 / ELVH12S18E(6V/9W)

Model name	ERRA12EV3 / ELVH12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.62 kW
COP	4.92	2.94

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.96 kW	
Cooling capacity	8.62	
EER	2.91	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

Sound power level outdoor	56 dB(A)	56 dB(A)
---------------------------	----------	----------

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	186 %	135 %
Prated	8.3 kW	12.5 kW
SCOP	4.71	3.44
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.77	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	2
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3637 kWh	7510 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.31	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	2.91	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.17	
Cdc Tj = 30 °C	0.98	

Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.13
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.75
Cdc Tj = 20 °C	0.91
Poff	25 W
PTO	3 W
PSB	25 W
PCK	0 W

## Model ERRA12EW1 / ELVH12S18E(6V/9W)

Model name	ERRA12EW1 / ELVH12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.1	3.05

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.86 kW	
Cooling capacity	8.62	
EER	3.01	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

Sound power level outdoor                      56 dB(A)                      56 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	191 %	138 %
Prated	8.3 kW	12.5 kW
SCOP	4.84	3.53
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.86	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.06
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3539 kWh	7309 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.41	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	3.01	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.32	
Cdc Tj = 30 °C	0.98	

Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.34
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.72
Cdc Tj = 20 °C	0.91
Poff	31 W
PTO	0 W
PSB	31 W
PCK	0 W

## Model ERRA12EV3 / ELVX12S18E(6V/9W)

Model name	ERRA12EV3 / ELVX12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.62 kW
COP	4.92	2.94

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.96 kW	
Cooling capacity	8.62	
EER	2.91	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------



Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	190 %	136 %
Prated	8.3 kW	12.5 kW
SCOP	4.82	3.47
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.77	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	2
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3560 kWh	7433 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.31	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	2.91	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.17	

Cdc Tj = 30 °C	0.98
Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.13
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.75
Cdc Tj = 20 °C	0.91
Poff	25 W
PTO	3 W
PSB	25 W
PCK	0 W

## Model ERRA12EW1 / ELVX12S18E(6V/9W)

Model name	ERRA12EW1 / ELVX12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.1	3.05

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.86 kW	
Cooling capacity	8.62	
EER	3.01	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	196 %	140 %
Prated	8.3 kW	12.5 kW
SCOP	4.98	3.58
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.86	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.06
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3440 kWh	7210 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.41	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	3.01	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.32	

Cdc Tj = 30 °C	0.98
Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.34
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.72
Cdc Tj = 20 °C	0.91
Poff	31 W
PTO	0 W
PSB	31 W
PCK	0 W

## Model ERRA12EV3 / ELVZ12S18E(6V/9W)

Model name	ERRA12EV3 / ELVZ12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.62 kW
COP	4.92	2.94

### EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.96 kW	
Cooling capacity	8.62	
EER	2.91	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

Sound power level outdoor                      56 dB(A)                      56 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	186 %	135 %
Prated	8.3 kW	12.5 kW
SCOP	4.71	3.44
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.77	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	2
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3637 kWh	7510 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.31	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	2.91	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.17	
Cdc Tj = 30 °C	0.98	

Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.13
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.75
Cdc Tj = 20 °C	0.91
Poff	25 W
PTO	3 W
PSB	25 W
PCK	0 W



## Model ERRA12EW1 / ELVZ12S18E(6V/9W)

Model name	ERRA12EW1 / ELVZ12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.1	3.05

### EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.86 kW	
Cooling capacity	8.62	
EER	3.01	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)

Sound power level outdoor 56 dB(A) 56 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	191 %	138 %
Prated	8.3 kW	12.5 kW
SCOP	4.84	3.53
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.86	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.06
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3539 kWh	7309 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.41	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	3.01	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.32	
Cdc Tj = 30 °C	0.98	

Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.34
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.72
Cdc Tj = 20 °C	0.91
Poff	31 W
PTO	0 W
PSB	31 W
PCK	0 W

## Model ERRA12EV3 / ELBH12E(6V/9W)

Model name	ERRA12EV3 / ELBH12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.62 kW
COP	4.92	2.94

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.96 kW	
Cooling capacity	8.62	
EER	2.91	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	186 %	135 %
Prated	8.3 kW	12.5 kW
SCOP	4.71	3.44
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.77	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	2
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3637 kWh	7510 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.31	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	2.91	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.17	
Cdc Tj = 30 °C	0.98	
Pdc Tj = 25°C	4.04 kW	
EER Tj = 25°C	6.13	
Cdc Tj = 25 °C	0.96	
Pdc Tj = 20°C	2.69 kW	
EER Tj = 20°C	8.75	
Cdc Tj = 20 °C	0.91	
Poff	25 W	
PTO	3 W	
PSB	25 W	
PCK	0 W	

## Model ERRA12EW1 / ELBH12E(6V/9W)

Model name	ERRA12EW1 / ELBH12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.1	3.05

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.86 kW	
Cooling capacity	8.62	
EER	3.01	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	191 %	138 %
Prated	8.3 kW	12.5 kW
SCOP	4.84	3.53
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.86	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.06
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3539 kWh	7309 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.41	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	3.01	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.32	
Cdc Tj = 30 °C	0.98	
Pdc Tj = 25°C	4.04 kW	
EER Tj = 25°C	6.34	
Cdc Tj = 25 °C	0.96	
Pdc Tj = 20°C	2.69 kW	
EER Tj = 20°C	8.72	
Cdc Tj = 20 °C	0.91	
Poff	31 W	
PTO	0 W	
PSB	31 W	
PCK	0 W	

## Model ERRA12EV3 / ELBX12E(6V/9W)

Model name	ERRA12EV3 / ELBX12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.62 kW
COP	4.92	2.94

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.96 kW	
Cooling capacity	8.62	
EER	2.91	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	190 %	136 %
Prated	8.3 kW	12.5 kW
SCOP	4.82	3.47
Tbiv	-10 °C	-5 °C



TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.77	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	2
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3560 kWh	7433 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.31	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	2.91	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.17	
Cdc Tj = 30 °C	0.98	
Pdc Tj = 25°C	4.04 kW	
EER Tj = 25°C	6.13	
Cdc Tj = 25 °C	0.96	
Pdc Tj = 20°C	2.69 kW	
EER Tj = 20°C	8.75	
Cdc Tj = 20 °C	0.91	
Poff	25 W	
PTO	3 W	
PSB	25 W	

PCK

0 W

---

## Model ERRA12EW1 / ELBX12E(6V/9W)

Model name	ERRA12EW1 / ELBX12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.1	3.05

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.86 kW	
Cooling capacity	8.62	
EER	3.01	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	196 %	140 %
Prated	8.3 kW	12.5 kW
SCOP	4.98	3.58
Tbiv	-10 °C	-5 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.86	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.06
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3440 kWh	7210 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.41	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	3.01	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.32	
Cdc Tj = 30 °C	0.98	
Pdc Tj = 25°C	4.04 kW	
EER Tj = 25°C	6.34	
Cdc Tj = 25 °C	0.96	
Pdc Tj = 20°C	2.69 kW	
EER Tj = 20°C	8.72	
Cdc Tj = 20 °C	0.91	
Poff	31 W	
PTO	0 W	
PSB	31 W	

PCK

0 W

---

### Model ERRA12EV3 / ELVH12S18E(6V/9W) + cooling kit

Model name	ERRA12EV3 / ELVH12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

### General data

Power supply	1x230V 50Hz
Off-peak product	n/a

### Outdoor Air/Water

#### EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.62 kW
COP	4.92	2.94

### EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.96 kW	
Cooling capacity	8.62	
EER	2.91	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	190 %	136 %
Prated	8.3 kW	12.5 kW
SCOP	4.82	3.47
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.77	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	2
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3560 kWh	7433 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.31	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	2.91	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.17	

Cdc Tj = 30 °C	0.98
Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.13
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.75
Cdc Tj = 20 °C	0.91
Poff	25 W
PTO	3 W
PSB	25 W
PCK	0 W



## Model ERRA12EW1 / ELVH12S18E(6V/9W) + cooling kit

Model name	ERRA12EW1 / ELVH12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.1	3.05

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.86 kW	
Cooling capacity	8.62	
EER	3.01	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	196 %	140 %
Prated	8.3 kW	12.5 kW
SCOP	4.98	3.58
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.86	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.06
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3440 kWh	7210 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.41	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	3.01	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.32	

Cdc Tj = 30 °C	0.98
Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.34
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.72
Cdc Tj = 20 °C	0.91
Poff	31 W
PTO	0 W
PSB	31 W
PCK	0 W

## Model ERRA12EV3 / ELVZ12S18E(6V/9W) + cooling kit

Model name	ERRA12EV3 / ELVZ12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.62 kW
COP	4.92	2.94

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.96 kW	
Cooling capacity	8.62	
EER	2.91	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	190 %	136 %
Prated	8.3 kW	12.5 kW
SCOP	4.82	3.47
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.77	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	2
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3560 kWh	7433 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.31	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	2.91	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.17	

Cdc Tj = 30 °C	0.98
Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.13
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.75
Cdc Tj = 20 °C	0.91
Poff	25 W
PTO	3 W
PSB	25 W
PCK	0 W

### Model ERRA12EW1 / ELVZ12S18E(6V/9W) + cooling kit

Model name	ERRA12EW1 / ELVZ12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

### General data

Power supply	3x400V 50Hz
Off-peak product	n/a

### Outdoor Air/Water

#### EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	120 %
COP	2.8
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	53 °C
Mixed water at 40°C	240 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.1	3.05

### EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.86 kW	
Cooling capacity	8.62	
EER	3.01	

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
--	-----------------	--------------------

Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

#### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	196 %	140 %
Prated	8.3 kW	12.5 kW
SCOP	4.98	3.58
Tbiv	-10 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.86	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.06
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3440 kWh	7210 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.41	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	3.01	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.32	



Cdc Tj = 30 °C	0.98
Pdc Tj = 25°C	4.04 kW
EER Tj = 25°C	6.34
Cdc Tj = 25 °C	0.96
Pdc Tj = 20°C	2.69 kW
EER Tj = 20°C	8.72
Cdc Tj = 20 °C	0.91
Poff	31 W
PTO	0 W
PSB	31 W
PCK	0 W

## Model ERRA12EV3 / ELBH12E(6V/9W) + cooling kit

Model name	ERRA12EV3 / ELBH12E(6V/9W) + cooling kit
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.62 kW
COP	4.92	2.94

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.96 kW	
Cooling capacity	8.62	
EER	2.91	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	190 %	136 %
Prated	8.3 kW	12.5 kW
SCOP	4.82	3.47
Tbiv	-10 °C	-5 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.1	2.26
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.76	3.39
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.14	4.9
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	7.84	6.02
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.77	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	2
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3560 kWh	7433 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.31	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	2.91	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.17	
Cdc Tj = 30 °C	0.98	
Pdc Tj = 25°C	4.04 kW	
EER Tj = 25°C	6.13	
Cdc Tj = 25 °C	0.96	
Pdc Tj = 20°C	2.69 kW	
EER Tj = 20°C	8.75	
Cdc Tj = 20 °C	0.91	
Poff	25 W	
PTO	3 W	
PSB	25 W	

PCK

0 W

---

## Model ERRA12EW1 / ELBH12E(6V/9W) + cooling kit

Model name	ERRA12EW1 / ELBH12E(6V/9W) + cooling kit
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.1	3.05

## EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.86 kW	
Cooling capacity	8.62	
EER	3.01	

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	56 dB(A)	56 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	196 %	140 %
Prated	8.3 kW	12.5 kW
SCOP	4.98	3.58
Tbiv	-10 °C	-5 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.2	2.34
Cdh Tj = -7 °C	1	1
Pdh Tj = +2°C	4.4 kW	6.8 kW
COP Tj = +2°C	4.93	3.5
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	4.3 kW	4.5 kW
COP Tj = +7°C	6.37	5.07
Cdh Tj = +7 °C	1	1
Pdh Tj = 12°C	6.6 kW	5.2 kW
COP Tj = 12°C	8.13	6.23
Cdh Tj = +12 °C	1	1
Pdh Tj = Tbiv	8.1 kW	10 kW
COP Tj = Tbiv	2.86	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.2 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.06
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	4.3 kW
Annual energy consumption Qhe	3440 kWh	7210 kWh

#### EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.5 kW	
SEER	5.41	
Pdc Tj = 35°C	8.62 kW	
EER Tj = 35°C	3.01	
Pdc Tj = 30°C	6.68 kW	
EER Tj = 30°C	4.32	
Cdc Tj = 30 °C	0.98	
Pdc Tj = 25°C	4.04 kW	
EER Tj = 25°C	6.34	
Cdc Tj = 25 °C	0.96	
Pdc Tj = 20°C	2.69 kW	
EER Tj = 20°C	8.72	
Cdc Tj = 20 °C	0.91	
Poff	31 W	
PTO	0 W	
PSB	31 W	

PCK

0 W

---