

## Subtype iTec XT 10

Certificate Holder	Thermia
Address	Snickaregatan 1
ZIP	
City	Arvika
Country	SE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	iTec XT 10
Registration number	011-1W0742
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	2.7 kg
Certification Date	12.12.2023
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 12 (as of 2023-03)

## Model iTec XT 10 230-1

Model name	iTec XT 10 230-1
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.60 kW	2.50 kW
COP	5.00	3.20

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	183 %	132 %
Prated	9.50 kW	9.50 kW
SCOP	4.65	3.37
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.40 kW	8.40 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.12 kW	5.12 kW
COP Tj = +2°C	4.55	3.20
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.00 kW	4.00 kW

COP Tj = +7°C	5.70	4.39
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.00 kW	4.00 kW
COP Tj = 12°C	7.70	5.45
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.40 kW	8.40 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.40 kW	9.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	2.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.10 kW	0.10 kW
Annual energy consumption Qhe	4219 kWh	5825 kWh

## Model iTec XT 10 400V

Model name	iTec XT 10 400V
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.60 kW	2.50 kW
COP	5.00	3.20

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	183 %	132 %
Prated	9.50 kW	9.50 kW
SCOP	4.65	3.37
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.40 kW	8.40 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.12 kW	5.12 kW
COP Tj = +2°C	4.55	3.20
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	4.00 kW	4.00 kW

COP Tj = +7°C	5.70	4.39
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	4.00 kW	4.00 kW
COP Tj = 12°C	7.70	5.45
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.40 kW	8.40 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.40 kW	9.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	2.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.10 kW	0.10 kW
Annual energy consumption Qhe	4219 kWh	5825 kWh