

Subtype DFT series 8kW 10kW

Certificate Holder	Qingdao Smad Electric Appliance Co., Ltd.
Address	Room 906, Block C, Vanke Center, No.2 Heilongjiang South Road Shibe District
ZIP	266000
City	QINGDAO
Country	CN
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	DFT series 8kW 10kW
Registration number	011-1W0882
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.3 kg
Certification Date	04.09.2024
Testing basis	HP KEYMARK certification scheme rules V14

Model DFT-008CCH2E1-M

Model name	DFT-008CCH2E1-M
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.62 kW	2.42 kW
COP	4.95	3.30

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	2.50 kW	1.63 kW
Cooling capacity	8.00	8.00
EER	3.20	4.90

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	193 %	151 %
Prated	8.00 kW	8.00 kW
SCOP	4.90	3.85
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	7.07 kW	7.16 kW
COP Tj = -7°C	3.36	2.64
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.57 kW	4.52 kW
COP Tj = +2°C	4.90	3.79
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.07 kW	2.92 kW
COP Tj = +7°C	6.12	4.74
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.64 kW	3.50 kW
COP Tj = 12°C	7.98	6.40
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.11 kW	8.15 kW
COP Tj = Tbiv	2.88	2.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.11 kW	8.15 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.88	2.36
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	75 °C	75 °C
Poff	9 W	9 W
PTO	40 W	40 W
PSB	9 W	9 W
PCK	22 W	22 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3388 kWh	4365 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	8.00 kW	8.00 kW
SEER	4.50	6.30
Pdc Tj = 35°C	8.09 kW	8.14 kW
EER Tj = 35°C	3.21	4.98
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	5.91 kW	6.00 kW
EER Tj = 30°C	4.13	6.25
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	3.83 kW	3.95 kW
EER Tj = 25°C	5.97	8.76
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.34 kW	4.11 kW
EER Tj = 20°C	7.60	10.60
Cdc Tj = 20 °C	0.900	0.900
Poff	9 W	9 W

PTO	40 W	40 W
PSB	9 W	9 W
PCK	0 W	0 W
Annual energy consumption Qce	1056 kWh	770 kWh

Model DFT-010CCH2E1-M

Model name	DFT-010CCH2E1-M
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C, +18°C/+23°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.00 kW	10.00 kW
El input	2.08 kW	3.03 kW
COP	4.80	3.30

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	3.33 kW	2.15 kW
Cooling capacity	10.00	10.00
EER	3.00	4.65

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	193 %	151 %
Prated	10.00 kW	10.00 kW
SCOP	4.90	3.85
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C

Pdh Tj = -7°C	9.05 kW	8.98 kW
COP Tj = -7°C	3.29	2.59
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.44 kW	5.55 kW
COP Tj = +2°C	4.81	3.83
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.54 kW	3.54 kW
COP Tj = +7°C	6.43	4.92
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.66 kW	3.50 kW
COP Tj = 12°C	8.21	6.45
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	10.13 kW	10.15 kW
COP Tj = Tbiv	2.72	2.23
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.13 kW	10.15 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.72	2.23
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	75 °C	75 °C
Poff	9 W	9 W
PTO	40 W	40 W
PSB	9 W	9 W
PCK	22 W	22 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4217 kWh	5361 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	10.00 kW	10.00 kW
SEER	4.50	6.50
Pdc Tj = 35°C	10.07 kW	10.05 kW
EER Tj = 35°C	3.06	4.69
Cdc Tj = 35 °C	0.900	0.900
Pdc Tj = 30°C	7.38 kW	7.49 kW
EER Tj = 30°C	4.01	6.11
Cdc Tj = 30 °C	0.900	0.900
Pdc Tj = 25°C	4.97 kW	4.88 kW
EER Tj = 25°C	5.50	8.31
Cdc Tj = 25 °C	0.900	0.900
Pdc Tj = 20°C	3.34 kW	4.11 kW
EER Tj = 20°C	7.60	10.60
Cdc Tj = 20 °C	0.900	0.900
Poff	9 W	9 W

PTO	40 W	40 W
PSB	9 W	9 W
PCK	0 W	0 W
Annual energy consumption Qce	1306 kWh	927 kWh