

## Subtype TTL 20 AC

Certificate Holder	tecalor GmbH
Address	Lüchtringer Weg 3
ZIP	37603
City	Holzminde
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	TTL 20 AC
Registration number	011-1W0489
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	5.5 kg
Certification Date	15.02.2017

## Model TTL 20 AC

Model name	TTL 20 AC
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.84 kW	7.36 kW
El input	1.54 kW	2.33 kW
COP	5.09	3.16

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	192 %	147 %
Prated	11.00 kW	12.00 kW
SCOP	4.87	3.74
Tbiv	-5 °C	-5 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.50 kW	10.60 kW
COP Tj = -7°C	3.30	2.69
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.72	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.00 kW	7.80 kW

COP Tj = +7°C	6.16	4.61
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.80 kW	9.90 kW
COP Tj = Tbiv	3.46	2.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.53 kW	9.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.50 kW	2.50 kW
Annual energy consumption Qhe	4663 kWh	6625 kWh

#### EN 14825 | Colder Climate

	Low temperature	Medium temperature
$\eta_s$	167 %	133 %
Prated	15.00 kW	17.00 kW
SCOP	4.25	3.41
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.20 kW	10.10 kW
COP Tj = -7°C	3.50	2.91
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.30 kW	8.30 kW
COP Tj = +2°C	5.15	3.92
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.90 kW
COP Tj = +7°C	6.57	5.12
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.20 kW	10.10 kW
COP Tj = Tbiv	3.50	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.80 kW	12.60 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.06	2.56
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	15.27 kW	16.65 kW
Annual energy consumption Qhe	8698 kWh	12299 kWh
Pdh Tj = -15°C (if TOL	11.80	12.60
COP Tj = -15°C (if TOL	3.06	2.56
Cdh Tj = -15 °C	0.90	0.90

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	149 %	177 %
Prated	7.00 kW	8.00 kW
SCOP	3.79	4.51
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.00 kW	8.40 kW
COP Tj = +2°C	3.65	2.74
Cdh Tj = +2 °C	1.000	0.900
Pdh Tj = +7°C	8.20 kW	7.50 kW
COP Tj = +7°C	4.48	3.64
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	9.60 kW	9.00 kW
COP Tj = 12°C	5.82	6.11
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.99 kW	8.40 kW
COP Tj = Tbiv	3.65	2.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.99 kW	12.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.65	2.45
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption  $Q_{he}$ 

2822 kWh

2369 kWh

---