

Subtype Carrier XP ENERGY T 8M/11M AIO

Certificate Holder	Riello S.p.A.
Address	Via Ing. Pilade Riello 7
ZIP	37045
City	Legnago (VR)
Country	IT
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Carrier XP ENERGY T 8M/11M AIO
Registration number	011-1W0709
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.25 kg
Certification Date	24.10.2023
Testing basis	HP KEYMARK certification scheme rules V12

Model 38AW080H7RT / 80AWX110M31RTA

Model name	38AW080H7RT / 80AWX110M31RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	135 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8 kW	9.96 kW
El input	1.54 kW	3.47 kW
COP	5.19	2.87

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.63	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW080H7RT / 80AWX110M61RTA

Model name	38AW080H7RT / 80AWX110M61RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	135 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8 kW	9.96 kW
El input	1.54 kW	3.47 kW
COP	5.19	2.87

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.63	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW080H7RT / 80AWX110T61RTA

Model name	38AW080H7RT / 80AWX110T61RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	135 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8 kW	9.96 kW
El input	1.54 kW	3.47 kW
COP	5.19	2.87

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.63	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW080H7RT / 80AWX110M32RTA

Model name	38AW080H7RT / 80AWX110M32RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	135 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8 kW	9.96 kW
El input	1.54 kW	3.47 kW
COP	5.19	2.87

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.63	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW080H7RT / 80AWX110M62RTA

Model name	38AW080H7RT / 80AWX110M62RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	135 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8 kW	9.96 kW
El input	1.54 kW	3.47 kW
COP	5.19	2.87

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.63	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW080H7RT / 80AWX110T62RTA

Model name	38AW080H7RT / 80AWX110T62RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	135 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8 kW	9.96 kW
El input	1.54 kW	3.47 kW
COP	5.19	2.87

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.63	3.63
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW110H7RT / 80AWX110M31RTA

Model name	38AW110H7RT / 80AWX110M31RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11 kW	10.17 kW
El input	2.39 kW	3.62 kW
COP	4.5	2.81

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.65	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW110H7RT / 80AWX110M61RTA

Model name	38AW110H7RT / 80AWX110M61RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11 kW	10.17 kW
El input	2.39 kW	3.62 kW
COP	4.5	2.81

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.65	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW110H7RT / 80AWX110T61RTA

Model name	38AW110H7RT / 80AWX110T61RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11 kW	10.17 kW
El input	2.39 kW	3.62 kW
COP	4.5	2.81

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.65	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW110H7RT / 80AWX110M32RTA

Model name	38AW110H7RT / 80AWX110M32RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11 kW	10.17 kW
El input	2.39 kW	3.62 kW
COP	4.5	2.81

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.65	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW110H7RT / 80AWX110M62RTA

Model name	38AW110H7RT / 80AWX110M62RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11 kW	10.17 kW
El input	2.39 kW	3.62 kW
COP	4.5	2.81

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.65	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh

Model 38AW110H7RT / 80AWX110T62RTA

Model name	38AW110H7RT / 80AWX110T62RTA
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	130 %
COP	3.27
Heating up time	0:55 h:min
Standby power input	35 W
Reference hot water temperature	47.8 °C
Mixed water at 40°C	235 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	11 kW	10.17 kW
El input	2.39 kW	3.62 kW
COP	4.5	2.81

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	182 %	142 %

Prated	8 kW	8 kW
SCOP	4.65	3.62
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.2 kW	7.3 kW
COP Tj = -7°C	2.72	2.12
Cdh Tj = -7 °C	0.98	0.99
Pdh Tj = +2°C	4.7 kW	4.6 kW
COP Tj = +2°C	4.56	3.6
Cdh Tj = +2 °C	0.95	0.96
Pdh Tj = +7°C	3 kW	3 kW
COP Tj = +7°C	6.3	4.75
Cdh Tj = +7 °C	0.9	0.92
Pdh Tj = 12°C	2.3 kW	2.3 kW
COP Tj = 12°C	8.4	7
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.2 kW	7.3 kW
COP Tj = Tbiv	2.72	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.8 kW	6.7 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.90
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.8	0.9
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	49 W	49 W
PSB	7 W	7 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.2 kW	1.3 kW
Annual energy consumption Qhe	3655 kWh	4675 kWh