

Subtype Air/water HP R290 Monobloc outdoor unit 400V/3N 15kW

Certificate Holder	ES Heat Pumps AB
Address	Metallgatan 2
ZIP	441 32
City	Alingsås
Country	SE
Certification Body	Kiwa Nederland B.V.
Subtype title	Air/water HP R290 Monobloc outdoor unit 400V/3N 15kW
Registration number	007-DQ0208
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	1.5 kg
Certification Date	20.06.2025
Testing basis	European KEYMARK Scheme for Heat Pumps (v15)
Testing laboratory	KIWA, NL

Model ES M15 R290 3PH

Model name	ES M15 R290 3PH
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.55 kW	10.17 kW
El input	1.72 kW	3.33 kW
COP	4.97	3.05

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	179 %	141 %
Prated	12.89 kW	11.10 kW
SCOP	4.54	3.61
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.40 kW	9.82 kW
COP Tj = -7°C	3.07	2.16
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.90 kW	6.32 kW
COP Tj = +2°C	4.33	3.71
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.14 kW	5.78 kW

COP Tj = +7°C	6.41	4.86
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	6.69 kW	6.49 kW
COP Tj = 12°C	7.64	6.09
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.40 kW	9.82 kW
COP Tj = Tbiv	3.07	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.66 kW	8.98 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.85	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.23 kW	2.12 kW
Annual energy consumption Qhe	5860 kWh	6355 kWh

Model HP 15kW R290 3PH

Model name	HP 15kW R290 3PH
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.55 kW	10.17 kW
El input	1.72 kW	3.33 kW
COP	4.97	3.05

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	179 %	141 %
Prated	12.89 kW	11.10 kW
SCOP	4.54	3.61
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.40 kW	9.82 kW
COP Tj = -7°C	3.07	2.16
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	6.90 kW	6.32 kW
COP Tj = +2°C	4.33	3.71
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	6.14 kW	5.78 kW

COP Tj = +7°C	6.41	4.86
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	6.69 kW	6.49 kW
COP Tj = 12°C	7.64	6.09
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	11.40 kW	9.82 kW
COP Tj = Tbiv	3.07	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.66 kW	8.98 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.85	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.23 kW	2.12 kW
Annual energy consumption Qhe	5860 kWh	6355 kWh