

Subtype Grant Aerona HPR29065

Certificate Holder	Grant Engineering (UK) Ltd
Address	Frankland Road Blagrove
ZIP	SN5 8YG
City	Swindon
Country	GB
Certification Body	BRE Global Limited
Subtype title	Grant Aerona HPR29065
Registration number	041-K006-06
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	0.83 kg
Certification Date	14.01.2025
Testing basis	Heat Pump Keymark Scheme Rules Rev 15

Model Grant Aerona HPR29065

Model name	Grant Aerona HPR29065
Application	Heating + DHW + low temp
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	129.3 %
COP	3.05
Heating up time	01:49 h:min
Standby power input	41 W
Reference hot water temperature	55.5 °C
Mixed water at 40°C	330 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.62 kW	7.23 kW
El input	1.54 kW	2.4 kW
COP	4.95	3

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	51 dB(A)	52 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	203 %	145 %
Prated	6.5 kW	6.5 kW
SCOP	5.16	3.7

Tbiv	-9 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.33 kW	5.98 kW
COP Tj = -7°C	3.25	2.33
Cdh Tj = -7 °C	0.9	0.9
Pdh Tj = +2°C	4.03 kW	3.99 kW
COP Tj = +2°C	5.22	3.77
Cdh Tj = +2 °C	0.9	0.9
Pdh Tj = +7°C	2.74 kW	2.75 kW
COP Tj = +7°C	6.85	4.74
Cdh Tj = +7 °C	0.9	0.9
Pdh Tj = 12°C	2.24 kW	2.41 kW
COP Tj = 12°C	8.07	6.17
Cdh Tj = +12 °C	0.9	0.9
Pdh Tj = Tbiv	6.18 kW	6.09 kW
COP Tj = Tbiv	2.91	2.09
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.99 kW	5.65 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.97
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.9	0.9
WTOL	60 °C	60 °C
Poff	7 W	7 W
PTO	25 W	25 W
PSB	7 W	7 W
PCK	20 W	20 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.48 kW	0.79 kW
Annual energy consumption Qhe	2603 kWh	3633 kWh