

## Subtype WPL 20 A

Certificate Holder	STIEBEL ELTRON GmbH & Co KG
Address	Dr. Stiebel Straße 33
ZIP	37603
City	Holzminden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	WPL 20 A
Registration number	011-1W0071
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	4.7 kg
Certification Date	15.02.2017

## Model WPL 20 A

Model name	WPL 20 A
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.84 kW	7.36 kW
El input	1.54 kW	2.33 kW
COP	5.09	3.16

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	185 %	143 %
Prated	11.00 kW	12.00 kW
SCOP	4.70	3.65
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.50 kW	10.60 kW
COP Tj = -7°C	3.30	2.69
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.72	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.00 kW	7.80 kW

COP Tj = +7°C	6.16	4.61
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.80 kW	9.90 kW
COP Tj = Tbiv	3.46	2.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.53 kW	9.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.50 kW	2.50 kW
Annual energy consumption Qhe	4839 kWh	6801 kWh

#### EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	165 %	132 %
Prated	15.00 kW	17.00 kW
SCOP	4.20	3.38
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.20 kW	10.10 kW
COP Tj = -7°C	3.50	2.91
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.30 kW	8.30 kW
COP Tj = +2°C	5.15	3.92
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.90 kW
COP Tj = +7°C	6.57	5.12
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.20 kW	10.10 kW
COP Tj = Tbiv	3.50	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.80 kW	12.60 kW

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.06	2.56
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	15.27 kW	16.65 kW
Annual energy consumption Qhe	8804 kWh	12405 kWh
Pdh Tj = -15°C (if TOL	11.80	12.60
COP Tj = -15°C (if TOL	3.06	2.56
Cdh Tj = -15 °C	0.90	0.90

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
$\eta_s$	214 %	163 %
Prated	7.00 kW	8.00 kW
SCOP	5.44	4.14
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.14	2.74
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.90 kW	7.50 kW
COP Tj = +7°C	5.47	3.64
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.30 kW	8.40 kW
COP Tj = Tbiv	4.14	2.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	12.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.98	2.45
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1720 kWh	2581 kWh

### Model WPL 20 A + HSBC 300 cool "Profile M"

Model name	WPL 20 A + HSBC 300 cool "Profile M"
Application	Heating + DHW + low temp
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

### General data

Power supply	3x400V 50Hz
Off-peak product	n/a

### Outdoor Air/Water

#### EN 16147 | Average Climate

Declared load profile	M
Efficiency $\eta_{DHW}$	79 %
COP	1.72
Heating up time	1:53 h:min
Standby power input	79.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	350 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.84 kW	7.36 kW
El input	1.54 kW	2.33 kW
COP	5.09	3.16

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	185 %	143 %
Prated	11.00 kW	12.00 kW

SCOP	4.70	3.65
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.50 kW	10.60 kW
COP Tj = -7°C	3.30	2.69
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.72	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.00 kW	7.80 kW
COP Tj = +7°C	6.16	4.61
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.80 kW	9.90 kW
COP Tj = Tbiv	3.46	2.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.53 kW	9.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.50 kW	2.50 kW
Annual energy consumption Qhe	4839 kWh	6801 kWh

#### EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	165 %	132 %
Prated	15.00 kW	17.00 kW
SCOP	4.20	3.38
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.20 kW	10.10 kW
COP Tj = -7°C	3.50	2.91
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.30 kW	8.30 kW
COP Tj = +2°C	5.15	3.92
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.90 kW

COP Tj = +7°C	6.57	5.12
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.20 kW	10.10 kW
COP Tj = Tbiv	3.50	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.80 kW	12.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.06	2.56
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	15.27 kW	16.65 kW
Annual energy consumption Qhe	8804 kWh	12405 kWh
Pdh Tj = -15°C (if TOL	11.80	12.60
COP Tj = -15°C (if TOL	3.06	2.56
Cdh Tj = -15 °C	0.90	0.90

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	214 %	163 %
Prated	7.00 kW	8.00 kW
SCOP	5.44	4.14
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.14	2.74
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.90 kW	7.50 kW
COP Tj = +7°C	5.47	3.64
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.30 kW	8.40 kW
COP Tj = Tbiv	4.14	2.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	12.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.98	2.45
WTOL	65 °C	65 °C

Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1720 kWh	2581 kWh



### Model WPL 20 A + HSBC 300 cool "Profile XL"

Model name	WPL 20 A + HSBC 300 cool "Profile XL"
Application	Heating + DHW + low temp
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

### General data

Power supply	n/a
Off-peak product	n/a

### Outdoor Air/Water

#### EN 16147 | Average Climate

Declared load profile	XL
Efficiency $\eta_{DHW}$	111 %
COP	2.60
Heating up time	1:49 h:min
Standby power input	79.0 W
Reference hot water temperature	52.9 °C
Mixed water at 40°C	362 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	7.84 kW	7.36 kW
El input	1.54 kW	2.33 kW
COP	5.09	3.16

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	185 %	143 %
Prated	11.00 kW	12.00 kW

SCOP	4.70	3.65
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.50 kW	10.60 kW
COP Tj = -7°C	3.30	2.69
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.72	3.51
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.00 kW	7.80 kW
COP Tj = +7°C	6.16	4.61
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.80 kW	9.90 kW
COP Tj = Tbiv	3.46	2.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.53 kW	9.48 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.50 kW	2.50 kW
Annual energy consumption Qhe	4839 kWh	6801 kWh

#### EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	165 %	132 %
Prated	15.00 kW	17.00 kW
SCOP	4.20	3.38
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	9.20 kW	10.10 kW
COP Tj = -7°C	3.50	2.91
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.30 kW	8.30 kW
COP Tj = +2°C	5.15	3.92
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.00 kW	7.90 kW

COP Tj = +7°C	6.57	5.12
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.20 kW	10.10 kW
COP Tj = Tbiv	3.50	2.41
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.80 kW	12.60 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.06	2.56
WTOL	65 °C	65 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	15.27 kW	16.65 kW
Annual energy consumption Qhe	8804 kWh	12405 kWh
Pdh Tj = -15°C (if TOL	11.80	12.60
COP Tj = -15°C (if TOL	3.06	2.56
Cdh Tj = -15 °C	0.90	0.90

#### EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	214 %	163 %
Prated	7.00 kW	8.00 kW
SCOP	5.44	4.14
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.30 kW	8.40 kW
COP Tj = +2°C	4.14	2.74
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.90 kW	7.50 kW
COP Tj = +7°C	5.47	3.64
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.30 kW	8.40 kW
COP Tj = Tbiv	4.14	2.74
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.90 kW	12.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.98	2.45
WTOL	65 °C	65 °C

Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	38 W	38 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1720 kWh	2581 kWh