

Subtype Mundoclimate MUACS-80-H14

Certificate Holder	Salvador Escoda S.A.U.
Address	Calle Rosselló 430-432
ZIP	08025
City	Barcelona
Country	ES
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Mundoclimate MUACS-80-H14
Registration number	011-1W0955
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R290
Mass of Refrigerant	0.15 kg
Certification Date	02.01.2025
Testing basis	HP KEYMARK certification scheme rules V14

Model Mundoclima MUACS-80-H14

Model name	Mundoclima MUACS-80-H14
Application	n/a
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Heat Pump for Domestic Hot Water (DHW)

EN 16147 | Operating test

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

EN 12102-2 | Average Climate

Sound power level indoor	54 dB(A)
--------------------------	----------

EN 16147 | Average Climate

Declared load profile	M
Efficiency η_{DHW}	112 %
COP	2.61
Heating up time	4:40 h:min
Standby power input	14.0 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	85 l

EN 12102-2 | Colder Climate

Sound power level indoor	54 dB(A)
--------------------------	----------

EN 16147 | Colder Climate

Declared load profile	M
Efficiency η_{DHW}	95 %
COP	2.28
Heating up time	05:14 h:min
Standby power input	15.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	83 l

EN 12102-2 | Warmer Climate

Sound power level indoor 54 dB(A)

EN 16147 | Warmer Climate

Declared load profile	M
Efficiency η_{DHW}	115 %
COP	2.75
Heating up time	4:02 h:min
Standby power input	14.0 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	84 l