

Subtype Aquarena Split 3 kW STD (K Series)

Certificate Holder	Panasonic Marketing Europe GmbH
Address	Hagenauer Strasse 43, Wiesbaden
ZIP	65203
City	Wiesbaden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Aquarena Split 3 kW STD (K Series)
Registration number	011-1W0604
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	0.9 kg
Certification Date	28.04.2023
Testing basis	European KEYMARK Scheme for Heat Pumps Rev. 11

Model WH-ADC0309K3E5 / WH-UDZ03KE5

Model name	WH-ADC0309K3E5 / WH-UDZ03KE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	129 %
COP	3.23
Heating up time	1:32 h:min
Standby power input	31.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	99 %
COP	2.48
Heating up time	1:32 h:min
Standby power input	34.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	154 %
COP	3.86
Heating up time	1:32 h:min
Standby power input	28.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.20 kW	3.20 kW
El input	0.60 kW	1.14 kW
COP	5.33	2.81

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	0.91 kW	0.68 kW
Cooling capacity	3.20	3.20
EER	3.52	4.71

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	200 %	136 %
Prated	4.00 kW	3.00 kW
SCOP	5.07	3.47
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.50 kW	2.60 kW
COP Tj = -7°C	2.80	2.18
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	2.00 kW	1.60 kW
COP Tj = +2°C	5.14	3.42
Cdh Tj = +2 °C	0.930	0.940
Pdh Tj = +7°C	1.40 kW	1.10 kW
COP Tj = +7°C	6.80	4.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.40 kW
COP Tj = 12°C	9.50	6.97
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	2.90 kW
COP Tj = Tbiv	2.60	1.66
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	2.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.66

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1631 kWh	1788 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	157 %	110 %
Prated	3.00 kW	2.00 kW
SCOP	4.00	2.83
Tbiv	-20 °C	-20 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	1.80 kW	1.21 kW
COP Tj = -7°C	3.26	2.16
Cdh Tj = -7 °C	0.950	0.950
Pdh Tj = +2°C	1.75 kW	1.41 kW
COP Tj = +2°C	5.17	3.80
Cdh Tj = +2 °C	0.920	0.930
Pdh Tj = +7°C	1.30 kW	1.19 kW
COP Tj = +7°C	7.00	5.05
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.51 kW
COP Tj = 12°C	9.00	7.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	2.84 kW	1.84 kW
COP Tj = Tbiv	1.80	1.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.00 kW	1.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.81	1.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W

PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	0.04 kW
Annual energy consumption Q _{he}	1848 kWh	1740 kWh
P _{dh} T _j = -15 °C (if TOL	2.40	1.66
COP T _j = -15 °C (if TOL	2.29	1.76
C _{dh} T _j = -15 °C	0.980	0.970

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	224 %	165 %
Prated	4.00 kW	4.00 kW
SCOP	6.20	4.20
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2 °C	3.95 kW	3.90 kW
COP T _j = +2 °C	3.15	1.80
C _{dh} T _j = +2 °C	0.980	0.990
P _{dh} T _j = +7 °C	2.60 kW	2.52 kW
COP T _j = +7 °C	5.61	3.55
C _{dh} T _j = +7 °C	0.940	0.960
P _{dh} T _j = 12 °C	1.50 kW	1.40 kW
COP T _j = 12 °C	8.35	6.00
C _{dh} T _j = +12 °C	0.900	0.900
P _{dh} T _j = T _{biv}	3.95 kW	3.90 kW
COP T _j = T _{biv}	3.15	1.80
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.95 kW	3.90 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.15	1.80
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.900	0.900
WTOL	55 °C	55 °C
P _{off}	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q _{he}	862 kWh	1274 kWh
---	---------	----------

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
P _{designc}	3.00 kW	
SEER	6.29	
P _{dc} T _j = 35°C	3.00 kW	
EER T _j = 35°C	3.95	
C _{dc} T _j = 35 °C	0.900	
P _{dc} T _j = 30°C	2.21 kW	
EER T _j = 30°C	5.37	
C _{dc} T _j = 30 °C	0.900	
P _{dc} T _j = 25°C	1.42 kW	
EER T _j = 25°C	7.44	
C _{dc} T _j = 25 °C	0.900	
P _{dc} T _j = 20°C	0.63 kW	
EER T _j = 20°C	8.93	
C _{dc} T _j = 20 °C	0.900	
P _{off}	5 W	
PTO	0 W	
PSB	5 W	
PCK	0 W	
Annual energy consumption Q _{ce}	167 kWh	

Model WH-ADC0309K3E5AN / WH-UDZ03KE5

Model name	WH-ADC0309K3E5AN / WH-UDZ03KE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	129 %
COP	3.23
Heating up time	1:32 h:min
Standby power input	31.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	99 %
COP	2.48
Heating up time	1:32 h:min
Standby power input	34.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	154 %
COP	3.86
Heating up time	1:32 h:min
Standby power input	28.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.20 kW	3.20 kW
El input	0.60 kW	1.14 kW
COP	5.33	2.81

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	0.91 kW	0.68 kW
Cooling capacity	3.20	3.20
EER	3.52	4.71

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	200 %	136 %
Prated	4.00 kW	3.00 kW
SCOP	5.07	3.47
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.50 kW	2.60 kW
COP Tj = -7°C	2.80	2.18
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	2.00 kW	1.60 kW
COP Tj = +2°C	5.14	3.42
Cdh Tj = +2 °C	0.930	0.940
Pdh Tj = +7°C	1.40 kW	1.10 kW
COP Tj = +7°C	6.80	4.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.40 kW
COP Tj = 12°C	9.50	6.97
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	2.90 kW
COP Tj = Tbiv	2.60	1.66
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	2.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.66

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1631 kWh	1788 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	157 %	110 %
Prated	3.00 kW	2.00 kW
SCOP	4.00	2.83
Tbiv	-20 °C	-20 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	1.80 kW	1.21 kW
COP Tj = -7°C	3.26	2.16
Cdh Tj = -7 °C	0.950	0.950
Pdh Tj = +2°C	1.75 kW	1.41 kW
COP Tj = +2°C	5.17	3.80
Cdh Tj = +2 °C	0.920	0.930
Pdh Tj = +7°C	1.30 kW	1.19 kW
COP Tj = +7°C	7.00	5.05
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.51 kW
COP Tj = 12°C	9.00	7.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	2.84 kW	1.84 kW
COP Tj = Tbiv	1.80	1.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.00 kW	1.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.81	1.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W

PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	0.04 kW
Annual energy consumption Q _{he}	1848 kWh	1740 kWh
P _{dh} T _j = -15 °C (if TOL	2.40	1.66
COP T _j = -15 °C (if TOL	2.29	1.76
C _{dh} T _j = -15 °C	0.980	0.970

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	224 %	165 %
Prated	4.00 kW	4.00 kW
SCOP	6.20	4.20
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2 °C	3.95 kW	3.90 kW
COP T _j = +2 °C	3.15	1.80
C _{dh} T _j = +2 °C	0.980	0.990
P _{dh} T _j = +7 °C	2.60 kW	2.52 kW
COP T _j = +7 °C	5.61	3.55
C _{dh} T _j = +7 °C	0.940	0.960
P _{dh} T _j = 12 °C	1.50 kW	1.40 kW
COP T _j = 12 °C	8.35	6.00
C _{dh} T _j = +12 °C	0.900	0.900
P _{dh} T _j = T _{biv}	3.95 kW	3.90 kW
COP T _j = T _{biv}	3.15	1.80
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.95 kW	3.90 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.15	1.80
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.900	0.900
WTOL	55 °C	55 °C
P _{off}	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Qhe	862 kWh	1274 kWh
-------------------------------	---------	----------

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	3.00 kW	
SEER	6.29	
Pdc Tj = 35°C	3.00 kW	
EER Tj = 35°C	3.95	
Cdc Tj = 35 °C	0.900	
Pdc Tj = 30°C	2.21 kW	
EER Tj = 30°C	5.37	
Cdc Tj = 30 °C	0.900	
Pdc Tj = 25°C	1.42 kW	
EER Tj = 25°C	7.44	
Cdc Tj = 25 °C	0.900	
Pdc Tj = 20°C	0.63 kW	
EER Tj = 20°C	8.93	
Cdc Tj = 20 °C	0.900	
Poff	5 W	
PTO	0 W	
PSB	5 W	
PCK	0 W	
Annual energy consumption Qce	167 kWh	

Model WH-ADC0309K3E5B / WH-UDZ03KE5

Model name	WH-ADC0309K3E5B / WH-UDZ03KE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	129 %
COP	3.23
Heating up time	1:32 h:min
Standby power input	31.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	99 %
COP	2.48
Heating up time	1:32 h:min
Standby power input	34.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	154 %
COP	3.86
Heating up time	1:32 h:min
Standby power input	28.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	3.20 kW	3.20 kW
El input	0.60 kW	1.14 kW
COP	5.33	2.81
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	0.91 kW	0.68 kW
Cooling capacity	3.20	3.20
EER	3.52	4.71
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	200 %	136 %
Prated	4.00 kW	3.00 kW
SCOP	5.07	3.47
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.50 kW	2.60 kW
COP Tj = -7°C	2.80	2.18
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	2.00 kW	1.60 kW
COP Tj = +2°C	5.14	3.42
Cdh Tj = +2 °C	0.930	0.940
Pdh Tj = +7°C	1.40 kW	1.10 kW
COP Tj = +7°C	6.80	4.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.40 kW
COP Tj = 12°C	9.50	6.97
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	2.90 kW
COP Tj = Tbiv	2.60	1.66
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	2.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.66

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1631 kWh	1788 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	157 %	110 %
Prated	3.00 kW	2.00 kW
SCOP	4.00	2.83
Tbiv	-20 °C	-20 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	1.80 kW	1.21 kW
COP Tj = -7°C	3.26	2.16
Cdh Tj = -7 °C	0.950	0.950
Pdh Tj = +2°C	1.75 kW	1.41 kW
COP Tj = +2°C	5.17	3.80
Cdh Tj = +2 °C	0.920	0.930
Pdh Tj = +7°C	1.30 kW	1.19 kW
COP Tj = +7°C	7.00	5.05
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.51 kW
COP Tj = 12°C	9.00	7.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	2.84 kW	1.84 kW
COP Tj = Tbiv	1.80	1.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.00 kW	1.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.81	1.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W

PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	0.04 kW
Annual energy consumption Q _{he}	1848 kWh	1740 kWh
P _{dh} T _j = -15°C (if TOL	2.40	1.66
COP T _j = -15°C (if TOL	2.29	1.76
C _{dh} T _j = -15 °C	0.980	0.970

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	224 %	165 %
Prated	4.00 kW	4.00 kW
SCOP	6.20	4.20
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	3.95 kW	3.90 kW
COP T _j = +2°C	3.15	1.80
C _{dh} T _j = +2 °C	0.980	0.990
P _{dh} T _j = +7°C	2.60 kW	2.52 kW
COP T _j = +7°C	5.61	3.55
C _{dh} T _j = +7 °C	0.940	0.960
P _{dh} T _j = 12°C	1.50 kW	1.40 kW
COP T _j = 12°C	8.35	6.00
C _{dh} T _j = +12 °C	0.900	0.900
P _{dh} T _j = T _{biv}	3.95 kW	3.90 kW
COP T _j = T _{biv}	3.15	1.80
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.95 kW	3.90 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.15	1.80
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.900	0.900
WTOL	55 °C	55 °C
P _{off}	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q _{he}	862 kWh	1274 kWh
---	---------	----------

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
P _{designc}	3.00 kW	
SEER	6.29	
P _{dc} T _j = 35°C	3.00 kW	
EER T _j = 35°C	3.95	
C _{dc} T _j = 35 °C	0.900	
P _{dc} T _j = 30°C	2.21 kW	
EER T _j = 30°C	5.37	
C _{dc} T _j = 30 °C	0.900	
P _{dc} T _j = 25°C	1.42 kW	
EER T _j = 25°C	7.44	
C _{dc} T _j = 25 °C	0.900	
P _{dc} T _j = 20°C	0.63 kW	
EER T _j = 20°C	8.93	
C _{dc} T _j = 20 °C	0.900	
P _{off}	5 W	
PTO	0 W	
PSB	5 W	
PCK	0 W	
Annual energy consumption Q _{ce}	167 kWh	

Model WH-ADC0309K3E5UK/ WH-UDZ03KE5

Model name	WH-ADC0309K3E5UK/ WH-UDZ03KE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	129 %
COP	3.23
Heating up time	1:32 h:min
Standby power input	31.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	99 %
COP	2.48
Heating up time	1:32 h:min
Standby power input	34.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	154 %
COP	3.86
Heating up time	1:32 h:min
Standby power input	28.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	3.20 kW	3.20 kW
El input	0.60 kW	1.14 kW
COP	5.33	2.81
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	0.91 kW	0.68 kW
Cooling capacity	3.20	3.20
EER	3.52	4.71
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	200 %	136 %
Prated	4.00 kW	3.00 kW
SCOP	5.07	3.47
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.50 kW	2.60 kW
COP Tj = -7°C	2.80	2.18
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	2.00 kW	1.60 kW
COP Tj = +2°C	5.14	3.42
Cdh Tj = +2 °C	0.930	0.940
Pdh Tj = +7°C	1.40 kW	1.10 kW
COP Tj = +7°C	6.80	4.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.40 kW
COP Tj = 12°C	9.50	6.97
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	2.90 kW
COP Tj = Tbiv	2.60	1.66
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	2.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.66

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1631 kWh	1788 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	157 %	110 %
Prated	3.00 kW	2.00 kW
SCOP	4.00	2.83
Tbiv	-20 °C	-20 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	1.80 kW	1.21 kW
COP Tj = -7°C	3.26	2.16
Cdh Tj = -7 °C	0.950	0.950
Pdh Tj = +2°C	1.75 kW	1.41 kW
COP Tj = +2°C	5.17	3.80
Cdh Tj = +2 °C	0.920	0.930
Pdh Tj = +7°C	1.30 kW	1.19 kW
COP Tj = +7°C	7.00	5.05
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.51 kW
COP Tj = 12°C	9.00	7.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	2.84 kW	1.84 kW
COP Tj = Tbiv	1.80	1.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.00 kW	1.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.81	1.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W

PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	0.04 kW
Annual energy consumption Q _{he}	1848 kWh	1740 kWh
P _{dh} T _j = -15°C (if TOL	2.40	1.66
COP T _j = -15°C (if TOL	2.29	1.76
C _{dh} T _j = -15 °C	0.980	0.970

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	224 %	165 %
Prated	4.00 kW	4.00 kW
SCOP	6.20	4.20
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2°C	3.95 kW	3.90 kW
COP T _j = +2°C	3.15	1.80
C _{dh} T _j = +2 °C	0.980	0.990
P _{dh} T _j = +7°C	2.60 kW	2.52 kW
COP T _j = +7°C	5.61	3.55
C _{dh} T _j = +7 °C	0.940	0.960
P _{dh} T _j = 12°C	1.50 kW	1.40 kW
COP T _j = 12°C	8.35	6.00
C _{dh} T _j = +12 °C	0.900	0.900
P _{dh} T _j = T _{biv}	3.95 kW	3.90 kW
COP T _j = T _{biv}	3.15	1.80
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.95 kW	3.90 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.15	1.80
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.900	0.900
WTOL	55 °C	55 °C
P _{off}	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q _{he}	862 kWh	1274 kWh
EN 14825 Cooling		
	+7°C/+12°C	+18°C/+23°C
P _{designc}	3.00 kW	
SEER	6.29	
P _{dc} T _j = 35°C	3.00 kW	
EER T _j = 35°C	3.95	
C _{dc} T _j = 35 °C	0.900	
P _{dc} T _j = 30°C	2.21 kW	
EER T _j = 30°C	5.37	
C _{dc} T _j = 30 °C	0.900	
P _{dc} T _j = 25°C	1.42 kW	
EER T _j = 25°C	7.44	
C _{dc} T _j = 25 °C	0.900	
P _{dc} T _j = 20°C	0.63 kW	
EER T _j = 20°C	8.93	
C _{dc} T _j = 20 °C	0.900	
P _{off}	5 W	
PTO	0 W	
PSB	5 W	
PCK	0 W	
Annual energy consumption Q _{ce}	167 kWh	

Model WH-ADC0309K6E5 / WH-UDZ03KE5

Model name	WH-ADC0309K6E5 / WH-UDZ03KE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	129 %
COP	3.23
Heating up time	1:32 h:min
Standby power input	31.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	99 %
COP	2.48
Heating up time	1:32 h:min
Standby power input	34.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	154 %
COP	3.86
Heating up time	1:32 h:min
Standby power input	28.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.20 kW	3.20 kW
El input	0.60 kW	1.14 kW
COP	5.33	2.81

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	0.91 kW	0.68 kW
Cooling capacity	3.20	3.20
EER	3.52	4.71

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	200 %	136 %
Prated	4.00 kW	3.00 kW
SCOP	5.07	3.47
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.50 kW	2.60 kW
COP Tj = -7°C	2.80	2.18
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	2.00 kW	1.60 kW
COP Tj = +2°C	5.14	3.42
Cdh Tj = +2 °C	0.930	0.940
Pdh Tj = +7°C	1.40 kW	1.10 kW
COP Tj = +7°C	6.80	4.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.40 kW
COP Tj = 12°C	9.50	6.97
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	2.90 kW
COP Tj = Tbiv	2.60	1.66
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	2.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.66

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1631 kWh	1788 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	157 %	110 %
Prated	3.00 kW	2.00 kW
SCOP	4.00	2.83
Tbiv	-20 °C	-20 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	1.80 kW	1.21 kW
COP Tj = -7°C	3.26	2.16
Cdh Tj = -7 °C	0.950	0.950
Pdh Tj = +2°C	1.75 kW	1.41 kW
COP Tj = +2°C	5.17	3.80
Cdh Tj = +2 °C	0.920	0.930
Pdh Tj = +7°C	1.30 kW	1.19 kW
COP Tj = +7°C	7.00	5.05
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.51 kW
COP Tj = 12°C	9.00	7.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	2.84 kW	1.84 kW
COP Tj = Tbiv	1.80	1.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.00 kW	1.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.81	1.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W

PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	0.04 kW
Annual energy consumption Q _{he}	1848 kWh	1740 kWh
P _{dh} T _j = -15 °C (if TOL	2.40	1.66
COP T _j = -15 °C (if TOL	2.29	1.76
C _{dh} T _j = -15 °C	0.980	0.970

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	224 %	165 %
Prated	4.00 kW	4.00 kW
SCOP	6.20	4.20
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2 °C	3.95 kW	3.90 kW
COP T _j = +2 °C	3.15	1.80
C _{dh} T _j = +2 °C	0.980	0.990
P _{dh} T _j = +7 °C	2.60 kW	2.52 kW
COP T _j = +7 °C	5.61	3.55
C _{dh} T _j = +7 °C	0.940	0.960
P _{dh} T _j = 12 °C	1.50 kW	1.40 kW
COP T _j = 12 °C	8.35	6.00
C _{dh} T _j = +12 °C	0.900	0.900
P _{dh} T _j = T _{biv}	3.95 kW	3.90 kW
COP T _j = T _{biv}	3.15	1.80
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.95 kW	3.90 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.15	1.80
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.900	0.900
WTOL	55 °C	55 °C
P _{off}	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q _{he}	862 kWh	1274 kWh
EN 14825 Cooling		
	+7°C/+12°C	+18°C/+23°C
P _{designc}	3.00 kW	
SEER	6.29	
P _{dc} T _j = 35°C	3.00 kW	
EER T _j = 35°C	3.95	
C _{dc} T _j = 35 °C	0.900	
P _{dc} T _j = 30°C	2.21 kW	
EER T _j = 30°C	5.37	
C _{dc} T _j = 30 °C	0.900	
P _{dc} T _j = 25°C	1.42 kW	
EER T _j = 25°C	7.44	
C _{dc} T _j = 25 °C	0.900	
P _{dc} T _j = 20°C	0.63 kW	
EER T _j = 20°C	8.93	
C _{dc} T _j = 20 °C	0.900	
P _{off}	5 W	
PTO	0 W	
PSB	5 W	
PCK	0 W	
Annual energy consumption Q _{ce}	167 kWh	

Model WH-ADC0309K6E5AN / WH-UDZ03KE5

Model name	WH-ADC0309K6E5AN / WH-UDZ03KE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	129 %
COP	3.23
Heating up time	1:32 h:min
Standby power input	31.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	99 %
COP	2.48
Heating up time	1:32 h:min
Standby power input	34.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	154 %
COP	3.86
Heating up time	1:32 h:min
Standby power input	28.0 W
Reference hot water temperature	53.3 °C
Mixed water at 40°C	239 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

Defrost test	passed	
Starting and operating test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	3.20 kW	3.20 kW
El input	0.60 kW	1.14 kW
COP	5.33	2.81
EN 14511-2 Cooling		
	+7°C/+12°C	+18°C/+23°C
El input	0.91 kW	0.68 kW
Cooling capacity	3.20	3.20
EER	3.52	4.71
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	200 %	136 %
Prated	4.00 kW	3.00 kW
SCOP	5.07	3.47
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.50 kW	2.60 kW
COP Tj = -7°C	2.80	2.18
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	2.00 kW	1.60 kW
COP Tj = +2°C	5.14	3.42
Cdh Tj = +2 °C	0.930	0.940
Pdh Tj = +7°C	1.40 kW	1.10 kW
COP Tj = +7°C	6.80	4.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.40 kW
COP Tj = 12°C	9.50	6.97
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	2.90 kW
COP Tj = Tbiv	2.60	1.66
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	2.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.66

Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1631 kWh	1788 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	157 %	110 %
Prated	3.00 kW	2.00 kW
SCOP	4.00	2.83
Tbiv	-20 °C	-20 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	1.80 kW	1.21 kW
COP Tj = -7°C	3.26	2.16
Cdh Tj = -7 °C	0.950	0.950
Pdh Tj = +2°C	1.75 kW	1.41 kW
COP Tj = +2°C	5.17	3.80
Cdh Tj = +2 °C	0.920	0.930
Pdh Tj = +7°C	1.30 kW	1.19 kW
COP Tj = +7°C	7.00	5.05
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.51 kW
COP Tj = 12°C	9.00	7.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	2.84 kW	1.84 kW
COP Tj = Tbiv	1.80	1.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.00 kW	1.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.81	1.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W

PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	0.04 kW
Annual energy consumption Q _{he}	1848 kWh	1740 kWh
P _{dh} T _j = -15 °C (if TOL	2.40	1.66
COP T _j = -15 °C (if TOL	2.29	1.76
C _{dh} T _j = -15 °C	0.980	0.970

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η _s	224 %	165 %
Prated	4.00 kW	4.00 kW
SCOP	6.20	4.20
T _{biv}	2 °C	2 °C
TOL	2 °C	2 °C
P _{dh} T _j = +2 °C	3.95 kW	3.90 kW
COP T _j = +2 °C	3.15	1.80
C _{dh} T _j = +2 °C	0.980	0.990
P _{dh} T _j = +7 °C	2.60 kW	2.52 kW
COP T _j = +7 °C	5.61	3.55
C _{dh} T _j = +7 °C	0.940	0.960
P _{dh} T _j = 12 °C	1.50 kW	1.40 kW
COP T _j = 12 °C	8.35	6.00
C _{dh} T _j = +12 °C	0.900	0.900
P _{dh} T _j = T _{biv}	3.95 kW	3.90 kW
COP T _j = T _{biv}	3.15	1.80
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	3.95 kW	3.90 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	3.15	1.80
C _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	0.900	0.900
WTOL	55 °C	55 °C
P _{off}	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

Annual energy consumption Q _{he}	862 kWh	1274 kWh
---	---------	----------

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
P _{designc}	3.00 kW	
SEER	6.29	
P _{dc} T _j = 35°C	3.00 kW	
EER T _j = 35°C	3.95	
C _{dc} T _j = 35 °C	0.900	
P _{dc} T _j = 30°C	2.21 kW	
EER T _j = 30°C	5.37	
C _{dc} T _j = 30 °C	0.900	
P _{dc} T _j = 25°C	1.42 kW	
EER T _j = 25°C	7.44	
C _{dc} T _j = 25 °C	0.900	
P _{dc} T _j = 20°C	0.63 kW	
EER T _j = 20°C	8.93	
C _{dc} T _j = 20 °C	0.900	
P _{off}	5 W	
PTO	0 W	
PSB	5 W	
PCK	0 W	
Annual energy consumption Q _{ce}	167 kWh	

Model WH-SDC0309K3E5 / WH-UDZ03KE5

Model name	WH-SDC0309K3E5 / WH-UDZ03KE5
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.20 kW	3.20 kW
El input	0.60 kW	1.14 kW
COP	5.33	2.81

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	0.91 kW	0.68 kW
Cooling capacity	3.20	3.20
EER	3.52	4.71

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	200 %	136 %
Prated	4.00 kW	3.00 kW
SCOP	5.07	3.47
Tbiv	-10 °C	-10 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.50 kW	2.60 kW
COP Tj = -7°C	2.80	2.18
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	2.00 kW	1.60 kW
COP Tj = +2°C	5.14	3.42
Cdh Tj = +2 °C	0.930	0.940
Pdh Tj = +7°C	1.40 kW	1.10 kW
COP Tj = +7°C	6.80	4.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.40 kW
COP Tj = 12°C	9.50	6.97
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	2.90 kW
COP Tj = Tbiv	2.60	1.66
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	2.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.66
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1631 kWh	1788 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	157 %	110 %
Prated	3.00 kW	2.00 kW
SCOP	4.00	2.83
Tbiv	-20 °C	-20 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	1.80 kW	1.21 kW
COP Tj = -7°C	3.26	2.16
Cdh Tj = -7 °C	0.950	0.950
Pdh Tj = +2°C	1.75 kW	1.41 kW

COP Tj = +2°C	5.17	3.80
Cdh Tj = +2 °C	0.920	0.930
Pdh Tj = +7°C	1.30 kW	1.19 kW
COP Tj = +7°C	7.00	5.05
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.51 kW
COP Tj = 12°C	9.00	7.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	2.84 kW	1.84 kW
COP Tj = Tbiv	1.80	1.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.00 kW	1.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.81	1.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	0.04 kW
Annual energy consumption Qhe	1848 kWh	1740 kWh
Pdh Tj = -15°C (if TOL	2.40	1.66
COP Tj = -15°C (if TOL	2.29	1.76
Cdh Tj = -15 °C	0.980	0.970

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	165 %
Prated	4.00 kW	4.00 kW
SCOP	6.20	4.20
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	3.95 kW	3.90 kW
COP Tj = +2°C	3.15	1.80
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.60 kW	2.52 kW
COP Tj = +7°C	5.61	3.55
Cdh Tj = +7 °C	0.940	0.960

Pdh Tj = 12°C	1.50 kW	1.40 kW
COP Tj = 12°C	8.35	6.00
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	3.90 kW
COP Tj = Tbiv	3.15	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	3.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	862 kWh	1274 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	3.00 kW	
SEER	6.29	
Pdc Tj = 35°C	3.00 kW	
EER Tj = 35°C	3.95	
Cdc Tj = 35 °C	0.900	
Pdc Tj = 30°C	2.21 kW	
EER Tj = 30°C	5.37	
Cdc Tj = 30 °C	0.900	
Pdc Tj = 25°C	1.42 kW	
EER Tj = 25°C	7.44	
Cdc Tj = 25 °C	0.900	
Pdc Tj = 20°C	0.63 kW	
EER Tj = 20°C	8.93	
Cdc Tj = 20 °C	0.900	
Poff	5 W	
PTO	0 W	
PSB	5 W	
PCK	0 W	
Annual energy consumption Qce	167 kWh	

Model WH-SDC0309K6E5 / WH-UDZ03KE5

Model name	WH-SDC0309K6E5 / WH-UDZ03KE5
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	3.20 kW	3.20 kW
El input	0.60 kW	1.14 kW
COP	5.33	2.81

EN 14511-2 | Cooling

	+7°C/+12°C	+18°C/+23°C
El input	0.91 kW	0.68 kW
Cooling capacity	3.20	3.20
EER	3.52	4.71

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	200 %	136 %
Prated	4.00 kW	3.00 kW
SCOP	5.07	3.47
Tbiv	-10 °C	-10 °C

TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.50 kW	2.60 kW
COP Tj = -7°C	2.80	2.18
Cdh Tj = -7 °C	0.980	0.980
Pdh Tj = +2°C	2.00 kW	1.60 kW
COP Tj = +2°C	5.14	3.42
Cdh Tj = +2 °C	0.930	0.940
Pdh Tj = +7°C	1.40 kW	1.10 kW
COP Tj = +7°C	6.80	4.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.40 kW
COP Tj = 12°C	9.50	6.97
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	2.90 kW
COP Tj = Tbiv	2.60	1.66
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	2.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.60	1.66
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1631 kWh	1788 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	157 %	110 %
Prated	3.00 kW	2.00 kW
SCOP	4.00	2.83
Tbiv	-20 °C	-20 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	1.80 kW	1.21 kW
COP Tj = -7°C	3.26	2.16
Cdh Tj = -7 °C	0.950	0.950
Pdh Tj = +2°C	1.75 kW	1.41 kW

COP Tj = +2°C	5.17	3.80
Cdh Tj = +2 °C	0.920	0.930
Pdh Tj = +7°C	1.30 kW	1.19 kW
COP Tj = +7°C	7.00	5.05
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.55 kW	1.51 kW
COP Tj = 12°C	9.00	7.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	2.84 kW	1.84 kW
COP Tj = Tbiv	1.80	1.36
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.00 kW	1.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.81	1.05
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.00 kW	0.04 kW
Annual energy consumption Qhe	1848 kWh	1740 kWh
Pdh Tj = -15°C (if TOL	2.40	1.66
COP Tj = -15°C (if TOL	2.29	1.76
Cdh Tj = -15 °C	0.980	0.970

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	41 dB(A)	41 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	224 %	165 %
Prated	4.00 kW	4.00 kW
SCOP	6.20	4.20
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	3.95 kW	3.90 kW
COP Tj = +2°C	3.15	1.80
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	2.60 kW	2.52 kW
COP Tj = +7°C	5.61	3.55
Cdh Tj = +7 °C	0.940	0.960

Pdh Tj = 12°C	1.50 kW	1.40 kW
COP Tj = 12°C	8.35	6.00
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	3.95 kW	3.90 kW
COP Tj = Tbiv	3.15	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.95 kW	3.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.15	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	26 W	26 W
PSB	8 W	8 W
PCK	8 W	8 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	862 kWh	1274 kWh

EN 14825 | Cooling

	+7°C/+12°C	+18°C/+23°C
Pdesignc	3.00 kW	
SEER	6.29	
Pdc Tj = 35°C	3.00 kW	
EER Tj = 35°C	3.95	
Cdc Tj = 35 °C	0.900	
Pdc Tj = 30°C	2.21 kW	
EER Tj = 30°C	5.37	
Cdc Tj = 30 °C	0.900	
Pdc Tj = 25°C	1.42 kW	
EER Tj = 25°C	7.44	
Cdc Tj = 25 °C	0.900	
Pdc Tj = 20°C	0.63 kW	
EER Tj = 20°C	8.93	
Cdc Tj = 20 °C	0.900	
Poff	5 W	
PTO	0 W	
PSB	5 W	
PCK	0 W	
Annual energy consumption Qce	167 kWh	