

Subtype CHA-10/400V

Certificate Holder	WOLF GmbH
Address	Industriestr. 1
ZIP	84048
City	Mainburg
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	CHA-10/400V
Registration number	011-1W0381
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	3.4 kg
Certification Date	30.06.2020

Model CHA-10/400V

Model name	CHA-10/400V
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.10 kW	3.99 kW
El input	0.75 kW	1.29 kW
COP	5.54	3.09

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	191 %	141 %
Prated	7.58 kW	7.40 kW
SCOP	4.86	3.60
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.25 kW	7.03 kW
COP Tj = -7°C	2.92	2.09
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.33 kW	4.28 kW
COP Tj = +2°C	4.69	3.45
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.72 kW	3.54 kW

COP Tj = +7°C	6.89	5.07
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	3.75 kW	4.09 kW
COP Tj = 12°C	7.43	6.60
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	7.58 kW	7.40 kW
COP Tj = Tbiv	2.52	1.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.58 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.75
WTOL	35 °C	55 °C
Poff	13 W	13 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	3225 kWh	4255 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	177 %	135 %
Prated	8.78 kW	8.17 kW
SCOP	4.50	3.44
Tbiv	-17 °C	-17 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.32 kW	5.44 kW
COP Tj = -7°C	4.00	2.84
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.36 kW	3.30 kW
COP Tj = +2°C	5.10	4.25
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.73 kW	3.61 kW
COP Tj = +7°C	7.24	5.52
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	4.03 kW	3.90 kW
COP Tj = 12°C	7.70	6.57
Cdh Tj = +12 °C	0.97	0.97
Pdh Tj = Tbiv	7.62 kW	7.09 kW
COP Tj = Tbiv	2.47	1.70

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.70 kW	5.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.19	1.35
WTOL	35 °C	55 °C
Poff	13 W	13 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4812 kWh	5852 kWh
Pdh Tj = -15°C (if TOL	7.10	7.28
COP Tj = -15°C (if TOL	2.77	1.99
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	272 %	185 %
Prated	8.57 kW	8.64 kW
SCOP	6.88	4.71
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = +2°C	8.57 kW	8.64 kW
COP Tj = +2°C	3.51	2.40
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.99 kW	5.93 kW
COP Tj = +7°C	6.41	4.14
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.14 kW	3.82 kW
COP Tj = 12°C	8.36	5.99
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	8.57 kW	8.64 kW
COP Tj = Tbiv	3.51	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.57 kW	8.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.51	2.40
WTOL	35 °C	55 °C
Poff	13 W	13 W
PTO	15 W	15 W
PSB	15 W	15 W

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1665 kWh	2451 kWh

Model CHA-10/400V + CEW-2-200 (CHC-Monoblock 10/200 ; CHC-Monoblock 10/200-35)

Model name	CHA-10/400V + CEW-2-200 (CHC-Monoblock 10/200 ; CHC-Monoblock 10/200-35)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	126 %
COP	3.05
Heating up time	01:57 h:min
Standby power input	38.7 W
Reference hot water temperature	50.1 °C
Mixed water at 40°C	229 l

EN 16147 | Colder Climate

Declared load profile	XL
Efficiency η_{DHW}	112 %
COP	2.69
Heating up time	2:02 h:min
Standby power input	48.7 W
Reference hot water temperature	50.3 °C
Mixed water at 40°C	228 l

EN 16147 | Warmer Climate

Declared load profile	XL
Efficiency η_{DHW}	150 %
COP	3.60
Heating up time	02:00 h:min
Standby power input	38.5 W
Reference hot water temperature	50.1 °C
Mixed water at 40°C	231 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.10 kW	3.99 kW
El input	0.75 kW	1.29 kW
COP	5.54	3.09

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	191 %	141 %
Prated	7.58 kW	7.40 kW
SCOP	4.86	3.60
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.25 kW	7.03 kW
COP Tj = -7°C	2.92	2.09
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.33 kW	4.28 kW
COP Tj = +2°C	4.69	3.45
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.72 kW	3.54 kW
COP Tj = +7°C	6.89	5.07
Cdh Tj = +7 °C	0.97	0.98
Pdh Tj = 12°C	3.75 kW	4.09 kW
COP Tj = 12°C	7.43	6.60
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	7.58 kW	7.40 kW
COP Tj = Tbiv	2.52	1.75
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.58 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.52	1.75
WTOL	35 °C	55 °C
Poff	13 W	13 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	3225 kWh	4255 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	177 %	135 %
Prated	8.78 kW	8.17 kW
SCOP	4.50	3.44
T _{biv}	-17 °C	-17 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	5.32 kW	5.44 kW
COP T _j = -7°C	4.00	2.84
C _{dh} T _j = -7 °C	0.90	0.90
P _{dh} T _j = +2°C	3.36 kW	3.30 kW
COP T _j = +2°C	5.10	4.25
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	3.73 kW	3.61 kW
COP T _j = +7°C	7.24	5.52
C _{dh} T _j = +7 °C	0.97	0.98
P _{dh} T _j = 12°C	4.03 kW	3.90 kW
COP T _j = 12°C	7.70	6.57
C _{dh} T _j = +12 °C	0.97	0.97
P _{dh} T _j = T _{biv}	7.62 kW	7.09 kW
COP T _j = T _{biv}	2.47	1.70
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	6.70 kW	5.95 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	2.19	1.35
WTOL	35 °C	55 °C
P _{off}	13 W	13 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.08 kW	2.22 kW
Annual energy consumption Q _{he}	4812 kWh	5852 kWh
P _{dh} T _j = -15°C (if TOL	7.10	7.28
COP T _j = -15°C (if TOL	2.77	1.99
C _{dh} T _j = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)
EN 14825 Warmer Climate		
	Low temperature	Medium temperature
η_s	272 %	185 %
Prated	8.57 kW	8.64 kW
SCOP	6.88	4.71
Tbiv	2 °C	2 °C
TOL	-22 °C	-22 °C
Pdh Tj = +2°C	8.57 kW	8.64 kW
COP Tj = +2°C	3.51	2.40
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.99 kW	5.93 kW
COP Tj = +7°C	6.41	4.14
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	4.14 kW	3.82 kW
COP Tj = 12°C	8.36	5.99
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	8.57 kW	8.64 kW
COP Tj = Tbiv	3.51	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.57 kW	8.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.51	2.40
WTOL	35 °C	55 °C
Poff	13 W	13 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1665 kWh	2451 kWh