

## Subtype Aquarena Split 9-12 kW T-CAP (H Series)

Certificate Holder	Panasonic Marketing Europe GmbH
Address	Hagenauer Strasse 43, Wiesbaden
ZIP	65203
City	Wiesbaden
Country	DE
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	Aquarena Split 9-12 kW T-CAP (H Series)
Registration number	011-1W0511
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	2.85 kg
Certification Date	09.11.2021
Testing basis	HP KEYMARK certification scheme rules rev. 9

## Model WH-ADC1216H6E5 / WH-UX09HE5

Model name	WH-ADC1216H6E5 / WH-UX09HE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %

Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-ADC1216H6E5C / WH-UX09HE5

Model name	WH-ADC1216H6E5C / WH-UX09HE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	92 %
COP	2.31
Heating up time	54 h:min
Standby power input	39.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	228 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %

Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-SXC09H3E5 / WH-UX09HE5

Model name	WH-SXC09H3E5 / WH-UX09HE5
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	n/a
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %
Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990

Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-ADC0916H9E8 / WH-UX09HE8

Model name	WH-ADC0916H9E8 / WH-UX09HE8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %



Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-ADC0916H9E8AN / WH-UX09HE8

Model name	WH-ADC0916H9E8AN / WH-UX09HE8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %

Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-ADC0916H9E8 / WH-UQ09HE8

Model name	WH-ADC0916H9E8 / WH-UQ09HE8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %

Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-ADC0916H9E8AN / WH-UQ09HE8

Model name	WH-ADC0916H9E8AN / WH-UQ09HE8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %

Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-ADC1216H6E5UK / WH-UX09HE5

Model name	WH-ADC1216H6E5UK / WH-UX09HE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %



Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-SXC09H3E8 / WH-UX09HE8

Model name	WH-SXC09H3E8 / WH-UX09HE8
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %
Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990

Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-SXC09H3E5 / WH-UQ09HE8

Model name	WH-SXC09H3E5 / WH-UQ09HE8
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	9.00 kW	9.00 kW
El input	1.86 kW	3.06 kW
COP	4.84	2.94

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %
Prated	9.00 kW	9.00 kW
SCOP	4.59	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.50 kW	7.70 kW
COP Tj = -7°C	2.75	2.11
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.70 kW	4.80 kW
COP Tj = +2°C	4.57	3.24
Cdh Tj = +2 °C	0.990	0.990

Pdh Tj = +7°C	5.00 kW	4.60 kW
COP Tj = +7°C	5.89	4.17
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.10 kW	5.50 kW
COP Tj = 12°C	7.67	5.74
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	9.00 kW	8.70 kW
COP Tj = Tbiv	2.71	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.00 kW	8.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	4049 kWh	5596 kWh

## Model WH-ADC1216H6E5 / WH-UX12HE5

Model name	WH-ADC1216H6E5 / WH-UX12HE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

### EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

### EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

### EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

### EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %

Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

## Model WH-ADC1216H6E5UK / WH-UX12HE5

Model name	WH-ADC1216H6E5UK / WH-UX12HE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %



Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

## Model WH-ADC1216H6E5C / WH-UX12HE5

Model name	WH-ADC1216H6E5C / WH-UX12HE5
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	92 %
COP	2.31
Heating up time	0:54 h:min
Standby power input	39.0 W
Reference hot water temperature	53.1 °C
Mixed water at 40°C	228 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %

Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

## Model WH-ADC0916H9E8 / WH-UQ12HE8

Model name	WH-ADC0916H9E8 / WH-UQ12HE8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %

Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

## Model WH-ADC0916H9E8AN / WH-UQ12HE8

Model name	WH-ADC0916H9E8AN / WH-UQ12HE8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %

Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

## Model WH-SXC12H6E5 / WH-UX12HE5

Model name	WH-SXC12H6E5 / WH-UX12HE5
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990



Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

## Model WH-SXC12H9E8 / WH-UX12HE8

Model name	WH-SXC12H9E8 / WH-UX12HE8
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990

Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

## Model WH-ADC0916H9E8 / WH-UX12HE8

Model name	WH-ADC0916H9E8 / WH-UX12HE8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %

Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

## Model WH-ADC0916H9E8AN / WH-UX12HE8

Model name	WH-ADC0916H9E8AN / WH-UX12HE8
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 16147 | Average Climate

Declared load profile	L
Efficiency $\eta_{DHW}$	95 %
COP	2.37
Heating up time	0:58 h:min
Standby power input	42.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	256 l

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %

Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh

## Model WH-SQC12H9E8 / WH-UQ12HE8

Model name	WH-SQC12H9E8 / WH-UQ12HE8
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	3x400V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	12.00 kW	12.00 kW
El input	2.53 kW	4.16 kW
COP	4.74	2.88

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	170 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.32	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.70 kW	10.80 kW
COP Tj = -7°C	2.84	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.96	3.19
Cdh Tj = +2 °C	0.990	0.990



Pdh Tj = +7°C	5.10 kW	4.70 kW
COP Tj = +7°C	5.93	4.38
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	7.88	5.89
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	12.00 kW	11.70 kW
COP Tj = Tbiv	2.56	1.95
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.00 kW	11.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	33 W	33 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.30 kW
Annual energy consumption Qhe	5745 kWh	7466 kWh