

Subtype AquaMaster Inverter AQ90I-1

Certificate Holder	Master Therm tepelna cerpadla s.r.o.
Address	Vaclavske namesti 819/43
ZIP	110 00
City	Praha
Country	CZ
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
Subtype title	AquaMaster Inverter AQ90I-1
Registration number	037-0132-23
Heat Pump Type	Brine/Water
Refrigerant	R410A
Mass of Refrigerant	3.6 kg
Certification Date	30.08.2023
Testing basis	HP Keymark scheme rules rev. no. 10
Testing laboratory	SZU Brno, CZ

Model AquaMaster Inverter AQ90I-1

Model name	AquaMaster Inverter AQ90I-1
Application	Heating (medium temp)
Units	Indoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	Yes

Brine/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	31.29 kW	29.44 kW
El input	6.87 kW	9.98 kW
COP	4.55	2.95

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	188 %	150 %
Prated	43.68 kW	42.23 kW
SCOP	4.90	3.96
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	39.07 kW	38.71 kW
COP Tj = -7°C	3.82	2.96
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	23.70 kW	24.34 kW
COP Tj = +2°C	4.84	3.94
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	15.49 kW	15.37 kW
COP Tj = +7°C	5.58	4.62
Cdh Tj = +7 °C	0.900	0.900

Pdh Tj = 12°C	6.97 kW	6.80 kW
COP Tj = 12°C	5.96	4.77
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	43.68 kW	42.23 kW
COP Tj = Tbiv	3.56	2.60
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	43.68 kW	42.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.56	2.60
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	26 W	26 W
PSB	26 W	26 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	kW	kW
Annual energy consumption Qhe	18408 kWh	22038 kWh