

Subtype X-Force 8 kW

| | |
|---------------------|---|
| Certificate Holder | INVENTOR A.G. SINGLE MEMBER ELECTRIC APPLIANCES S.A. |
| Address | 2 Thoukididou str. & 24th km National Road Athens - Lamia |
| ZIP | 14565 |
| City | Agios Stefanos |
| Country | GR |
| Certification Body | BRE Global Limited |
| Subtype title | X-Force 8 kW |
| Registration number | 041-K014-05 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R32 |
| Mass of Refrigerant | 1.3 kg |
| Certification Date | 19.12.2022 |
| Testing basis | Heat Pump Keymark Scheme Rules Rev 09 |
| Testing laboratory | TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN |

Model XFM*08S*

| | |
|-------------------------------------|-----------------------|
| Model name | XFM*08S* |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water
EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

| | |
|-------------------------------|--------|
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 7.99 kW | 7.59 kW |
| El input | 1.89 kW | 3.16 kW |
| COP | 4.24 | 2.40 |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 59 dB(A) | 60 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 175 % | 125 % |
| Prated | 7.80 kW | 6.69 kW |
| SCOP | 4.46 | 3.21 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 6.88 kW | 5.92 kW |
| COP Tj = -7°C | 2.49 | 1.85 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 4.21 kW | 3.92 kW |
| COP Tj = +2°C | 4.44 | 3.11 |
| Cdh Tj = +2 °C | 0.990 | 0.990 |
| Pdh Tj = +7°C | 3.91 kW | 2.99 kW |

| | | |
|---|-------------|-------------|
| COP Tj = +7°C | 6.00 | 4.42 |
| Cdh Tj = +7 °C | 0.990 | 0.990 |
| Pdh Tj = 12°C | 3.27 kW | 3.60 kW |
| COP Tj = 12°C | 8.32 | 6.14 |
| Cdh Tj = +12 °C | 0.990 | 0.990 |
| Pdh Tj = Tbiv | 6.88 kW | 5.92 kW |
| COP Tj = Tbiv | 2.49 | 1.85 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 6.27 kW | 5.37 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.08 | 1.50 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 65 °C | 65 °C |
| Poff | 7 W | 7 W |
| PTO | 19 W | 19 W |
| PSB | 7 W | 7 W |
| PCK | 17 W | 17 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.51 kW | 1.33 kW |
| Annual energy consumption Qhe | 3607 kWh | 4312 kWh |