

Subtype DC Inverter Heat Pump R290-17T

| | |
|---------------------|--|
| Certificate Holder | ECO Engineering 2050 GmbH |
| Address | Gewerbepark 1, |
| ZIP | 4133 |
| City | Niederkappel |
| Country | AT |
| Certification Body | BRE Global Limited |
| Subtype title | DC Inverter Heat Pump R290-17T |
| Registration number | 041-K082-04 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R290 |
| Mass of Refrigerant | 1.4 kg |
| Certification Date | 20.02.2024 |
| Testing basis | Heat Pump KEYMARK Scheme Rules Rev 13 |
| Testing laboratory | TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN |

Model Easypell EPA17T

| | |
|-------------------------------------|-----------------------|
| Model name | Easypell EPA17T |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 3x400V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow passed

| | |
|-------------------------------|--------|
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 12.78 kW | 12.25 kW |
| El input | 2.76 kW | 3.88 kW |
| COP | 4.63 | 3.16 |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 60 dB(A) | 62 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 185 % | 139 % |
| Prated | 14.05 kW | 13.47 kW |
| SCOP | 4.69 | 3.55 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 12.43 kW | 11.91 kW |
| COP Tj = -7°C | 3.34 | 2.38 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 7.57 kW | 7.29 kW |
| COP Tj = +2°C | 4.52 | 3.49 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = +7°C | 8.14 kW | 7.66 kW |

| | | |
|---|-------------|-------------|
| COP Tj = +7°C | 6.38 | 4.73 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 8.98 kW | 8.89 kW |
| COP Tj = 12°C | 8.11 | 6.50 |
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 12.43 kW | 11.91 kW |
| COP Tj = Tbiv | 3.34 | 2.38 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 14.01 kW | 13.29 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.76 | 2.08 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 60 °C | 60 °C |
| Poff | 13 W | 13 W |
| PTO | 39 W | 39 W |
| PSB | 13 W | 13 W |
| PCK | 54 W | 54 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.04 kW | 0.18 kW |
| Annual energy consumption Qhe | 6189 kWh | 7844 kWh |