

Subtype KHA KHC 08 / 10

Certificate Holder	Klima-Therm Sp. z o.o
Address	Ostrobramska 101a
ZIP	04-041
City	Warszawa
Country	PL
Certification Body	BRE Global Limited
Subtype title	KHA KHC 08 / 10
Registration number	041-K016-02
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.65 kg
Certification Date	22.06.2021
Testing basis	Heat Pump Keymark Scheme Rules Rev 08
Testing laboratory	TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN

Model KHA-08RY... + KMK...

Model name	KHA-08RY... + KMK...
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.30 kW	7.50 kW
El input	1.60 kW	2.36 kW
COP	5.20	3.18

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	205 %	132 %
Prated	8.12 kW	6.60 kW
SCOP	5.21	3.36
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.19 kW	5.84 kW
COP Tj = -7°C	3.35	2.16
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.65 kW	3.76 kW
COP Tj = +2°C	5.09	3.30
Cdh Tj = +2 °C	0.90	0.90

Pdh Tj = +7°C	2.90 kW	2.43 kW
COP Tj = +7°C	6.82	4.34
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.63 kW	1.40 kW
COP Tj = 12°C	8.35	5.33
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.19 kW	5.84 kW
COP Tj = Tbiv	3.35	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.45 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	1.84
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.68 kW	1.69 kW
Annual energy consumption Qhe	3223 kWh	4056 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	170 %	112 %
Prated	6.98 kW	5.78 kW
SCOP	4.32	2.88
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.46 kW	3.86 kW
COP Tj = -7°C	3.66	2.48
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.70 kW	2.21 kW
COP Tj = +2°C	5.20	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.66 kW	1.44 kW
COP Tj = +7°C	6.53	4.11
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.66 kW	1.47 kW
COP Tj = 12°C	7.96	5.92
Cdh Tj = +12 °C	0.90	0.90

Pdh Tj = Tbiv	5.69 kW	4.71 kW
COP Tj = Tbiv	2.83	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.06 kW	2.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.95	1.22
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.91 kW	2.99 kW
Annual energy consumption Qhe	3978 kWh	4950 kWh
Pdh Tj = -15°C (if TOL	5.69	4.71
COP Tj = -15°C (if TOL	2.83	1.90
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	273 %	177 %
Prated	8.12 kW	8.37 kW
SCOP	6.99	4.50
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.57 kW	7.55 kW
COP Tj = +2°C	3.98	2.59
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.22 kW	5.38 kW
COP Tj = +7°C	6.26	4.01
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.45 kW	2.32 kW
COP Tj = 12°C	9.02	5.55
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.22 kW	5.38 kW
COP Tj = Tbiv	6.26	4.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	7.55 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.98	2.59

$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$

WTOL	65 °C	65 °C
P _{off}	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.55 kW	0.82 kW
Annual energy consumption Q _{he}	1569 kWh	2485 kWh

Model KHA-10RY... + KMK...

Model name	KHA-10RY... + KMK...
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.00 kW	9.50 kW
El input	2.00 kW	3.06 kW
COP	5.00	3.10

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	205 %	137 %
Prated	9.17 kW	7.67 kW
SCOP	5.19	3.49
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.11 kW	6.78 kW
COP Tj = -7°C	3.23	2.24
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.18 kW	4.29 kW
COP Tj = +2°C	5.01	3.42
Cdh Tj = +2 °C	0.90	0.90

Pdh Tj = +7°C	3.32 kW	2.77 kW
COP Tj = +7°C	7.08	4.52
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.65 kW	1.58 kW
COP Tj = 12°C	8.58	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.11 kW	6.78 kW
COP Tj = Tbiv	3.23	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.40 kW	5.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.96	1.83
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.76 kW	2.28 kW
Annual energy consumption Qhe	3647 kWh	4539 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	170 %	116 %
Prated	7.75 kW	6.71 kW
SCOP	4.32	2.99
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.83 kW	4.27 kW
COP Tj = -7°C	3.60	2.54
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.94 kW	2.57 kW
COP Tj = +2°C	5.26	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.92 kW	1.66 kW
COP Tj = +7°C	7.08	4.37
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.66 kW	1.48 kW
COP Tj = 12°C	7.96	5.96
Cdh Tj = +12 °C	0.90	0.90

Pdh Tj = Tbiv	6.32 kW	5.48 kW
COP Tj = Tbiv	2.64	2.00
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.63 kW	2.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.22
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.13 kW	3.91 kW
Annual energy consumption Qhe	4424 kWh	5540 kWh
Pdh Tj = -15°C (if TOL	6.32	5.48
COP Tj = -15°C (if TOL	2.64	2.00
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	279 %	180 %
Prated	8.58 kW	8.63 kW
SCOP	7.12	4.58
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.44 kW	8.06 kW
COP Tj = +2°C	3.84	2.59
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.52 kW	5.55 kW
COP Tj = +7°C	6.18	4.10
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.62 kW	2.53 kW
COP Tj = 12°C	9.04	5.82
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.52 kW	5.55 kW
COP Tj = Tbiv	6.18	4.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.44 kW	8.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.84	2.61
WTOL	65 °C	65 °C

Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.14 kW	0.48 kW
Annual energy consumption Qhe	1628 kWh	2516 kWh

Model KHC-08RY...

Model name	KHC-08RY...
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.40 kW	7.50 kW
El input	1.63 kW	2.36 kW
COP	5.15	3.18

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	205 %	132 %
Prated	8.12 kW	6.60 kW
SCOP	5.21	3.36
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.19 kW	5.84 kW
COP Tj = -7°C	3.35	2.16
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.65 kW	3.76 kW
COP Tj = +2°C	5.09	3.30
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.90 kW	2.43 kW

COP Tj = +7°C	6.82	4.34
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.63 kW	1.40 kW
COP Tj = 12°C	8.35	5.33
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.19 kW	5.84 kW
COP Tj = Tbiv	3.35	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.45 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	1.84
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.68 kW	1.69 kW
Annual energy consumption Qhe	3223 kWh	4056 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	170 %	112 %
Prated	6.98 kW	5.78 kW
SCOP	4.32	2.88
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.46 kW	3.86 kW
COP Tj = -7°C	3.66	2.48
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.70 kW	2.21 kW
COP Tj = +2°C	5.20	3.35
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.66 kW	1.44 kW
COP Tj = +7°C	6.53	4.11
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.66 kW	1.47 kW
COP Tj = 12°C	7.96	5.92
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.69 kW	4.71 kW
COP Tj = Tbiv	2.83	1.90

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.06 kW	2.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.95	1.22
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.91 kW	2.99 kW
Annual energy consumption Qhe	3978 kWh	4950 kWh
Pdh Tj = -15°C (if TOL	5.69	4.71
COP Tj = -15°C (if TOL	2.83	1.90
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	273 %	177 %
Prated	8.12 kW	8.37 kW
SCOP	6.99	4.50
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.57 kW	7.55 kW
COP Tj = +2°C	3.98	2.59
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.22 kW	5.38 kW
COP Tj = +7°C	6.26	4.01
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.45 kW	2.32 kW
COP Tj = 12°C	9.02	5.55
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.22 kW	5.38 kW
COP Tj = Tbiv	6.26	4.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	7.55 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.98	2.59
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	14 W	14 W

PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.55 kW	0.82 kW
Annual energy consumption Q _{he}	1569 kWh	2485 kWh

Model KHC-10RY...

Model name	KHC-10RY...
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.00 kW	9.50 kW
El input	2.02 kW	3.06 kW
COP	4.95	3.10

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	205 %	137 %
Prated	9.17 kW	7.67 kW
SCOP	5.19	3.49
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.11 kW	6.78 kW
COP Tj = -7°C	3.23	2.24
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.18 kW	4.29 kW
COP Tj = +2°C	5.01	3.42
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.32 kW	2.77 kW

COP Tj = +7°C	7.08	4.52
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.65 kW	1.58 kW
COP Tj = 12°C	8.58	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.11 kW	6.78 kW
COP Tj = Tbiv	3.23	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.40 kW	5.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.96	1.83
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.76 kW	2.28 kW
Annual energy consumption Qhe	3647 kWh	4539 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	170 %	116 %
Prated	7.75 kW	6.71 kW
SCOP	4.32	2.99
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.83 kW	4.27 kW
COP Tj = -7°C	3.60	2.54
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.94 kW	2.57 kW
COP Tj = +2°C	5.26	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.92 kW	1.66 kW
COP Tj = +7°C	7.08	4.37
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.66 kW	1.48 kW
COP Tj = 12°C	7.96	5.96
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.32 kW	5.48 kW
COP Tj = Tbiv	2.64	2.00

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.63 kW	2.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.22
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.13 kW	3.91 kW
Annual energy consumption Qhe	4424 kWh	5540 kWh
Pdh Tj = -15°C (if TOL	6.32	5.48
COP Tj = -15°C (if TOL	2.64	2.00
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	279 %	180 %
Prated	8.58 kW	8.63 kW
SCOP	7.12	4.58
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.44 kW	8.06 kW
COP Tj = +2°C	3.84	2.59
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.52 kW	5.55 kW
COP Tj = +7°C	6.18	4.10
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.62 kW	2.53 kW
COP Tj = 12°C	9.04	5.82
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.52 kW	5.55 kW
COP Tj = Tbiv	6.18	4.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.44 kW	8.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.84	2.61
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.14 kW	0.48 kW
Annual energy consumption Q _{he}	1628 kWh	2516 kWh