

Subtype Buderus Logatherm WLW156-4/6 MB

Certificate Holder	Bosch Thermotechnik GmbH (Buderus)
Address	Sophienstraße 30-32
ZIP	35576
City	Wetzlar
Country	DE
Certification Body	BRE Global Limited
Subtype title	Buderus Logatherm WLW156-4/6 MB
Registration number	041-K045-01
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.5 kg
Certification Date	13.06.2023
Testing basis	Heat Pump Keymark Scheme Rules Rev 11
Testing laboratory	TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN

Model WLW156-4 MB AR

Model name	WLW156-4 MB AR
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	4.20 kW	4.40 kW
El input	0.82 kW	1.49 kW
COP	5.10	2.95

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	191 %	130 %
Prated	5.52 kW	4.40 kW
SCOP	4.85	3.31
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.88 kW	3.89 kW
COP Tj = -7°C	3.19	2.17
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.06 kW	2.38 kW
COP Tj = +2°C	4.78	3.30
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.93 kW	2.95 kW

COP Tj = +7°C	6.13	4.41
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.48 kW	1.32 kW
COP Tj = 12°C	8.05	5.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.88 kW	3.89 kW
COP Tj = Tbiv	3.19	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.42 kW	3.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	1.91
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.11 kW	0.98 kW
Annual energy consumption Qhe	2351 kWh	2744 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	159 %	102 %
Prated	4.57 kW	3.37 kW
SCOP	4.06	2.63
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	2.76 kW	2.14 kW
COP Tj = -7°C	3.49	2.32
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	1.77 kW	1.28 kW
COP Tj = +2°C	4.95	2.99
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.17 kW	1.01 kW
COP Tj = +7°C	5.53	3.86
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.43 kW	1.36 kW
COP Tj = 12°C	7.67	6.28
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.72 kW	2.75 kW
COP Tj = Tbiv	2.57	1.74

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	2.80 kW	1.64 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.02
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.76 kW	1.73 kW
Annual energy consumption Qhe	2770 kWh	3159 kWh
Pdh Tj = -15°C (if TOL	3.72	2.75
COP Tj = -15°C (if TOL	2.57	1.74
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	254 %	162 %
Prated	5.54 kW	5.02 kW
SCOP	6.52	4.14
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.35 kW	4.84 kW
COP Tj = +2°C	3.94	2.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.56 kW	3.23 kW
COP Tj = +7°C	5.92	3.68
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.64 kW	1.47 kW
COP Tj = 12°C	7.91	5.15
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.56 kW	3.23 kW
COP Tj = Tbiv	5.92	3.68
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.35 kW	4.84 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.94	2.51
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.19 kW	0.18 kW
Annual energy consumption Q _{he}	1152 kWh	1621 kWh

Model WLW156-6 MB AR

Model name	WLW156-6 MB AR
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.35 kW	6.00 kW
El input	1.28 kW	2.03 kW
COP	4.95	2.95

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	195 %	138 %
Prated	6.82 kW	5.70 kW
SCOP	4.95	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	6.03 kW	5.05 kW
COP Tj = -7°C	3.09	2.17
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.88 kW	3.12 kW
COP Tj = +2°C	4.85	3.51
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.40 kW	2.09 kW

COP Tj = +7°C	6.63	4.54
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.39 kW	1.28 kW
COP Tj = 12°C	7.83	5.59
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	6.03 kW	5.05 kW
COP Tj = Tbiv	3.09	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.36 kW	4.52 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	1.91
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.18 kW
Annual energy consumption Qhe	2846 kWh	3345 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
ηs	165 %	111 %
Prated	5.63 kW	4.26 kW
SCOP	4.21	2.85
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.42 kW	2.70 kW
COP Tj = -7°C	3.59	2.46
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	2.06 kW	1.61 kW
COP Tj = +2°C	5.21	3.36
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	1.47 kW	1.02 kW
COP Tj = +7°C	6.24	3.94
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.44 kW	1.37 kW
COP Tj = 12°C	7.66	6.35
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.60 kW	3.48 kW
COP Tj = Tbiv	2.53	1.86

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.48 kW	2.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.96	1.13
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.15 kW	2.16 kW
Annual energy consumption Qhe	3301 kWh	3681 kWh
Pdh Tj = -15°C (if TOL	4.60	3.48
COP Tj = -15°C (if TOL	2.53	1.86
Cdh Tj = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
ηs	258 %	165 %
Prated	6.12 kW	5.15 kW
SCOP	6.63	4.19
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.94 kW	5.03 kW
COP Tj = +2°C	3.91	2.48
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.93 kW	3.31 kW
COP Tj = +7°C	5.89	3.67
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.80 kW	1.60 kW
COP Tj = 12°C	8.20	5.29
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	3.93 kW	3.31 kW
COP Tj = Tbiv	5.89	3.67
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.94 kW	5.03 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.91	2.48
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.18 kW	0.12 kW
Annual energy consumption Q _{he}	1251 kWh	1640 kWh