

Subtype Sphera EVO 2.0 Tower 250L 4.1, 5.1

Certificate Holder	Clivet s.p.a.
Address	Via camp lonc 25 c.ap.
ZIP	I-32032
City	z.i. Villapaiera - Feltre (BL)
Country	IT
Certification Body	ICIM S.p.A.
Subtype title	Sphera EVO 2.0 Tower 250L 4.1, 5.1
Registration number	ICIM-PDC-000169
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.65 kg
Certification Date	10.06.2022
Testing basis	HP KEYMARK certification scheme rules rev. n. 9

Model SQKN-YEE 1 TC A 250 + MiSAN-YEE 1 S 4.1

Model name	SQKN-YEE 1 TC A 250 + MiSAN-YEE 1 S 4.1
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	123 %
COP	2.95
Heating up time	02:10 h:min
Standby power input	44.0 W
Reference hot water temperature	50.0 °C
Mixed water at 40°C	265 l

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.30 kW	7.50 kW
El input	1.56 kW	2.35 kW
COP	5.31	3.19

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	41 dB(A)
Sound power level outdoor	dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	210 %	146 %
Prated	8.08 kW	6.88 kW
SCOP	5.32	3.72
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.15 kW	6.09 kW
COP Tj = -7°C	3.30	2.27
Cdh Tj = -7 °C	0.900	0.900

Pdh Tj = +2°C	4.65 kW	3.94 kW
COP Tj = +2°C	5.17	3.56
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.91 kW	2.52 kW
COP Tj = +7°C	7.08	4.70
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.85 kW	1.72 kW
COP Tj = 12°C	9.46	9.71
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.15 kW	6.09 kW
COP Tj = Tbiv	3.30	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.42 kW	4.97 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.06	1.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.66 kW	1.91 kW
Annual energy consumption Qhe	3141 kWh	3824 kWh

Model SQKN-YEE 1 TC A 250 + MiSAN-YEE 1 S 5.1

Model name	SQKN-YEE 1 TC A 250 + MiSAN-YEE 1 S 5.1
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	XL
Efficiency η_{DHW}	123 %
COP	2.95
Heating up time	02:10 h:min
Standby power input	50.0 W
Reference hot water temperature	44.0 °C
Mixed water at 40°C	265 l

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.09 kW	9.60 kW
El input	2.01 kW	3.10 kW
COP	5.01	3.10

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	41 dB(A)
Sound power level outdoor	dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	208 %	143 %
Prated	9.55 kW	8.57 kW
SCOP	5.27	3.73
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.45 kW	7.58 kW
COP Tj = -7°C	3.18	2.02
Cdh Tj = -7 °C	0.900	0.900

Pdh Tj = +2°C	5.23 kW	4.44 kW
COP Tj = +2°C	5.03	3.63
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.47 kW	2.92 kW
COP Tj = +7°C	7.33	4.95
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	1.96 kW	1.71 kW
COP Tj = 12°C	9.94	6.56
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.45 kW	7.58 kW
COP Tj = Tbiv	3.18	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.38 kW	5.46 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.97	1.87
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	2.17 kW	3.11 kW
Annual energy consumption Qhe	3747 kWh	4749 kWh