

Subtype Alféa Excellia S 14

Certificate Holder	Groupe Atlantic
Address	Rue des Fondateurs BP 64
ZIP	59660
City	Merville
Country	FR
Certification Body	RISE CERT
Subtype title	Alféa Excellia S 14
Registration number	012-C700301
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.63 kg
Certification Date	20.05.2024
Testing basis	EN 14511:2022, EN 14825:2022, EN 16147:2017+A1:2022, EN 12102:2022
Testing laboratory	ACTA INDUSTRIE - Laboratoire Acoustique et Climatique

Model Alféa Excellia S 14

Model name	Alféa Excellia S 14
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.47 kW	10.09 kW
El input	3.36 kW	3.36 kW
COP	4.31	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	185 %	137 %
Prated	11.70 kW	11.40 kW
SCOP	4.71	3.51
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.40 kW	10.10 kW
COP Tj = -7°C	3.09	2.32
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	6.30 kW	6.10 kW
COP Tj = +2°C	4.61	3.41
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	4.50 kW	4.30 kW

COP Tj = +7°C	6.24	4.50
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	5.10 kW	4.90 kW
COP Tj = 12°C	7.67	5.97
Cdh Tj = +12 °C	0.970	0.980
Pdh Tj = Tbiv	10.40 kW	10.10 kW
COP Tj = Tbiv	3.09	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	9.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	2.06
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	21 W	18 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	1.90 kW
Annual energy consumption Qhe	5132 kWh	6717 kWh

Model Alféa Excellia S Duo 14

Model name	Alféa Excellia S Duo 14
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	116 %
COP	2.90
Heating up time	1:10 h:min
Standby power input	34.0 W
Reference hot water temperature	55.0 °C
Mixed water at 40°C	250 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.47 kW	10.09 kW
El input	3.36 kW	3.36 kW
COP	4.31	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	185 %	137 %
Prated	11.70 kW	11.40 kW

SCOP	4.71	3.51
Tbiv	-7 �C	-7 �C
TOL	-10 �C	-10 �C
Pdh Tj = -7�C	10.40 kW	10.10 kW
COP Tj = -7�C	3.09	2.32
Cdh Tj = -7 �C	0.990	1.000
Pdh Tj = +2�C	6.30 kW	6.10 kW
COP Tj = +2�C	4.61	3.41
Cdh Tj = +2 �C	0.980	0.990
Pdh Tj = +7�C	4.50 kW	4.30 kW
COP Tj = +7�C	6.24	4.50
Cdh Tj = +7 �C	0.970	0.980
Pdh Tj = 12�C	5.10 kW	4.90 kW
COP Tj = 12�C	7.67	5.97
Cdh Tj = +12 �C	0.970	0.980
Pdh Tj = Tbiv	10.40 kW	10.10 kW
COP Tj = Tbiv	3.09	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	9.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	2.06
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	60 �C	60 �C
Poff	14 W	14 W
PTO	21 W	18 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	1.90 kW
Annual energy consumption Qhe	5132 kWh	6717 kWh

Model Hysolina 14 - 23

Model name	Hysolina 14 - 23
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.47 kW	10.09 kW
El input	3.36 kW	3.36 kW
COP	4.31	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	186 %	138 %
Prated	11.70 kW	11.40 kW
SCOP	4.73	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.40 kW	10.10 kW
COP Tj = -7°C	3.09	2.32
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	6.30 kW	6.10 kW
COP Tj = +2°C	4.61	3.41
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	4.50 kW	4.30 kW

COP Tj = +7°C	6.24	4.50
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	5.10 kW	4.90 kW
COP Tj = 12°C	7.67	5.97
Cdh Tj = +12 °C	0.970	0.980
Pdh Tj = Tbiv	10.40 kW	10.10 kW
COP Tj = Tbiv	3.09	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	9.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	2.06
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	21 W	18 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	1.70 kW	1.90 kW
Annual energy consumption Qhe	5109 kWh	6692 kWh

Model Hysolina 14 - 29

Model name	Hysolina 14 - 29
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	14.47 kW	10.09 kW
El input	3.36 kW	3.36 kW
COP	4.31	3.00

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	36 dB(A)	36 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	186 %	138 %
Prated	11.70 kW	11.40 kW
SCOP	4.73	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.40 kW	10.10 kW
COP Tj = -7°C	3.09	2.32
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	6.30 kW	6.10 kW
COP Tj = +2°C	4.61	3.41
Cdh Tj = +2 °C	0.980	0.990
Pdh Tj = +7°C	4.50 kW	4.30 kW

COP Tj = +7°C	6.24	4.50
Cdh Tj = +7 °C	0.970	0.980
Pdh Tj = 12°C	5.10 kW	4.90 kW
COP Tj = 12°C	7.67	5.97
Cdh Tj = +12 °C	0.970	0.980
Pdh Tj = Tbiv	10.40 kW	10.10 kW
COP Tj = Tbiv	3.09	2.32
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.00 kW	9.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	2.06
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	60 °C	60 °C
Poff	14 W	14 W
PTO	21 W	18 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Gas	Gas
Supplementary Heater: PSUP	1.70 kW	1.90 kW
Annual energy consumption Qhe	5109 kWh	6692 kWh