

Subtype DVI AW-407-5

Certificate Holder	DVI Energi A/S
Address	
ZIP	
City	
Country	DK
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)
Subtype title	DVI AW-407-5
Registration number	037-0166-24
Heat Pump Type	Outdoor Air/Water
Refrigerant	R407c
Mass of Refrigerant	4 kg
Certification Date	09.05.2024
Testing basis	HP Keymark scheme rules rev. no. 12
Testing laboratory	SZU Brno, CZ

Model DVI AW-407-5

Model name	DVI AW-407-5
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.47 kW	5.72 kW
El input	1.39 kW	1.89 kW
COP	4.63	3.02

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	152 %	130 %
Prated	4.08 kW	3.90 kW
SCOP	4.00	3.31
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.61 kW	3.30 kW
COP Tj = -7°C	2.74	2.02
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	4.64 kW	4.65 kW
COP Tj = +2°C	3.81	3.18
Cdh Tj = +2 °C	1.000	0.999
Pdh Tj = +7°C	6.87 kW	6.35 kW
COP Tj = +7°C	5.33	4.57

Cdh Tj = +7 °C	1.000	0.999
Pdh Tj = 12°C	7.74 kW	7.82 kW
COP Tj = 12°C	6.01	5.86
Cdh Tj = +12 °C	1.000	1.000
Pdh Tj = Tbiv	3.61 kW	3.30 kW
COP Tj = Tbiv	2.74	2.02
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.57 kW	3.07 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	3 W	3 W
PTO	2 W	6 W
PSB	6 W	6 W
PCK	W	W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.48 kW	0.89 kW
Annual energy consumption Qhe	2106 kWh	2432 kWh