

Subtype SWH-100P, SWH-100PM

Certificate Holder	SINCLAIR Global Group s.r.o.
Address	Purkyňova 45
ZIP	61200
City	Brno
Country	CZ
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	SWH-100P, SWH-100PM
Registration number	011-1W0786
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)
Refrigerant	R290
Mass of Refrigerant	0.15 kg
Certification Date	28.05.2024
Testing basis	HP KEYMARK certification scheme rules V14

Model SWH-100P

Model name	SWH-100P
Application	n/a
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	No

Heat Pump for Domestic Hot Water (DHW)

EN 16147 | Operating test

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

EN 12102-2 | Average Climate

Sound power level indoor	54 dB(A)
--------------------------	----------

EN 16147 | Average Climate

Declared load profile	M
Efficiency η_{DHW}	111 %
COP	2.61
Heating up time	6:04 h:min
Standby power input	19.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	110 l

EN 12102-2 | Colder Climate

Sound power level indoor	54 dB(A)
--------------------------	----------

EN 16147 | Colder Climate

Declared load profile	M
Efficiency η_{DHW}	92 %
COP	2.22
Heating up time	7:10 h:min
Standby power input	20.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	108 l

EN 12102-2 | Warmer Climate

Sound power level indoor 54 dB(A)

EN 16147 | Warmer Climate

Declared load profile	M
Efficiency η_{DHW}	114 %
COP	2.74
Heating up time	5:14 h:min
Standby power input	16.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	108 l

Model SWH-100PM

Model name	SWH-100PM
Application	n/a
Units	Indoor
Climate zone (for heating)	Colder, Warmer, Warmer Climate, Colder Climate
Heat Source	Outdoor Air
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	n/a
Off-peak product	n/a

Heat Pump for Domestic Hot Water (DHW)

EN 16147 | Operating test

Temperature operating range	2
Safety devices checking test	2
Condensate draining	2

EN 12102-2 | Average Climate

Sound power level indoor	54 dB(A)
--------------------------	----------

EN 16147 | Average Climate

Declared load profile	M
Efficiency η_{DHW}	111 %
COP	2.61
Heating up time	6:04 h:min
Standby power input	19.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	110 l

EN 12102-2 | Colder Climate

Sound power level indoor	54 dB(A)
--------------------------	----------

EN 16147 | Colder Climate

Declared load profile	M
Efficiency η_{DHW}	92 %
COP	2.22
Heating up time	7:10 h:min
Standby power input	20.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	108 l

EN 12102-2 | Warmer Climate

Sound power level indoor 54 dB(A)

EN 16147 | Warmer Climate

Declared load profile	M
Efficiency η_{DHW}	114 %
COP	2.74
Heating up time	5:14 h:min
Standby power input	16.0 W
Reference hot water temperature	52.7 °C
Mixed water at 40°C	108 l