

Subtype LA 35TBS

| | |
|---------------------|--|
| Certificate Holder | Glen Dimplex Deutschland GmbH |
| Address | Am Goldenen Feld 18 |
| ZIP | D-95326 |
| City | Kulmbach |
| Country | DE |
| Certification Body | VDE Prüf- und Zertifizierungsinstitut GmbH |
| Subtype title | LA 35TBS |
| Registration number | 40054223 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R407c |
| Mass of Refrigerant | 5.6 kg |
| Certification Date | 28.02.2025 |
| Testing basis | DIN EN 14511-1:2023-08; EN 14511-1:2022 ;DIN EN 14511-2:2023-08; EN 14511-2:2022; DIN EN 14511-3:2023-12; EN 14511-3:2022; DIN EN 14511-4:2023-08; EN 14511-4:2022; DIN EN 14825:2023-10; EN 14825:2022; DIN EN 12102-1:2023-11; EN 12102-1:2022 |
| Testing laboratory | VDE Prüf- und Zertifizierungsinstitut GmbH, DE |

Model LA 35TBS

| | |
|-------------------------------------|-----------------------|
| Model name | LA 35TBS |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 3x400V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water**EN 14511-4 | Heating**

Shutting off the heat transfer medium flow passed

| | |
|-------------------------------|--------|
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 17.60 kW | 17.40 kW |
| EI input | 4.07 kW | 5.58 kW |
| COP | 4.33 | 3.11 |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 63 dB(A) | 63 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 152 % | 125 % |
| Prated | 20.70 kW | 20.70 kW |
| SCOP | 3.87 | 3.21 |
| Tbiv | -10 °C | -10 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 21.80 kW | 22.20 kW |
| COP Tj = -7°C | 3.02 | 2.36 |
| Cdh Tj = -7 °C | 1.000 | 1.000 |
| Pdh Tj = +2°C | 14.30 kW | 14.10 kW |
| COP Tj = +2°C | 3.88 | 3.22 |
| Cdh Tj = +2 °C | 0.990 | 1.000 |
| Pdh Tj = +7°C | 18.00 kW | 17.60 kW |
| COP Tj = +7°C | 4.79 | 3.95 |

| | | |
|---|-------------|-------------|
| Cdh Tj = +7 °C | 0.990 | 1.000 |
| Pdh Tj = 12°C | 21.90 kW | 21.30 kW |
| COP Tj = 12°C | 5.72 | 4.93 |
| Cdh Tj = +12 °C | 0.990 | 1.000 |
| Pdh Tj = Tbiv | 20.50 kW | 20.60 kW |
| COP Tj = Tbiv | 2.90 | 2.17 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 20.50 kW | 20.60 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.90 | 2.17 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 1.000 | 1.000 |
| WTOL | 60 °C | 60 °C |
| Poff | 20 W | 20 W |
| PTO | 20 W | 20 W |
| PSB | 20 W | 20 W |
| PCK | 88 W | 88 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.00 kW | 0.00 kW |
| Annual energy consumption Qhe | 11198 kWh | 13342 kWh |