

Subtype Beretta Tower Green M 8-10kW with 240L tank

Certificate Holder	Riello S.p.A.
Address	Via Ing. Pilade Riello 7
ZIP	37045
City	Legnago (VR)
Country	IT
Certification Body	BRE Global Limited
Subtype title	Beretta Tower Green M 8-10kW with 240L tank
Registration number	041-K019-37
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.65 kg
Certification Date	11.02.2025
Testing basis	Heat Pump Keymark Scheme Rules Rev 08

Model EXTERNAL UNIT HP R32/008 + HP IDU TOWER L*1/ 04-10

Model name	EXTERNAL UNIT HP R32/008 + HP IDU TOWER L*1/ 04-10
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	125 %
COP	3.02
Heating up time	1:38 h:min
Standby power input	23.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	200 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	107 %
COP	2.61
Heating up time	1:32 h:min
Standby power input	25.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	200 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	151 %
COP	3.66
Heating up time	1:30 h:min
Standby power input	21.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	200 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.30 kW	7.50 kW
El input	1.60 kW	2.36 kW
COP	5.20	3.18

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	205 %	132 %
Prated	8.12 kW	6.60 kW
SCOP	5.21	3.36
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.19 kW	5.84 kW
COP Tj = -7°C	3.35	2.16
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.65 kW	3.76 kW
COP Tj = +2°C	5.09	3.30
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.90 kW	2.43 kW
COP Tj = +7°C	6.82	4.34
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.63 kW	1.40 kW
COP Tj = 12°C	8.35	5.33
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.19 kW	5.84 kW
COP Tj = Tbiv	3.35	2.16
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.45 kW	4.91 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	1.84
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

Supplementary Heater: PSUP	1.68 kW	1.69 kW
Annual energy consumption Q _{he}	3223 kWh	4056 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	170 %	112 %
Prated	6.98 kW	5.78 kW
SCOP	4.32	2.88
T _{biv}	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	4.46 kW	3.86 kW
COP T _j = -7°C	3.66	2.48
C _{dh} T _j = -7 °C	0.90	0.90
P _{dh} T _j = +2°C	2.70 kW	2.21 kW
COP T _j = +2°C	5.20	3.35
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	1.66 kW	1.44 kW
COP T _j = +7°C	6.53	4.11
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	1.66 kW	1.47 kW
COP T _j = 12°C	7.96	5.92
C _{dh} T _j = +12 °C	0.90	0.90
P _{dh} T _j = T _{biv}	5.69 kW	4.71 kW
COP T _j = T _{biv}	2.83	1.90
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	4.06 kW	2.80 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	1.95	1.22
WTOL	65 °C	65 °C
P _{off}	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.91 kW	2.99 kW
Annual energy consumption Q _{he}	3978 kWh	4950 kWh
P _{dh} T _j = -15°C (if TOL	5.69	4.71
COP T _j = -15°C (if TOL	2.83	1.90
C _{dh} T _j = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	59 dB(A)	59 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	273 %	176 %
Prated	8.12 kW	7.56 kW
SCOP	6.99	4.47
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.57 kW	7.55 kW
COP Tj = +2°C	3.98	2.59
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.22 kW	4.86 kW
COP Tj = +7°C	6.26	3.92
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	2.45 kW	2.32 kW
COP Tj = 12°C	9.02	5.55
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.22 kW	4.86 kW
COP Tj = Tbiv	6.26	3.92
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	7.55 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.98	2.59
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.55 kW	0.01 kW
Annual energy consumption Qhe	1569 kWh	2259 kWh

Model EXTERNAL UNIT HP R32/010 + HP IDU TOWER L*1/ 04-10

Model name	EXTERNAL UNIT HP R32/010 + HP IDU TOWER L*1/ 04-10
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	Warmer Climate, Colder Climate
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	125 %
COP	3.02
Heating up time	1:38 h:min
Standby power input	23.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	200 l

EN 16147 | Colder Climate

Declared load profile	L
Efficiency η_{DHW}	107 %
COP	2.61
Heating up time	1:31 h:min
Standby power input	25.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	200 l

EN 16147 | Warmer Climate

Declared load profile	L
Efficiency η_{DHW}	151 %
COP	3.66
Heating up time	1:30 h:min
Standby power input	21.0 W
Reference hot water temperature	47.0 °C
Mixed water at 40°C	200 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure passed

Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.00 kW	9.50 kW
El input	2.00 kW	3.06 kW
COP	5.00	3.10

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	205 %	137 %
Prated	9.17 kW	7.67 kW
SCOP	5.19	3.49
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.11 kW	6.78 kW
COP Tj = -7°C	3.23	2.24
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.18 kW	4.29 kW
COP Tj = +2°C	5.01	3.42
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.32 kW	2.77 kW
COP Tj = +7°C	7.08	4.52
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.65 kW	1.58 kW
COP Tj = 12°C	8.58	5.68
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.11 kW	6.78 kW
COP Tj = Tbiv	3.23	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.40 kW	5.39 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.96	1.83
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

Supplementary Heater: PSUP	1.76 kW	2.28 kW
Annual energy consumption Q _{he}	3647 kWh	4539 kWh

EN 12102-1 | Colder Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Colder Climate

	Low temperature	Medium temperature
η_s	170 %	116 %
Prated	7.75 kW	6.71 kW
SCOP	4.32	2.99
T _{biv}	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	4.83 kW	4.27 kW
COP T _j = -7°C	3.60	2.54
C _{dh} T _j = -7 °C	0.90	0.90
P _{dh} T _j = +2°C	2.94 kW	2.57 kW
COP T _j = +2°C	5.26	3.51
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	1.92 kW	1.66 kW
COP T _j = +7°C	7.08	4.37
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	1.66 kW	1.48 kW
COP T _j = 12°C	7.96	5.96
C _{dh} T _j = +12 °C	0.90	0.90
P _{dh} T _j = T _{biv}	6.32 kW	5.48 kW
COP T _j = T _{biv}	2.64	2.00
P _{dh} T _j = TOL or P _{dh} T _j = T _{designh} if TOL < T _{designh}	4.63 kW	2.80 kW
COP T _j = TOL or COP T _j = T _{designh} if TOL < T _{designh}	1.97	1.22
WTOL	65 °C	65 °C
P _{off}	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.13 kW	3.91 kW
Annual energy consumption Q _{he}	4424 kWh	5540 kWh
P _{dh} T _j = -15°C (if TOL	6.32	5.48
COP T _j = -15°C (if TOL	2.64	2.00
C _{dh} T _j = -15 °C	0.90	0.90

EN 12102-1 | Warmer Climate

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825 | Warmer Climate

	Low temperature	Medium temperature
η_s	279 %	180 %
Prated	8.58 kW	8.63 kW
SCOP	7.12	4.58
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	8.44 kW	8.06 kW
COP Tj = +2°C	3.84	2.59
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.52 kW	5.55 kW
COP Tj = +7°C	6.18	4.10
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	2.62 kW	2.53 kW
COP Tj = 12°C	9.04	5.82
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.52 kW	5.55 kW
COP Tj = Tbiv	6.18	4.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.44 kW	8.16 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.84	2.61
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.14 kW	0.48 kW
Annual energy consumption Qhe	1628 kWh	2516 kWh