

Subtype BoxAir Inverter BA26IS-1

| | |
|---------------------|---|
| Certificate Holder | Master Therm tepelna cerpadla s.r.o. |
| Address | Vaclavske namesti 819/43 |
| ZIP | 110 00 |
| City | Praha |
| Country | CZ |
| Certification Body | SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise) |
| Subtype title | BoxAir Inverter BA26IS-1 |
| Registration number | 037-0069-21 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R410A |
| Mass of Refrigerant | 2.3 kg |
| Certification Date | 26.01.2021 |
| Testing basis | HP Keymark scheme rules rev. no. 7 |
| Testing laboratory | SZU Brno, CZ |

Model BoxAir Inverter BA26IS-1

| | |
|-------------------------------------|--------------------------|
| Model name | BoxAir Inverter BA26IS-1 |
| Application | Heating (medium temp) |
| Units | Indoor, Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

| | |
|-------------------------------|--------|
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 8.10 kW | 7.28 kW |
| El input | 1.75 kW | 2.46 kW |
| COP | 4.63 | 2.96 |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 48 dB(A) | 48 dB(A) |
| Sound power level outdoor | 55 dB(A) | 55 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 168 % | 126 % |
| Prated | 6.51 kW | 6.33 kW |
| SCOP | 4.29 | 3.24 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 5.76 kW | 5.60 kW |
| COP Tj = -7°C | 2.59 | 1.94 |
| Cdh Tj = -7 °C | 0.90 | 0.90 |
| Pdh Tj = +2°C | 3.72 kW | 3.50 kW |
| COP Tj = +2°C | 3.92 | 3.02 |
| Cdh Tj = +2 °C | 0.90 | 0.90 |

| | | |
|---|-------------|-------------|
| Pdh Tj = +7°C | 2.42 kW | 2.33 kW |
| COP Tj = +7°C | 6.53 | 4.69 |
| Cdh Tj = +7 °C | 0.90 | 0.90 |
| Pdh Tj = 12°C | 2.74 kW | 2.78 kW |
| COP Tj = 12°C | 7.82 | 5.93 |
| Cdh Tj = +12 °C | 0.95 | 0.96 |
| Pdh Tj = Tbiv | 5.76 kW | 5.60 kW |
| COP Tj = Tbiv | 2.59 | 1.94 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 5.88 kW | 5.66 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.52 | 1.82 |
| WTOL | 60 °C | 60 °C |
| Poff | 18 W | 18 W |
| PTO | 17 W | 17 W |
| PSB | 18 W | 18 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.64 kW | 0.67 kW |
| Annual energy consumption Qhe | 3139 kWh | 4039 kWh |