

Subtype FUJITSU Waterstage Super High Power 15 3-phases

Certificate Holder	Groupe Atlantic
Address	Rue des Fondateurs BP 64
ZIP	59660
City	Merville
Country	FR
Certification Body	RISE CERT
Subtype title	FUJITSU Waterstage Super High Power 15 3-phases
Registration number	012-C700309
Heat Pump Type	Outdoor Air/Water
Refrigerant	R410A
Mass of Refrigerant	3.8 kg
Certification Date	20.05.2024
Testing basis	EN 14511:2013, EN 14825:2016, EN 16147:2017, EN 12102:2013
Testing laboratory	RISE Research Institutes of Sweden

Model FUJITSU Waterstage Super High Power 15 3-phases (WOYK150LJL/WSYK170DJ9)

Model name	FUJITSU Waterstage Super High Power 15 3-phases (WOYK150LJL/WSYK170DJ9)
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	15.10 kW	13.46 kW
El input	3.48 kW	4.75 kW
COP	4.34	2.83

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	130 %
Prated	17.40 kW	16.00 kW
SCOP	4.18	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	15.40 kW	14.20 kW
COP Tj = -7°C	2.90	2.12
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	9.40 kW	8.60 kW
COP Tj = +2°C	4.19	3.30
Cdh Tj = +2 °C	0.960	0.980

Pdh Tj = +7°C	6.70 kW	6.40 kW
COP Tj = +7°C	5.13	4.21
Cdh Tj = +7 °C	0.930	0.970
Pdh Tj = 12°C	8.00 kW	7.60 kW
COP Tj = 12°C	6.83	6.02
Cdh Tj = +12 °C	0.920	0.970
Pdh Tj = Tbiv	15.40 kW	14.20 kW
COP Tj = Tbiv	2.90	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.980	0.970
WTOL	60 °C	60 °C
Poff	16 W	16 W
PTO	96 W	43 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.70 kW	2.70 kW
Annual energy consumption Qhe	8606 kWh	9915 kWh

Model FUJITSU Waterstage Super High Power 15 3-phases Integrated DHW

(WOYK150LJL/WGYK170DJ9)

Model name	FUJITSU Waterstage Super High Power 15 3-phases Integrated DHW (WOYK150LJL/WGYK170DJ9)
Application	Heating + DHW + low temp
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x400V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 16147 | Average Climate

Declared load profile	L
Efficiency η_{DHW}	109 %
COP	2.56
Heating up time	0:54 h:min
Standby power input	48.0 W
Reference hot water temperature	54.2 °C
Mixed water at 40°C	250 l

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	15.10 kW	13.46 kW
El input	3.48 kW	4.75 kW
COP	4.34	2.83

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	164 %	130 %
Prated	17.40 kW	16.00 kW

SCOP	4.18	3.33
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	15.40 kW	14.20 kW
COP Tj = -7°C	2.90	2.12
Cdh Tj = -7 °C	0.980	0.990
Pdh Tj = +2°C	9.40 kW	8.60 kW
COP Tj = +2°C	4.19	3.30
Cdh Tj = +2 °C	0.960	0.980
Pdh Tj = +7°C	6.70 kW	6.40 kW
COP Tj = +7°C	5.13	4.21
Cdh Tj = +7 °C	0.930	0.970
Pdh Tj = 12°C	8.00 kW	7.60 kW
COP Tj = 12°C	6.83	6.02
Cdh Tj = +12 °C	0.920	0.970
Pdh Tj = Tbiv	15.40 kW	14.20 kW
COP Tj = Tbiv	2.90	2.12
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	14.70 kW	13.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.62	1.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.980	0.970
WTOL	60 °C	60 °C
Poff	16 W	16 W
PTO	96 W	43 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.70 kW	2.70 kW
Annual energy consumption Qhe	8606 kWh	9915 kWh