

Subtype Assure Mono 5 7 9

Certificate Holder	BAXI Potterton Myson
Address	Unit F 5&6, Calmount Park, Ballymount
ZIP	Dublin 12
City	Dublin
Country	IE
Certification Body	ICIM S.p.A.
Subtype title	Assure Mono 5 7 9
Registration number	ICIM-PDC-000083-00
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	2 kg
Certification Date	25.06.2020
Testing basis	HP KEYMARK certification scheme rules rev. 7

Model Assure Mono 5		
Model name	Assure Mono 5	
Application	Heating (medium temp)	
Units	Outdoor	
Climate zone (for heating)	n/a	
Cooling mode application (optional)	n/a	
Any additional heat sources	n/a	
General data		
Power supply	1x230V 50Hz	
Off-peak product	n/a	
Outdoor Air/Water		
EN 14511-4 Heating		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
EN 14511-2 Heating		
	Low temperature	Medium temperature
Heat output	4.65 kW	4.65 kW
El input	0.93 kW	1.77 kW
COP	5.00	2.63
EN 12102-1 Average Climate		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)
EN 14825 Average Climate		
	Low temperature	Medium temperature
ηs	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.83 kW
COP Tj = -7°C	2.91	1.97
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.64 kW	3.68 kW
COP Tj = +2°C	4.38	3.22
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.42 kW	2.47 kW
COP Tj = +7°C	5.89	4.21

Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.03 kW	1.26 kW
COP Tj = 12°C	5.89	4.91
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.88 kW	5.83 kW
COP Tj = Tbiv	2.91	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.62 kW	5.86 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.62
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	9 W	9 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	3071 kWh	4203 kWh

Model Assure Mono 7

Model name	Assure Mono 7
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	6.65 kW	6.80 kW
El input	1.35 kW	2.42 kW
COP	4.94	2.81

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	176 %	127 %
Prated	7.00 kW	7.00 kW
SCOP	4.47	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.88 kW	5.83 kW
COP Tj = -7°C	2.91	1.97
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	3.64 kW	3.68 kW
COP Tj = +2°C	4.38	3.22
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.42 kW	2.47 kW
COP Tj = +7°C	5.89	4.21

Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.03 kW	1.26 kW
COP Tj = 12°C	5.89	4.91
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.88 kW	5.83 kW
COP Tj = Tbiv	2.91	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.62 kW	5.86 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.63	1.62
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	6 W	6 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.70 kW
Annual energy consumption Qhe	3701 kWh	4203 kWh

Model Assure Mono 9

Model name	Assure Mono 9
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.60 kW	8.60 kW
El input	1.87 kW	3.12 kW
COP	4.60	2.75

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	67 dB(A)	67 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	177 %	126 %
Prated	8.00 kW	7.00 kW
SCOP	4.51	3.22
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.42 kW	6.58 kW
COP Tj = -7°C	2.80	1.87
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.83 kW	4.25 kW
COP Tj = +2°C	4.33	3.19
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.20 kW	2.80 kW
COP Tj = +7°C	6.20	4.38

Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	1.55 kW	1.27 kW
COP Tj = 12°C	7.61	5.04
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.42 kW	6.58 kW
COP Tj = Tbiv	2.80	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.64 kW	5.53 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.54	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	9 W	9 W
PTO	10 W	10 W
PSB	9 W	9 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.80 kW	1.80 kW
Annual energy consumption Qhe	3844 kWh	4770 kWh