

Subtype R290 Monobloc 08/10 kW

Certificate Holder	Qingdao Haier Air Conditioner Electric Co., Ltd.
Address	Haier Development Zone Industrial Park, Economic Development Zone, Qingdao City,
ZIP	
City	Shandong Province
Country	CN
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Subtype title	R290 Monobloc 08/10 kW
Registration number	011-1W0828
Heat Pump Type	Outdoor Air/Water
Refrigerant	R290
Mass of Refrigerant	0.9 kg
Certification Date	27.08.2024
Testing basis	HP KEYMARK certification scheme rules V14

Model AW082MUGHA

Model name	AW082MUGHA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	8.00 kW	8.00 kW
El input	1.50 kW	2.35 kW
COP	5.35	3.40

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	59 dB(A)	64 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	205 %	151 %
Prated	7.20 kW	6.00 kW
SCOP	5.20	3.85
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	6.34 kW	5.28 kW
COP Tj = -7°C	3.43	2.48
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.89 kW	3.24 kW
COP Tj = +2°C	5.01	3.65
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.52 kW	2.10 kW

COP Tj = +7°C	6.88	5.43
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.56 kW	3.22 kW
COP Tj = 12°C	8.83	6.70
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.34 kW	5.28 kW
COP Tj = Tbiv	3.43	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.11 kW	5.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.34	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	80 °C	80 °C
Poff	18 W	18 W
PTO	18 W	18 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.09 kW	0.05 kW
Annual energy consumption Qhe	2866 kWh	3223 kWh

Model AW102MUGHA

Model name	AW102MUGHA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	1x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.00 kW	10.00 kW
El input	1.96 kW	3.13 kW
COP	5.10	3.20

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	66 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	201 %	150 %
Prated	7.20 kW	6.00 kW
SCOP	5.10	3.83
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	6.34 kW	5.28 kW
COP Tj = -7°C	3.43	2.48
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.89 kW	3.24 kW
COP Tj = +2°C	4.88	3.62
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.52 kW	2.10 kW

COP Tj = +7°C	6.88	5.38
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.56 kW	3.22 kW
COP Tj = 12°C	8.83	6.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.34 kW	5.28 kW
COP Tj = Tbiv	3.43	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.11 kW	5.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	80 °C	80 °C
Poff	18 W	18 W
PTO	18 W	18 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.09 kW	0.05 kW
Annual energy consumption Qhe	2922 kWh	3240 kWh

Model AW10NMUGHA

Model name	AW10NMUGHA
Application	Heating (medium temp)
Units	Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

General data

Power supply	3x230V 50Hz
Off-peak product	n/a

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	10.00 kW	10.00 kW
El input	1.96 kW	3.13 kW
COP	5.10	3.20

EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	66 dB(A)

EN 14825 | Average Climate

	Low temperature	Medium temperature
η_s	201 %	150 %
Prated	7.20 kW	6.00 kW
SCOP	5.10	3.83
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	6.34 kW	5.28 kW
COP Tj = -7°C	3.43	2.48
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.89 kW	3.24 kW
COP Tj = +2°C	4.88	3.62
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	2.52 kW	2.10 kW

COP Tj = +7°C	6.88	5.38
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.56 kW	3.22 kW
COP Tj = 12°C	8.83	6.66
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	6.34 kW	5.28 kW
COP Tj = Tbiv	3.43	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.11 kW	5.95 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.84
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	80 °C	80 °C
Poff	18 W	18 W
PTO	18 W	18 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.09 kW	0.05 kW
Annual energy consumption Qhe	2922 kWh	3240 kWh