

Subtype Inverter Air Source Heat Pump- R32- 15

| | |
|---------------------|---|
| Certificate Holder | Guangzhou Dentwiton Manufacture Co., Ltd. |
| Address | No.3, No. 9, Huasheng Beiroad, Xicheng industry zone, Renhe town, Baiyun district, |
| ZIP | |
| City | Guangzhou |
| Country | CN |
| Certification Body | BRE Global Limited |
| Subtype title | Inverter Air Source Heat Pump- R32- 15 |
| Registration number | 041-K077-03 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R32 |
| Mass of Refrigerant | 2.4 kg |
| Certification Date | 24.11.2023 |
| Testing basis | Heat Pump KEYMARK certification Scheme rules v12 |
| Testing laboratory | TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN |

Model RS15V/L

| | |
|-------------------------------------|-----------------------|
| Model name | RS15V/L |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

General data

| | |
|------------------|-------------|
| Power supply | 3x400V 50Hz |
| Off-peak product | n/a |

Outdoor Air/Water

EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

| | |
|-------------------------------|--------|
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|-------------|-----------------|--------------------|
| Heat output | 15.03 kW | 15.82 kW |
| El input | 3.25 kW | 5.28 kW |
| COP | 4.63 | 2.99 |

EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level outdoor | 68 dB(A) | 69 dB(A) |

EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|----------------|-----------------|--------------------|
| η_s | 177 % | 133 % |
| Prated | 14.57 kW | 13.59 kW |
| SCOP | 4.51 | 3.39 |
| Tbiv | -7 °C | -7 °C |
| TOL | -25 °C | -25 °C |
| Pdh Tj = -7°C | 12.89 kW | 12.02 kW |
| COP Tj = -7°C | 3.07 | 2.39 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 7.69 kW | 7.19 kW |
| COP Tj = +2°C | 4.53 | 3.34 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = +7°C | 8.10 kW | 7.62 kW |

| | | |
|---|-------------|-------------|
| COP Tj = +7°C | 6.21 | 4.56 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 9.10 kW | 8.77 kW |
| COP Tj = 12°C | 8.02 | 6.15 |
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 12.89 kW | 12.02 kW |
| COP Tj = Tbiv | 3.07 | 2.39 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 12.88 kW | 12.38 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.84 | 2.17 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 55 °C | 55 °C |
| Poff | 18 W | 18 W |
| PTO | 18 W | 18 W |
| PSB | 18 W | 18 W |
| PCK | 0 W | 0 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.70 kW | 1.21 kW |
| Annual energy consumption Qhe | 6678 kWh | 8272 kWh |