

## Subtype DM Ecoline - R32 - 09

Certificate Holder	Dream Maker Technologie GmbH
Address	Zimmerbachstr.37
ZIP	74676
City	Niedernhall
Country	DE
Certification Body	BRE Global Limited
Subtype title	DM Ecoline - R32 - 09
Registration number	041-K043-01
Heat Pump Type	Outdoor Air/Water
Refrigerant	R32
Mass of Refrigerant	1.4 kg
Certification Date	02.02.2023
Testing basis	Heat Pump Keymark Scheme Rules Rev 09
Testing laboratory	TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN

## Model DM Ecoline Monoblock 9kw-O / DM Ecoline Monoblock 9kw-I

Model name	DM Ecoline Monoblock 9kw-O / DM Ecoline Monoblock 9kw-I
Application	Heating (medium temp)
Units	Indoor, Outdoor
Climate zone (for heating)	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a
Any additional heat sources	n/a

## General data

Power supply	1x230V 50Hz
Off-peak product	n/a

## Outdoor Air/Water

## EN 14511-4 | Heating

Shutting off the heat transfer medium flow passed

Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## EN 14511-2 | Heating

	Low temperature	Medium temperature
Heat output	5.72 kW	8.04 kW
El input	1.09 kW	3.16 kW
COP	5.26	2.54

## EN 12102-1 | Average Climate

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	46 dB(A)
Sound power level outdoor	53 dB(A)	54 dB(A)

## EN 14825 | Average Climate

	Low temperature	Medium temperature
$\eta_s$	181 %	130 %
Prated	6.39 kW	5.97 kW
SCOP	4.61	3.32
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.65 kW	5.28 kW
COP Tj = -7°C	3.19	1.94
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	3.52 kW	3.41 kW
COP Tj = +2°C	4.43	3.34

Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.36 kW	3.15 kW
COP Tj = +7°C	6.36	4.60
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.96 kW	3.73 kW
COP Tj = 12°C	8.37	6.49
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.65 kW	5.28 kW
COP Tj = Tbiv	3.19	1.94
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.32 kW	4.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.82	1.71
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	57 °C	57 °C
Poff	10 W	10 W
PTO	19 W	19 W
PSB	10 W	10 W
PCK	27 W	27 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.07 kW	1.17 kW
Annual energy consumption Qhe	2864 kWh	3720 kWh